

令和4年2月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 分水井 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	3.0	7.4	3.6	7.81	55.3	69.2	146	9.2	0.59	0.03	
2	晴	1.5	6.9	6.4	7.75							
3	晴	0.5	7.4	6.3	7.80							
4	曇	4.0	8.0	7.4	7.81							
5	晴	1.0	7.1	6.6	7.75							
6	晴	-2.0	7.1	4.8	7.81							
7	晴	2.0	6.8	3.8	7.83							
8	曇	3.0	7.4	2.7	7.80							
9	晴	3.0	8.0	3.0	7.99							
10	雨	3.0	7.5	3.2	7.78							
11	曇	1.5	5.5	3.9	7.63							
12	晴	1.5	7.8	3.9	7.77							
13	曇	3.5	7.8	6.9	7.74							
14	雨	4.5	7.3	2.7	7.76							
15	曇	2.5	7.6	4.2	7.68	54.4	81.0	138	12.3	0.47	0.02	
16	晴	5.0	8.4	3.1	7.81							
17	晴	-0.5	8.3	3.1	7.80							
18	晴	3.0	7.4	3.6	7.78							
19	曇	2.0	7.9	2.9	7.77							
20	雨	7.5	8.2	3.0	7.76							
21	晴	-0.5	9.2	7.7	7.78							
22	晴	-1.0	7.5	3.5	7.82							
23	晴	-1.0	7.4	3.7	7.78							
24	晴	2.5	7.4	3.8	7.76							
25	晴	3.5	8.0	3.5	7.80							
26	晴	3.0	7.9	3.3	7.75							
27	晴	1.0	8.6	3.7	7.76							
28	晴	2.0	9.2	3.5	7.82							
29												
30												
31												
平均		2.1	7.7	4.2	7.78	54.8	75.1	142	10.7	0.53	0.02	
最高		7.5	9.2	7.7	7.99	55.3	81.0	146	12.3	0.59	0.03	
最低		-2.0	5.5	2.7	7.63	54.4	69.2	138	9.2	0.47	0.02	

令和4年2月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 浄水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	3.0	7.1	0.6	7.62	54.4	69.7	140	9.5	0.07	<0.02	
2	晴	1.5	6.5	1.0	7.52							
3	晴	0.5	6.8	0.9	7.58							
4	曇	4.0	7.6	1.0	7.55							
5	晴	1.0	7.0	0.9	7.54							
6	晴	-2.0	7.1	1.3	7.53							
7	晴	2.0	6.8	1.2	7.60							
8	曇	3.0	7.0	0.8	7.60							
9	晴	3.0	7.4	0.9	7.61							
10	雨	3.0	7.2	1.0	7.56							
11	曇	1.5	7.1	1.2	7.53							
12	晴	1.5	6.6	0.9	7.61							
13	曇	3.5	7.5	1.6	7.47							
14	雨	4.5	7.4	0.9	7.56							
15	曇	2.5	7.4	1.0	7.45	51.5	73.8	131	12.7	0.06	<0.02	
16	晴	5.0	8.0	0.9	7.54							
17	晴	-0.5	7.6	1.1	7.50							
18	晴	3.0	7.5	1.0	7.56							
19	曇	2.0	6.9	0.9	7.57							
20	雨	7.5	7.8	1.0	7.56							
21	晴	-0.5	8.6	1.3	7.57							
22	晴	-1.0	7.4	0.9	7.61							
23	晴	-1.0	7.2	1.0	7.57							
24	晴	2.5	7.1	1.1	7.53							
25	晴	3.5	7.2	1.0	7.57							
26	晴	3.0	7.1	0.9	7.53							
27	晴	1.0	7.5	1.0	7.56							
28	晴	2.0	8.5	1.1	7.61							
29												
30												
31												
平均		2.1	7.3	1.0	7.56	52.9	71.8	136	11.1	0.06	<0.02	
最高		7.5	8.6	1.6	7.62	54.4	73.8	140	12.7	0.07	<0.02	
最低		-2.0	6.5	0.6	7.45	51.5	69.7	131	9.5	0.06	<0.02	