

令和4年3月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 分水井 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	2.5	8.8	3.6	7.73							
2	晴	8.0	10.1	4.5	7.78	59.0	76.5	158	11.2	0.50	0.03	
3	晴	5.0	10.5	4.0	7.72							
4	曇	7.0	11.0	4.3	7.80							
5	晴	3.5	10.1	4.4	7.76							
6	晴	8.0	10.8	5.3	7.81							
7	晴	4.5	9.4	5.5	7.76							
8	晴	4.5	8.9	4.6	7.78							
9	晴	6.0	10.4	4.3	7.75							
10	晴	2.5	10.1	4.9	7.75							
11	晴	5.0	11.0	6.2	7.80							
12	晴	5.5	11.0	8.1	7.80							
13	晴	8.5	12.6	4.5	7.82							
14	雨	14.0	13.1	4.9	7.84							
15	曇	16.0	14.1	8.8	7.77	56.0	74.8	165	9.6	0.95	0.04	
16	晴	8.0	12.8	7.6	7.78							
17	晴	9.0	12.7	5.2	7.77							
18	曇	11.0	11.9	7.7	7.66							
19	晴	8.5	11.0	6.1	7.73							
20	曇	9.0	11.1	35.6	7.72							
21	晴	9.5	11.5	13.7	7.74							
22	雨	9.0	11.4	5.7	7.79							
23	晴	2.5	9.5	9.8	7.72							
24	晴	4.0	9.4	6.5	7.81							
25	晴	5.5	12.2	7.3	7.79							
26	曇	10.5	12.7	5.9	7.80							
27	曇	16.0	12.8	14.6	7.81							
28	曇	12.5	12.7	34.5	7.73							
29	曇	11.5	12.7	18.6	7.82							
30	雨	12.0	12.0	20.6	7.81							
31	晴	11.5	13.9	24.1	7.85							
平均		8.1	11.4	9.7	7.77	57.5	75.7	162	10.4	0.72	0.03	
最高		16.0	14.1	35.6	7.85	59.0	76.5	165	11.2	0.95	0.04	
最低		2.5	8.8	3.6	7.66	56.0	74.8	158	9.6	0.50	0.03	

令和4年3月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 浄水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	2.5	8.4	1.3	7.56							
2	晴	8.0	9.8	1.0	7.55	52.3	70.3	138	10.3	0.06	<0.02	
3	晴	5.0	9.8	1.3	7.58							
4	曇	7.0	10.5	1.4	7.58							
5	晴	3.5	9.4	1.2	7.57							
6	晴	8.0	10.2	1.5	7.59							
7	晴	4.5	8.9	1.4	7.61							
8	晴	4.5	8.9	1.3	7.55							
9	晴	6.0	9.4	1.3	7.53							
10	晴	2.5	9.8	1.3	7.51							
11	晴	5.0	10.6	1.3	7.56							
12	晴	5.5	10.3	1.6	7.56							
13	晴	8.5	11.9	1.9	7.57							
14	雨	14.0	12.9	1.5	7.60							
15	曇	16.0	14.3	1.7	7.63	53.5	73.6	143	10.7	0.07	<0.02	
16	晴	8.0	13.3	1.8	7.56							
17	晴	9.0	12.4	1.2	7.53							
18	曇	11.0	12.7	0.9	7.51							
19	晴	8.5	11.9	0.9	7.51							
20	曇	9.0	10.9	2.3	7.34							
21	晴	9.5	11.1	1.1	7.56							
22	雨	9.0	11.5	0.7	7.54							
23	晴	2.5	10.2	0.7	7.54							
24	晴	4.0	9.4	0.9	7.51							
25	晴	5.5	10.7	0.7	7.53							
26	曇	10.5	11.9	0.6	7.52							
27	曇	16.0	13.5	0.7	7.53							
28	曇	12.5	12.8	1.4	7.37							
29	曇	11.5	13.2	0.9	7.43							
30	雨	12.0	12.5	0.7	7.48							
31	晴	11.5	12.9	0.5	7.53							
平均		8.1	11.2	1.2	7.53	52.9	72.0	141	10.5	0.06	<0.02	
最高		16.0	14.3	2.3	7.63	53.5	73.6	143	10.7	0.07	<0.02	
最低		2.5	8.4	0.5	7.34	52.3	70.3	138	10.3	0.06	<0.02	