

令和5年2月分

ふじさん工業用水道 (東駿河湾) 水質試験結果報告書 (静清庵)

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 分水井 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	2.0	7.1	3.9	7.83							
2	曇	7.0	7.7	6.0	7.84							
3	曇	3.0	7.4	7.1	7.86							
4	曇	3.0	7.8	4.4	7.91							
5	晴	2.0	8.2	4.9	7.90							
6	晴	2.0	8.3	3.5	7.80							
7	曇	6.0	8.9	3.7	7.81							
8	曇	5.0	9.5	3.7	7.80	59.5	81.1	191	12.2	1.36	0.04	
9	晴	5.0	9.0	8.1	7.86							
10	雨	5.0	9.0	6.3	7.90							
11	晴	7.0	5.4	9.2	7.75							
12	曇	7.5	8.6	8.4	7.76							
13	雨	9.0	10.4	5.3	7.78							
14	曇	5.0	9.2	10.7	7.79							
15	曇	3.0	8.0	15.8	7.77	55.9	76.6	171	11.7	0.87	0.03	
16	晴	1.5	7.0	6.4	7.80							
17	晴	0.5	7.7	4.8	7.79							
18	晴	2.5	8.7	4.4	7.80							
19	雨	13.0	10.7	4.1	7.78							
20	晴	5.5	8.6	286.0	7.75							
21	晴	3.0	8.5	52.3	7.76							
22	晴	2.5	7.0	16.8	7.78							
23	曇	4.5	7.7	7.7	7.75							
24	曇	5.0	8.3	8.4	7.76							
25	晴	4.0	8.3	5.1	7.78							
26	晴	3.0	8.0	4.4	7.71							
27	晴	5.5	7.9	3.2	7.79							
28	晴	3.5	8.5	3.6	7.78							
29												
30												
31												
平均		4.5	8.3	18.1	7.80	57.7	78.9	181	11.9	1.11	0.03	
最高		13.0	10.7	286.0	7.91	59.5	81.1	191	12.2	1.36	0.04	
最低		0.5	5.4	3.2	7.71	55.9	76.6	171	11.7	0.87	0.03	

令和5年2月分

ふじさん工業用水道(東駿河湾)水質試験結果報告書(静岡庵)

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 浄水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	2.0	6.8	1.1	7.53							
2	曇	7.0	8.0	0.9	7.47							
3	曇	3.0	7.7	1.0	7.53							
4	曇	3.0	7.8	1.1	7.50							
5	晴	2.0	7.9	1.4	7.54							
6	晴	2.0	7.8	1.1	7.56							
7	曇	6.0	8.8	1.0	7.56							
8	曇	5.0	9.1	1.1	7.57	53.0	72.2	150	11.2	0.07	<0.02	
9	晴	5.0	8.8	1.3	7.56							
10	雨	5.0	8.8	1.1	7.55							
11	晴	7.0	8.4	1.2	7.50							
12	曇	7.5	7.3	1.3	7.48							
13	雨	9.0	9.4	1.2	7.50							
14	曇	5.0	9.5	1.0	7.55							
15	曇	3.0	8.4	1.2	7.45	51.0	73.5	152	11.8	0.06	<0.02	
16	晴	1.5	6.7	1.1	7.49							
17	晴	0.5	7.2	1.1	7.55							
18	晴	2.5	8.1	1.0	7.50							
19	雨	13.0	10.9	1.1	7.40							
20	晴	5.5	10.0	0.9	7.45							
21	晴	3.0	8.3	1.4	7.38							
22	晴	2.5	7.1	1.2	7.46							
23	曇	4.5	7.6	1.0	7.44							
24	曇	5.0	8.7	0.6	7.52							
25	晴	4.0	8.1	1.0	7.51							
26	晴	3.0	7.6	0.6	7.50							
27	晴	5.5	7.5	0.7	7.60							
28	晴	3.5	7.6	0.8	7.65							
29												
30												
31												
平均		4.5	8.2	1.1	7.51	52.0	72.9	151	11.5	0.06	<0.02	
最高		13.0	10.9	1.4	7.65	53.0	73.5	152	11.8	0.07	<0.02	
最低		0.5	6.7	0.6	7.38	51.0	72.2	150	11.2	0.06	<0.02	