

令和6年7月分

ふじさん工業用水道 (東駿河湾) 水質試験結果報告書 (静清庵)

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 分水井 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	26.0	19.9	109.0	7.67	39.5	53.0	257	2.4	4.29	0.08	
2	曇	24.5	19.9	436.0	7.75							
3	曇	24.0	20.7	207.0	7.72							
4	晴	26.0	20.6	103.0	7.72							
5	晴	24.5	21.6	51.9	7.76							
6	晴	27.0	22.1	35.4	7.70							
7	晴	25.0	20.7	21.1	7.63							
8	晴	28.0	22.7	17.6	7.75							
9	晴	27.0	21.1	16.7	7.76							
10	晴	25.0	20.7	14.4	7.70							
11	曇	26.5	21.5	11.7	7.79							
12	曇	25.0	20.5	10.7	7.72							
13	曇	22.0	20.4	123.0	7.63							
14	曇	23.5	21.7	70.6	7.70							
15	曇	25.5	22.5	19.7	7.76							
16	雨	24.0	21.4	14.2	7.79	45.8	60.4	163	3.7	0.49	0.04	
17	曇	25.0	21.2	63.6	7.72							
18	晴	24.5	22.1	123.0	7.69							
19	晴	25.0	22.2	79.2	7.78							
20	晴	27.0	22.0	47.8	7.64							
21	晴	27.5	22.3	18.6	7.74							
22	晴	27.5	23.1	14.7	7.69							
23	晴	27.0	23.3	27.7	7.58							
24	曇	28.0	23.5	28.1	7.60							
25	晴	27.5	23.9	27.1	7.63							
26	晴	26.0	24.7	22.0	7.66							
27	曇	28.5	24.1	16.8	7.79							
28	晴	31.0	25.5	7.6	8.24							
29	晴	30.0	26.5	8.1	8.17							
30	晴	29.0	25.9	5.6	7.93							
31	晴	32.0	25.1	6.3	7.83							
平均		26.4	22.4	56.7	7.75	42.6	56.7	210	3.1	2.39	0.06	
最高		32.0	26.5	436.0	8.24	45.8	60.4	257	3.7	4.29	0.08	
最低		22.0	19.9	5.6	7.58	39.5	53.0	163	2.4	0.49	0.04	

令和6年7月分

ふじさん工業用水道 (東駿河湾) 水質試験結果報告書 (静岡庵)

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 浄水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	26.0	21.5	0.6	7.39	36.0	47.9	145	6.0	0.01	<0.02	
2	曇	24.5	20.1	0.5	7.30							
3	曇	24.0	21.3	0.4	7.27							
4	晴	26.0	21.4	0.4	7.42							
5	晴	24.5	22.1	0.8	7.41							
6	晴	27.0	22.5	1.0	7.37							
7	晴	25.0	22.0	1.0	7.40							
8	晴	28.0	22.5	1.2	7.50							
9	晴	27.0	22.6	1.1	7.54							
10	晴	25.0	22.0	1.0	7.56							
11	曇	26.5	22.9	1.1	7.58							
12	曇	25.0	22.0	1.3	7.57							
13	曇	22.0	21.6	1.1	7.40							
14	曇	23.5	22.0	0.7	7.39							
15	曇	25.5	22.8	1.1	7.43							
16	雨	24.0	23.6	1.4	7.61	44.6	57.1	164	3.9	0.02	<0.02	
17	曇	25.0	22.1	1.5	7.50							
18	晴	24.5	24.0	0.8	7.45							
19	晴	25.0	22.8	0.9	7.51							
20	晴	27.0	23.1	1.4	7.42							
21	晴	27.5	23.3	1.4	7.51							
22	晴	27.5	24.2	1.6	7.58							
23	晴	27.0	24.7	1.2	7.58							
24	曇	28.0	25.6	1.2	7.59							
25	晴	27.5	25.3	1.2	7.60							
26	晴	26.0	24.7	1.9	7.63							
27	曇	28.5	24.6	2.1	7.78							
28	晴	31.0	25.8	2.1	7.72							
29	晴	30.0	26.3	1.3	7.57							
30	晴	29.0	25.2	1.8	7.77							
31	晴	32.0	26.0	1.2	7.70							
平均		26.4	23.2	1.2	7.52	40.3	52.5	155	5.0	0.02	<0.02	
最高		32.0	26.3	2.1	7.78	44.6	57.1	164	6.0	0.02	<0.02	
最低		22.0	20.1	0.4	7.27	36.0	47.9	145	3.9	0.01	<0.02	