

令和6年12月分

ふじさん工業用水道 (東駿河湾) 水質試験結果報告書 (静岡庵)

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 分水井 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	7.0	11.0	7.0	7.80							
2	晴	8.0	10.9	3.5	7.75	55.2	73.6	137	7.3	0.13	<0.02	
3	晴	9.0	11.6	16.2	7.62							
4	晴	7.0	12.0	12.3	7.68							
5	曇	9.5	12.0	9.3	7.82							
6	晴	7.0	10.7	6.9	7.67							
7	晴	3.0	10.9	8.2	7.70							
8	晴	6.0										計画断水
9	晴	6.0	9.7	12.4	7.78							
10	晴	5.5	9.2	4.7	7.75							
11	晴	6.0	9.3	4.3	7.79							
12	晴	6.5	9.7	2.9	7.77							
13	晴	3.5	8.6	3.3	7.83							
14	晴	7.5	9.0	10.4	7.62							
15	晴	0.0	8.6	3.8	7.65							
16	晴	1.5	7.7	2.6	7.70	54.6	69.9	176	8.0	0.08	<0.02	
17	晴	1.0	8.8	2.5	7.89							
18	晴	0.5	9.0	11.0	7.60							
19	晴	6.0	9.1	11.2	7.74							
20	晴	3.5	8.3	2.8	7.77							
21	晴	4.0	7.6	19.6	7.89							
22	晴	8.5	8.2	2.7	7.80							
23	晴	3.0	8.5	2.4	7.78							
24	晴	-0.5	7.7	8.3	7.74							
25	晴	6.0	7.8	2.2	7.75							
26	晴	4.0	8.1	2.4	7.78							
27	晴	1.0	8.9	3.2	7.76							
28	晴	1.5	7.7	3.0	7.87							
29	晴	0.0	8.2	2.8	7.81							
30	晴	3.0	6.8	5.1	7.69							
31	晴	3.0	6.9	4.1	7.72							
平均		4.4	9.1	6.4	7.75	54.9	71.7	157	7.7	0.10	<0.02	
最高		9.5	12.0	19.6	7.89	55.2	73.6	176	8.0	0.13	<0.02	
最低		-0.5	6.8	2.2	7.60	54.6	69.9	137	7.3	0.08	<0.02	

令和6年12月分

ふじさん工業用水道 (東駿河湾) 水質試験結果報告書 (静岡庵)

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 浄水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	7.0	11.1	1.0	7.52							
2	晴	8.0	10.9	0.8	7.47	52.2	72.1	131	7.2	0.04	<0.02	
3	晴	9.0	11.7	1.0	7.58							
4	晴	7.0	12.1	1.3	7.59							
5	曇	9.5	12.1	1.1	7.54							
6	晴	7.0	10.9	1.1	7.50							
7	晴	3.0	11.1	0.3	7.52							
8	晴	6.0										計画断水
9	晴	6.0	10.6	1.0	7.65							
10	晴	5.5	9.3	0.8	7.58							
11	晴	6.0	9.6	0.7	7.62							
12	晴	6.5	9.7	1.0	7.59							
13	晴	3.5	8.7	0.8	7.59							
14	晴	7.5	9.1	1.0	7.52							
15	晴	0.0	8.7	1.1	7.48							
16	晴	1.5	7.8	1.0	7.47	52.8	69.1	139	8.3	0.03	<0.02	
17	晴	1.0	8.7	0.6	7.61							
18	晴	0.5	8.7	1.1	7.45							
19	晴	6.0	9.1	1.0	7.55							
20	晴	3.5	8.8	1.1	7.62							
21	晴	4.0	7.8	0.9	7.60							
22	晴	8.5	8.6	1.2	7.52							
23	晴	3.0	8.5	1.2	7.56							
24	晴	-0.5	7.9	0.7	7.52							
25	晴	6.0	7.8	1.0	7.54							
26	晴	4.0	7.9	1.3	7.59							
27	晴	1.0	8.3	1.5	7.49							
28	晴	1.5	8.1	1.3	7.48							
29	晴	0.0	8.2	1.0	7.50							
30	晴	3.0	7.6	1.1	7.54							
31	晴	3.0	7.6	0.8	7.56							
平均		4.4	9.2	1.0	7.55	52.5	70.6	135	7.8	0.03	<0.02	
最高		9.5	12.1	1.5	7.65	52.8	72.1	139	8.3	0.04	<0.02	
最低		-0.5	7.6	0.3	7.45	52.2	69.1	131	7.2	0.03	<0.02	