

令和7年2月分

ふじさん工業用水道 (東駿河湾) 水質試験結果報告書 (静清庵)

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 分水井 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	4.0	8.5	3.5	7.69							
2	雨	4.5	8.2	3.7	7.75							
3	曇	6.0	9.1	3.2	7.76	55.9	71.5	154	11.1	0.10	<0.02	
4	晴	1.5	8.6	3.1	7.77							
5	晴	2.0	7.9	3.5	7.64							
6	晴	0.0	7.3	3.3	7.73							
7	晴	-2.5	7.0	4.4	7.70							
8	晴	-1.0	7.4	4.2	7.73							
9	晴	2.5	7.7	3.2	7.61							
10	晴	-0.5	7.0	2.8	7.70							
11	晴	-1.0	8.0	4.0	7.62							
12	晴	3.0	8.6	4.1	7.70							
13	晴	8.0	8.1	5.2	7.71							
14	曇	9.0	9.4	6.4	7.67							
15	晴	4.5	9.5	6.1	7.66							
16	曇	7.5	9.5	4.8	7.70							
17	晴	6.0	10.9	3.6	7.68							
18	晴	3.0	10.0	3.5	7.72	57.6	73.7	178	11.0	0.08	<0.02	
19	晴	-0.5	8.3	3.8	7.69							
20	晴	3.0	7.5	4.0	7.73							
21	晴	2.0	8.2	3.0	7.66							
22	晴	-1.0	8.1	3.8	7.66							
23	晴	2.5	6.8	3.8	7.72							
24	晴	3.0	8.1	3.8	7.58							
25	晴	3.5	8.0	2.9	7.68							
26	晴	0.0	8.8	3.1	7.60							
27	晴	2.0	9.7	4.1	7.58							
28	晴	4.0	10.2	4.3	7.72							
29												
30												
31												
平均		2.7	8.4	3.9	7.68	56.7	72.6	166	11.1	0.09	<0.02	
最高		9.0	10.9	6.4	7.77	57.6	73.7	178	11.1	0.10	<0.02	
最低		-2.5	6.8	2.8	7.58	55.9	71.5	154	11.0	0.08	<0.02	

令和7年2月分

ふじさん工業用水道 (東駿河湾) 水質試験結果報告書 (静岡庵)

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 浄水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	4.0	7.9	1.5	7.60							
2	雨	4.5	7.6	0.9	7.55							
3	曇	6.0	8.8	1.1	7.53	53.1	73.0	141	11.0	0.05	<0.02	
4	晴	1.5	9.2	1.7	7.58							
5	晴	2.0	7.9	0.9	7.46							
6	晴	0.0	7.0	1.5	7.57							
7	晴	-2.5	7.0	1.2	7.50							
8	晴	-1.0	7.3	1.1	7.44							
9	晴	2.5	7.0	1.4	7.45							
10	晴	-0.5	6.8	1.0	7.53							
11	晴	-1.0	7.5	1.4	7.52							
12	晴	3.0	7.9	1.7	7.46							
13	晴	8.0	8.0	1.8	7.50							
14	曇	9.0	9.6	1.3	7.34							
15	晴	4.5	9.0	1.2	7.43							
16	曇	7.5	9.2	1.7	7.40							
17	晴	6.0	10.0	1.4	7.45							
18	晴	3.0	9.2	1.4	7.47	53.9	72.3	143	10.9	0.06	<0.02	
19	晴	-0.5	8.0	1.5	7.52							
20	晴	3.0	7.3	1.2	7.53							
21	晴	2.0	7.6	0.9	7.55							
22	晴	-1.0	8.0	1.2	7.49							
23	晴	2.5	7.0	1.1	7.50							
24	晴	3.0	7.4	1.3	7.46							
25	晴	3.5	7.2	1.0	7.54							
26	晴	0.0	8.0	1.0	7.60							
27	晴	2.0	9.0	1.2	7.49							
28	晴	4.0	9.5	1.4	7.47							
29												
30												
31												
平均		2.7	8.1	1.3	7.50	53.5	72.7	142	11.0	0.06	<0.02	
最高		9.0	10.0	1.8	7.60	53.9	73.0	143	11.0	0.06	<0.02	
最低		-2.5	6.8	0.9	7.34	53.1	72.3	141	10.9	0.05	<0.02	