

令和 2年 4月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇		10.4	10.8	7.78							
2	晴	12.7	10.4	9.5	7.76							
3	晴	14.4	10.5	28.1	7.63							
4	晴	14.5	10.6	22.1	7.61							
5	晴	13.2	12.0	24.6	7.63							
6	晴	11.9	10.7	21.1	7.66							
7	晴	12.4	10.8	27.2	7.66							
8	晴	15.6	11.0	28.4	7.60							
9	晴	14.8	11.1	23.8	7.63							
10	晴	13.0	11.4	27.6	7.53							
11	晴	11.3	10.9	21.7	7.51							
12	曇	13.2	12.4	23.4	7.67							
13	雨	11.4	10.9	23.9	7.71							
14	晴	11.9	10.8	26.7	7.65							
15	晴	14.5	11.0	25.2	7.66							
16	晴	17.4	12.0	18.8	7.49	34.0	40.0	70	4.2	0.10	<0.02	
17	晴	15.4	11.7	17.7	7.70							
18	雨	16.7	11.9	13.7	7.68							
19	晴	15.5	11.9	12.8	7.66							
20	雨	12.9	11.8	13.8	7.67							
21	晴	17.8	11.8	14.7	7.70							
22	曇	13.4	11.8	14.1	7.76							
23	晴	11.2	11.8	23.2	7.70							
24	晴	12.7	11.8	18.4	7.61							
25	晴	13.5	11.8	18.7	7.60							
26	晴	12.2	12.2	19.3	7.55							
27	晴	16.1	12.2	24.5	7.61							
28	晴	15.8	12.2	17.2	7.64	28.6	34.4	72	3.4	0.07	<0.02	
29	晴	15.8	12.3	14.2	7.51							
30	晴	19.5	12.2	15.4	7.56							
平均		14.2	11.5	20.0	7.64	31.3	37.2	71	3.8	0.08	<0.02	
最高		19.5	12.4	28.4	7.78	34.0	40.0	72	4.2	0.10	<0.02	
最低		11.2	10.4	9.5	7.49	28.6	34.4	70	3.4	0.07	<0.02	

令和 2年 4月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）								備考	
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L		マン ガン mg/L
1	曇		11.8	0.9	7.21							
2	晴	12.7	12.0	0.5	7.22							
3	晴	14.4	12.0	0.7	7.19							
4	晴	14.5	12.0	0.6	7.04							
5	晴	13.2	12.8	0.7	7.05							
6	晴	11.9	12.4	0.9	7.08							
7	晴	12.4	12.3	0.7	7.15							
8	晴	15.6	12.6	0.7	7.13							
9	晴	14.8	12.9	0.9	7.11							
10	晴	13.0	12.9	0.9	7.17							
11	晴	11.3	12.7	0.8	7.05							
12	曇	13.2	12.8	0.7	7.12							
13	雨	11.4	12.7	0.9	7.08							
14	晴	11.9	12.4	0.6	7.16							
15	晴	14.5	12.6	0.5	7.14							
16	晴	17.4	12.9	1.0	7.06	29.2	39.4	60	7.2	0.05	<0.02	
17	晴	15.4	13.1	1.4	7.16							
18	雨	16.7	13.7	0.9	7.06							
19	晴	15.5	13.5	0.1	7.17							
20	雨	12.9	13.7	0.2	7.09							
21	晴	17.8	13.7	0.5	7.10							
22	曇	13.4	13.6	1.0	7.05							
23	晴	11.2	13.4	0.9	7.04							
24	晴	12.7	13.3	0.5	6.93							
25	晴	13.5	13.4	1.1	6.86							
26	晴	12.2	13.5	0.6	6.90							
27	晴	16.1	14.0	1.0	7.00							
28	晴	15.8	14.2	0.2	7.01	24.9	34.5	86	6.8	<0.03	<0.02	
29	晴	15.8	14.3	0.4	6.92							
30	晴	19.5	14.4	0.8	6.96							
平均		14.2	13.1	0.7	7.07	27.1	37.0	73	7.0	0.04	<0.02	
最高		19.5	14.4	1.4	7.22	29.2	39.4	86	7.2	0.05	<0.02	
最低		11.2	11.8	0.1	6.86	24.9	34.5	60	6.8	<0.03	<0.02	