

令和 2年 8月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	28.6	19.4	207.3	7.58							
2	晴	27.3	19.3	177.3	7.67							
3	晴	28.2	20.0	155.2	7.69	35.1	38.2	230	1.8	0.05	<0.02	
4	晴	30.0	21.5	221.5	7.67							
5	晴	29.6	20.7	118.9	7.66							
6	曇	28.4	21.4	155.3	7.68							
7	晴	29.7	20.8	129.6	7.71							
8	晴	29.3	21.5	96.3	7.71							
9	晴	30.7	21.5	84.6	7.56							
10	晴	31.1	21.4	72.9	7.57							
11	曇	30.9	21.3	91.5	7.74							
12	晴	32.1	21.4	58.1	7.69							
13	晴	32.3	21.4	63.8	7.73							
14	曇	32.4	21.9	53.8	7.72							
15	晴	33.3	23.5	33.1	7.74							
16	晴	34.0	22.9	26.2	7.79							
17	晴	32.5	22.9	31.1	7.75	35.6	40.5	100	2.7	0.09	<0.02	
18	晴	31.4	22.9	21.2	7.76							
19	晴	31.5	22.9	23.7	7.75							
20	晴	30.7	22.9	18.6	7.78							
21	晴	31.9	23.5	15.4	7.77							
22	晴	31.3	25.7	14.0	7.80							
23	曇	26.6	23.1	11.9	7.81							
24	晴	29.1	23.7	12.9	7.77							
25	晴	29.9	23.5	11.8	7.71							
26	晴	29.6	24.1	9.5	7.70							
27	晴	30.6	23.6	11.8	7.77							
28	晴	29.9	23.5	12.6	7.78							
29	晴	30.4	23.5	12.8	7.81							
30	晴	31.1	25.8	11.4	7.79							
31	晴	30.6	23.5	8.3	7.79							
平均		30.5	22.4	63.6	7.72	35.4	39.4	165	2.3	0.07	<0.02	
最高		34.0	25.8	221.5	7.81	35.6	40.5	230	2.7	0.09	<0.02	
最低		26.6	19.3	8.3	7.56	35.1	38.2	100	1.8	0.05	<0.02	

令和 2年 8月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	28.6	22.4	0.7	6.57							
2	晴	27.3	22.9	0.7	6.65							
3	晴	28.2	23.2	0.9	6.68	25.0	37.7	66	9.7	<0.03	<0.02	
4	晴	30.0	23.3	1.2	6.65							
5	晴	29.6	23.5	0.9	6.70							
6	曇	28.4	24.1	0.9	6.76							
7	晴	29.7	23.9	1.3	6.77							
8	晴	29.3	24.1	1.0	6.76							
9	晴	30.7	24.5	0.9	6.77							
10	晴	31.1	24.9	1.2	6.77							
11	曇	30.9	25.0	1.0	6.84							
12	晴	32.1	25.2	0.6	6.90							
13	晴	32.3	25.8	0.5	6.91							
14	曇	32.4	25.8	0.3	6.91							
15	晴	33.3	25.9	0.4	6.93							
16	晴	34.0	26.5	0.3	6.97							
17	晴	32.5	26.7	0.6	7.00	30.0	39.7	50	6.8	<0.03	<0.02	
18	晴	31.4	26.7	0.6	7.02							
19	晴	31.5	26.3	0.4	7.02							
20	晴	30.7	26.6	0.6	7.05							
21	晴	31.9	26.8	0.9	7.05							
22	晴	31.3	26.9	0.3	7.08							
23	曇	26.6	27.0	0.2	7.08							
24	晴	29.1	27.2	0.5	7.13							
25	晴	29.9	27.2	0.4	7.10							
26	晴	29.6	27.0	1.0	7.07							
27	晴	30.6	27.4	0.5	7.11							
28	晴	29.9	27.5	0.8	7.17							
29	晴	30.4	26.8	0.4	7.10							
30	晴	31.1	27.0	0.2	7.11							
31	晴	30.6	27.2	0.3	7.13							
平均		30.5	25.7	0.7	6.93	27.5	38.7	58	8.2	<0.03	<0.02	
最高		34.0	27.5	1.3	7.17	30.0	39.7	66	9.7	<0.03	<0.02	
最低		26.6	22.4	0.2	6.57	25.0	37.7	50	6.8	<0.03	<0.02	