

令和 2年 9月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	28.2	23.6	6.1	7.79							
2	晴	31.4	25.9	7.5	7.73							
3	曇	28.6	25.3	9.1	7.78							
4	晴	27.8	23.6	9.0	7.77							
5	晴	30.0	24.2	6.9	7.59							
6	晴	29.8	23.6	9.1	7.73							
7	雨	28.6	25.9	8.8	7.76	39.8	44.4	80	3.8	0.14	<0.02	
8	曇	28.6	24.1	11.2	7.77							
9	晴	28.6	23.0	15.5	7.72							
10	晴	26.2	23.5	11.5	7.76							
11	晴	28.2	22.9	6.6	7.78							
12	曇	26.1	23.5	8.0	7.86							
13	晴	28.2	22.9	10.8	7.38							
14	晴	26.9	22.9	10.5	7.78							
15	晴	26.1	22.9	8.2	7.81							
16	曇	24.5	23.0	9.3	7.83							
17	曇	24.2	23.6	9.3	7.85							
18	曇	28.3	23.0	8.9	7.98							
19	曇	25.3	23.5	7.3	7.81							
20	雨	20.4	23.0	9.9	7.96							
21	晴	24.6	22.8	8.6	7.93							
22	晴	24.6	22.3	8.7	7.71							
23	晴	21.7	22.7	6.4	7.94	39.6	45.8	118	3.9	0.06	<0.02	
24	曇	24.8	21.8	11.9	8.06							
25	曇	24.9	22.9	6.2	7.74							
26	曇	23.3	21.4	6.5	7.75							
27	晴	21.5	23.8	9.3	7.62							
28	晴	23.5	21.8	8.8	7.75							
29	晴	22.3	21.8	8.1	7.68							
30	晴	21.5	21.3	7.4	7.68							
平均		26.0	23.2	8.8	7.78	39.7	45.1	99	3.9	0.10	<0.02	
最高		31.4	25.9	15.5	8.06	39.8	45.8	118	3.9	0.14	<0.02	
最低		20.4	21.3	6.1	7.38	39.6	44.4	80	3.8	0.06	<0.02	

令和 2年 9月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	28.2	27.2	0.6	7.21							
2	晴	31.4	27.2	0.6	7.13							
3	曇	28.6	27.0	0.6	7.02							
4	晴	27.8	26.8	0.6	6.93							
5	晴	30.0	26.6	0.6	7.05							
6	晴	29.8	26.8	0.4	7.11							
7	雨	28.6	26.6	0.4	7.11	35.2	43.2	66	6.6	0.03	<0.02	
8	曇	28.6	26.5	0.2	7.13							
9	晴	28.6	26.1	0.2	6.99							
10	晴	26.2	25.9	0.4	7.08							
11	晴	28.2	25.8	0.2	7.12							
12	曇	26.1	25.8	0.4	7.79							
13	晴	28.2	25.9	0.4	7.08							
14	晴	26.9	25.8	0.4	7.18							
15	晴	26.1	25.6	0.5	7.19							
16	曇	24.5	25.3	0.6	7.17							
17	曇	24.2	25.3	0.9	7.15							
18	曇	28.3	25.3	0.6	7.09							
19	曇	25.3	25.5	0.3	7.18							
20	雨	20.4	25.3	0.2	7.32							
21	晴	24.6	24.9	0.1	7.36							
22	晴	24.6	24.9	0.1	7.31							
23	晴	21.7	24.6	0.4	7.36	35.8	44.6	100	6.9	0.03	<0.02	
24	曇	24.8	24.4	0.5	7.87							
25	曇	24.9	24.6	0.5	7.60							
26	曇	23.3	24.3	0.4	6.98							
27	晴	21.5	23.9	0.7	7.00							
28	晴	23.5	24.1	0.0	7.02							
29	晴	22.3	24.3	0.8	6.96							
30	晴	21.5	24.4	0.6	6.95							
平均		26.0	25.6	0.4	7.18	35.5	43.9	83	6.8	0.03	<0.02	
最高		31.4	27.2	0.9	7.87	35.8	44.6	100	6.9	0.03	<0.02	
最低		20.4	23.9	0.0	6.93	35.2	43.2	66	6.6	0.03	<0.02	