

令和 2年 11月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)								備考	
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L		マン ガン mg/L
1	晴	16.2	13.9	13.4	7.25							
2	雨	16.9	13.9	14.8	7.67							
3	晴	16.9	16.5	12.9	7.58							
4	晴	11.7	13.2	14.1	7.50							
5	晴	13.4	13.3	9.3	7.69							
6	曇	13.6	12.8	12.2	7.74							
7	曇	17.0	12.8	9.4	7.61							
8	曇	17.5	13.2	9.3	7.50							
9	晴	14.9	12.8	14.1	7.59	40.4	46.0	66.0	3.6	0.11	<0.02	
10	晴	11.9	12.7	7.0	7.71							
11	晴	12.0	12.7	6.7	7.69							
12	曇	11.8	12.2	8.9	7.68							
13	晴	14.5	11.3	13.7	7.66							
14	晴	16.5	11.5	9.4	7.48							
15	晴	15.9	11.4	7.9	7.46							
16	晴	19.0	11.4	9.3	7.76							
17	晴	16.5	11.3	8.3	7.68							
18	晴	19.3	11.6	8.5	7.69							
19	曇	19.0	12.1	6.5	7.74							
20	雨	20.0	12.0	8.8	7.71							
21	晴	16.1	11.2	6.5	7.22							
22	晴	16.1	11.1	7.7	7.81							
23	晴	16.7	11.3	6.9	7.73							
24	晴	13.1	11.1	6.0	7.74	40.8	46.8	86.0	4.1	0.07	<0.02	
25	晴	14.6	11.0	11.0	7.79							
26	晴	12.4	10.9	7.2	7.85							
27	晴	13.3	10.9	8.4	7.60							
28	晴	13.3	10.7	5.7	7.52							
29	晴	9.7	10.7	5.1	7.71							
30	曇	10.5	12.7	6.0	7.78							
平均		15.0	12.1	9.2	7.64	40.6	46.4	76.0	3.8	0.09	<0.02	
最高		20.0	16.5	14.8	7.85	40.8	46.8	86.0	4.1	0.11	<0.02	
最低		9.7	10.7	5.1	7.22	40.4	46.0	66.0	3.6	0.07	<0.02	

令和 2年 11月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	16.2	17.1	0.3	6.80							
2	雨	16.9	16.9	0.6	7.11							
3	晴	16.9	17.0	0.5	7.01							
4	晴	11.7	16.7	0.4	7.05							
5	晴	13.4	16.2	0.5	6.99							
6	曇	13.6	16.2	0.4	6.98							
7	曇	17.0	16.0	0.4	6.90							
8	曇	17.5	16.2	0.2	6.66							
9	晴	14.9	16.1	0.3	7.04	35.3	45.6	44.0	6.0	<0.03	<0.02	
10	晴	11.9	15.8	0.6	7.13							
11	晴	12.0	15.5	0.6	7.18							
12	曇	11.8	15.4	0.6	7.18							
13	晴	14.5	15.1	0.7	7.07							
14	晴	16.5	15.0	0.5	6.90							
15	晴	15.9	15.1	0.3	7.00							
16	晴	19.0	15.2	0.3	7.13							
17	晴	16.5	15.2	0.0	7.13							
18	晴	19.3	15.3	0.2	7.17							
19	曇	19.0	15.4	0.2	7.16							
20	雨	20.0	15.5	0.3	7.18							
21	晴	16.1	15.5	0.1	7.10							
22	晴	16.1	15.4	0.2	7.15							
23	晴	16.7	15.2	0.1	7.16							
24	晴	13.1	14.9	0.3	7.17	37.1	47.0	62.0	7.0	<0.03	<0.02	
25	晴	14.6	14.9	0.2	7.10							
26	晴	12.4	14.6	0.4	7.12							
27	晴	13.3	14.5	0.4	7.12							
28	晴	13.3	14.5	0.3	6.97							
29	晴	9.7	14.2	0.1	7.18							
30	曇	10.5	13.9	0.2	7.21							
平均		15.0	15.5	0.3	7.07	36.2	46.3	53.0	6.5	<0.03	<0.02	
最高		20.0	17.1	0.7	7.21	37.1	47.0	62.0	7.0	<0.03	<0.02	
最低		9.7	13.9	0.0	6.66	35.3	45.6	44.0	6.0	<0.03	<0.02	