

令和 2年 12月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原水水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	10.8	9.7	4.7	7.68							
2	曇	12.0	10.2	4.8	7.69							
3	晴	13.5	9.7	5.2	7.72							
4	晴	11.0	9.5	6.8	7.70							
5	曇	12.0	10.3	5.7	7.51							
6	晴	8.5	9.3	5.8	7.73							
7	晴	12.3	10.1	6.7	7.69	40.8	48.7	68.0	5.2	0.05	<0.02	
8	晴	13.1	9.1	5.1	7.91							
9	曇	9.5	10.0	4.6	7.81							
10	晴	9.7	9.7	5.4	7.70							
11	晴	10.6	9.7	7.2	7.66							
12	雨	10.0	8.4	5.9	7.73							
13	晴	10.6	9.5	7.3	7.64							
14	曇	10.5	11.8	6.3	7.80							
15	晴	5.0	11.2	4.8	7.40							
16	晴	3.2	10.2	3.9	7.75							
17	晴	3.0	10.3	5.4	7.81							
18	晴	5.3	10.4	7.6	7.79							
19	晴	6.0	10.8	7.2	7.74							
20	晴	2.8	9.8	3.9	7.48							
21	晴	4.7	10.0	5.0	7.74	41.0	49.3	126.0	5.3	<0.03	<0.02	
22	晴	6.2	9.7	2.7	7.74							
23	晴	8.1	9.9	3.1	7.80							
24	晴	8.3	9.5	3.4	7.73							
25	晴	9.2	9.7	6.5	7.90							
26	晴	5.5	9.1	5.2	7.74							
27	晴	7.0	9.0	4.2	7.66							
28	雨	6.8	9.1	3.7	7.74							
29	晴	6.6	8.9	3.9	7.68							
30	雨	10.9	9.0	3.4	7.56							
31	晴	1.4	8.6	4.3	7.65							
平均		8.2	9.7	5.2	7.71	40.9	49.0	97.0	5.2	0.02	<0.02	
最高		13.5	11.8	7.6	7.91	41.0	49.3	126.0	5.3	0.05	<0.02	
最低		1.4	8.4	2.7	7.40	40.8	48.7	68.0	5.2	<0.03	<0.02	

令和 2年 12月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考	
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L		
1	晴	10.8	13.5	0.2	7.24								
2	曇	12.0	13.5	0.2	7.27								
3	晴	13.5	13.6	0.4	7.28								
4	晴	11.0	13.4	0.3	7.25								
5	曇	12.0	13.5	0.3	7.12								
6	晴	8.5	13.4	0.1	7.22								
7	晴	12.3	13.1	0.3	7.25	38.3	47.6	76.0	7.4	<0.03	<0.02		
8	晴	13.1	13.1	0.3	7.22								
9	曇	9.5	12.9	0.5	7.25								
10	晴	9.7	12.6	0.5	7.31								
11	晴	10.6	12.5	0.3	7.32								
12	雨	10.0	12.4	0.2	7.22								
13	晴	10.6	12.1	0.2	7.34								
14	曇	10.5	12.2	0.3	7.31								
15	晴	5.0	11.8	0.2	7.50								
16	晴	3.2	11.4	0.3	7.39								
17	晴	3.0	10.9	0.5	7.27								
18	晴	5.3	10.7	0.4	7.28								
19	晴	6.0	10.6	0.5	7.31								
20	晴	2.8	10.4	0.5	7.31								
21	晴	4.7	10.1	0.3	7.33	38.4	49.2	132.0	7.2	<0.03	<0.02		
22	晴	6.2	10.0	0.2	7.40								
23	晴	8.1	10.0	0.3	7.70								
24	晴	8.3	10.0	0.4	7.24								
25	晴	9.2	10.1	0.5	7.18								
26	晴	5.5	9.9	0.5	7.09								
27	晴	7.0	9.7	0.5	7.07								
28	雨	6.8	9.7	0.3	7.25								
29	晴	6.6	9.8	0.3	7.12								
30	雨	10.9	9.8	0.4	7.37								
31	晴	1.4	9.5	0.1	7.12								
平均		8.2	11.5	0.3	7.28	38.4	48.4	104.0	7.3	<0.03	<0.02		
最高		13.5	13.6	0.5	7.70	38.4	49.2	132.0	7.4	<0.03	<0.02		
最低		1.4	9.5	0.1	7.07	38.3	47.6	76.0	7.2	<0.03	<0.02		