

令和 3年 4月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	18.2	11.5	28.4	7.60							
2	晴	18.4	11.9	37.9	7.66							
3	晴	17.7	12.1	23.3	7.47							
4	曇	17.3	12.2	18.6	7.61							
5	晴	17.6	12.2	20.1	7.68							
6	晴	17.5	12.4	26.0	7.63							
7	晴	14.9	12.6	15.5	7.62	31.5	37.7	84	4.0	0.09	<0.02	
8	晴	15.2	12.8	13.0	7.61							
9	晴	14.8	12.6	14.1	7.64							
10	晴	12.4	12.5	10.3	7.68							
11	晴	12.9	12.6	9.7	7.63							
12	晴	16.4	12.6	9.0	7.75							
13	雨	14.5	13.1	7.4	7.70							
14	曇	18.4	13.3	13.2	7.76							
15	曇	12.0	13.1	8.0	7.74							
16	曇	15.3	12.9	8.8	7.77							
17	雨	13.5	13.0	7.4	7.67							
18	晴	13.1	12.9	8.3	7.69							
19	晴	14.0	12.7	9.3	7.68							
20	晴	17.3	12.9	6.4	7.74	33.8	39.7	80	3.9	0.05	<0.02	
21	晴	19.6	13.4	5.9	7.79							
22	晴	19.7	13.5	6.3	7.75							
23	晴	16.4	13.7	5.3	7.76							
24	晴	16.4	14.4	5.4	7.74							
25	晴	16.7	14.6	6.9	7.71							
26	晴	14.6	14.0	6.5	7.81							
27	晴	17.0	13.5	7.2	7.73							
28	曇	17.3	13.7	5.3	7.78							
29	雨	16.2	13.7	5.4	7.61							
30	晴	19.5	13.5	11.0	7.59							
平均		16.2	13.0	12.0	7.69	32.6	38.7	82	4.0	0.07	<0.02	
最高		19.7	14.6	37.9	7.81	33.8	39.7	84	4.0	0.09	<0.02	
最低		12.0	11.5	5.3	7.47	31.5	37.7	80	3.9	0.05	<0.02	

令和 3年 4月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）								備考	
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L		マン ガン mg/L
1	晴	18.2	13.8	0.8	6.94							
2	晴	18.4	13.9	0.9	6.96							
3	晴	17.7	14.3	0.8	6.94							
4	曇	17.3	14.7	0.5	7.02							
5	晴	17.6	14.8	0.3	7.09							
6	晴	17.5	14.6	0.7	7.07							
7	晴	14.9	14.8	0.7	7.16	28.2	38.2	68	7.1	<0.03	<0.02	
8	晴	15.2	14.8	0.6	7.07							
9	晴	14.8	15.0	0.6	7.17							
10	晴	12.4	14.6	0.4	7.13							
11	晴	12.9	15.0	0.2	7.14							
12	晴	16.4	15.0	0.3	7.13							
13	雨	14.5	15.1	0.4	7.30							
14	曇	18.4	15.1	0.4	7.19							
15	曇	12.0	15.4	0.4	7.26							
16	曇	15.3	14.9	0.5	7.18							
17	雨	13.5	14.8	0.3	7.23							
18	晴	13.1	14.8	0.3	7.21							
19	晴	14.0	14.7	0.5	7.34							
20	晴	17.3	14.6	0.5	7.19	28.6	38.4	69	6.3	0.04	<0.02	
21	晴	19.6	15.2	0.3	7.21							
22	晴	19.7	15.5	0.4	7.37							
23	晴	16.4	15.7	0.3	7.23							
24	晴	16.4	15.2	0.4	7.32							
25	晴	16.7	15.7	0.3	7.34							
26	晴	14.6	16.1	0.2	7.32							
27	晴	17.0	16.0	0.4	7.30							
28	曇	17.3	15.9	0.5	7.37							
29	雨	16.2	15.9	0.4	7.08							
30	晴	19.5	15.7	0.3	7.20							
平均		16.2	15.1	0.5	7.18	28.4	38.3	68	6.7	<0.03	<0.02	
最高		19.7	16.1	0.9	7.37	28.6	38.4	69	7.1	0.04	<0.02	
最低		12.0	13.8	0.2	6.94	28.2	38.2	68	6.3	<0.03	<0.02	