

令和 3年 5月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	19.4	15.0	8.4	7.49							
2	晴	15.9	13.9	5.8	7.55							
3	晴	14.6	13.6	6.4	7.57							
4	晴	19.0	14.0	5.1	7.55							
5	曇	18.8	13.9	5.4	7.61							
6	晴	18.5	14.1	5.4	7.68	34.4	40.1	67	3.8	0.08	<0.02	
7	曇	18.0	14.4	6.1	7.62							
8	晴	19.6	14.2	8.0	7.64							
9	晴	21.4	14.4	9.1	7.58							
10	晴	20.4	14.5	10.0	7.70							
11	曇	20.8	14.3	7.3	7.62							
12	曇	19.8	14.5	6.9	7.73							
13	雨	18.2	14.2	6.6	7.67							
14	晴	22.7	14.7	7.9	7.68							
15	晴	22.2	15.2	6.3	7.62							
16	曇	20.3	15.4	6.1	7.46							
17	雨	21.5	15.4	8.8	7.72							
18	晴	23.9	15.2	9.2	7.68							
19	雨	20.9	15.4	10.2	7.72							
20	曇	20.9	15.6	9.2	7.70	34.0	39.5	92	3.2	0.09	<0.02	
21	雨	21.9	16.0	9.1	7.74							
22	曇	18.7	16.5	56.5	7.72							
23	晴	21.6	17.1	417.9	7.55							
24	曇	22.6	16.4	528.0	7.68							
25	晴	22.2	16.0	751.0	7.70							
26	曇	19.9	16.0	407.7	7.65							
27	雨	14.1	15.7	314.4	7.60							
28	晴	21.1	15.7	219.8	7.67							
29	曇	22.9	16.0	159.1	7.74							
30	晴	22.2	16.2	129.1	7.77							
31	晴	23.1	16.0	135.2	7.75							
平均		20.2	15.1	105.7	7.65	34.2	39.8	80	3.5	0.08	<0.02	
最高		23.9	17.1	751.0	7.77	34.4	40.1	92	3.8	0.09	<0.02	
最低		14.1	13.6	5.1	7.46	34.0	39.5	67	3.2	0.08	<0.02	

令和 3年 5月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	19.4	15.8	0.9	7.20							
2	晴	15.9	16.0	0.3	7.14							
3	晴	14.6	15.7	0.2	7.20							
4	晴	19.0	15.8	0.2	7.23							
5	曇	18.8	16.2	0.2	7.28							
6	晴	18.5	16.4	0.2	7.28	30.9	39.6	54	6.3	<0.03	<0.02	
7	曇	18.0	16.8	0.2	7.27							
8	晴	19.6	16.7	0.3	7.22							
9	晴	21.4	16.7	0.3	7.16							
10	晴	20.4	17.2	0.5	7.39							
11	曇	20.8	17.0	0.3	7.25							
12	曇	19.8	17.2	0.6	7.40							
13	雨	18.2	16.8	0.4	7.28							
14	晴	22.7	17.0	0.4	7.23							
15	晴	22.2	17.4	0.3	7.18							
16	曇	20.3	18.1	0.2	7.13							
17	雨	21.5	17.8	0.2	7.32							
18	晴	23.9	17.6	0.3	7.20							
19	雨	20.9	17.7	0.4	7.22							
20	曇	20.9	17.8	0.5	7.22	30.2	38.5	87	5.5	<0.03	<0.02	
21	雨	21.9	18.1	0.5	7.22							
22	曇	18.7	18.3	0.7	7.15							
23	晴	21.6	18.1	1.2	6.99							
24	曇	22.6	18.8	1.0	7.03							
25	晴	22.2	18.5	2.1	6.58							
26	曇	19.9	18.7	1.4	6.78							
27	雨	14.1	18.4	1.2	6.62							
28	晴	21.1	17.8	1.4	6.66							
29	曇	22.9	18.2	1.2	6.86							
30	晴	22.2	18.4	0.9	6.90							
31	晴	23.1	18.9	1.0	6.93							
平均		20.2	17.4	0.6	7.11	30.6	39.0	70	5.9	<0.03	<0.02	
最高		23.9	18.9	2.1	7.40	30.9	39.6	87	6.3	<0.03	<0.02	
最低		14.1	15.7	0.2	6.58	30.2	38.5	54	5.5	<0.03	<0.02	