

令和 3年 10月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	22.8	20.3	10.4	7.92							
2	晴	23.5	20.0	9.4	7.91							
3	晴	23.1	20.3	8.9	7.92							
4	晴	25.2	20.5	7.6	7.93							
5	晴	24.4	20.4	7.3	7.95							
6	晴	26.0	20.5	8.1	7.94							
7	晴	24.5	20.5	6.3	7.95	38.7	42.7	92	3.2	0.06	<0.02	
8	晴	24.8	20.5	6.4	7.95							
9	晴	25.1	20.5	5.6	7.94							
10	曇	22.2	20.4	4.5	7.80							
11	曇	23.5	20.4	4.4	7.96							
12	晴	25.7	20.5	2.3	7.97							
13	雨	20.7	20.6	2.7	7.90							
14	晴	21.4	20.3	2.5	7.80							
15	晴	23.2	20.1	5.2	7.76							
16	曇	21.4	20.3	4.3	7.64							
17	曇	19.3	20.3	4.8	7.86							
18	曇	15.5	19.7	5.4	7.96							
19	曇	14.8	19.2	7.3	7.90							
20	晴	16.6	19.1	7.4	7.87							
21	晴	13.6	18.6	8.2	7.94	39.5	43.5	98	4.0	0.06	<0.02	
22	曇	14.3	18.3	14.5	7.88							
23	晴	15.1	17.7	14.2	7.77							
24	晴	16.3	17.6	10.8	7.72							
25	雨	15.4	17.4	7.4	7.89							
26	晴	16.8	16.8	6.4	7.99							
27	晴	19.3	16.9	10.0	7.93							
28	晴	17.5	16.6	9.8	7.91							
29	晴	13.7	16.2	12.1	7.97							
30	晴	15.7	15.9	10.2	7.77							
31	雨	15.4	16.0	7.3	7.84							
平均		19.9	19.1	7.5	7.89	39.1	43.1	95	3.6	0.06	<0.02	
最高		26.0	20.6	14.5	7.99	39.5	43.5	98	4.0	0.06	<0.02	
最低		13.6	15.9	2.3	7.64	38.7	42.7	92	3.2	0.06	<0.02	

令和 3年 10月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	22.8	22.2	0.6	7.38							
2	晴	23.5	22.0	0.6	7.35							
3	晴	23.1	22.1	0.4	7.42							
4	晴	25.2	22.1	0.4	7.50							
5	晴	24.4	22.1	0.5	7.45							
6	晴	26.0	22.1	0.6	7.42							
7	晴	24.5	22.2	0.4	7.56	35.6	41.6	86	5.2	<0.03	<0.02	
8	晴	24.8	22.2	0.6	7.43							
9	晴	25.1	22.2	0.6	7.42							
10	曇	22.2	22.2	0.2	7.37							
11	曇	23.5	22.4	0.3	7.53							
12	晴	25.7	22.2	0.2	7.61							
13	雨	20.7	22.4	0.3	7.55							
14	晴	21.4	22.1	0.2	7.50							
15	晴	23.2	22.0	0.2	7.39							
16	曇	21.4	22.1	0.2	7.25							
17	曇	19.3	22.0	0.2	7.39							
18	曇	15.5	21.7	0.1	7.43							
19	曇	14.8	21.0	0.5	7.45							
20	晴	16.6	20.7	0.5	7.38							
21	晴	13.6	20.0	0.5	7.48	36.0	43.1	111	6.1	<0.03	<0.02	
22	曇	14.3	19.9	0.7	7.42							
23	晴	15.1	19.5	0.7	7.27							
24	晴	16.3	19.2	0.4	7.15							
25	雨	15.4	18.9	0.3	7.56							
26	晴	16.8	18.6	0.8	7.53							
27	晴	19.3	18.4	0.8	7.50							
28	晴	17.5	18.5	0.9	7.45							
29	晴	13.7	18.2	1.0	7.47							
30	晴	15.7	17.9	0.8	7.45							
31	雨	15.4	17.8	0.7	7.47							
平均		19.9	20.9	0.5	7.44	35.8	42.4	98	5.6	<0.03	<0.02	
最高		26.0	22.4	1.0	7.61	36.0	43.1	111	6.1	<0.03	<0.02	
最低		13.6	17.8	0.1	7.15	35.6	41.6	86	5.2	<0.03	<0.02	