

令和 3年 12月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	14.8	11.6	13.1	7.98							
2	晴	7.9	10.7	12.2	7.88	40.6	47.4	102	5.0	0.13	<0.02	
3	晴	9.0	10.5	16.3	7.88							
4	晴	10.0	10.1	17.0	7.82							
5	曇	7.4	10.0	16.5	7.64							
6	雨	13.0	10.0	15.8	7.52							
7	雨	11.5	10.1	14.3	7.83							
8	曇	12.1	9.9	17.2	7.80							
9	晴	11.6	9.8	17.2	7.85							
10	曇	9.6	9.7	13.0	7.78							
11	晴	11.6	9.5	11.9	7.65							
12	晴	12.9	9.6	10.8	7.40							
13	晴	10.6	9.5	12.1	7.82							
14	曇	7.7	9.3	9.6	7.83							
15	晴	9.3	9.1	11.7	7.87							
16	晴	10.3	9.3	8.0	7.86	39.2	46.1	83	4.8	0.11	<0.02	
17	晴	12.5	9.3	16.6	7.89							
18	晴	3.1	8.9	10.7	7.50							
19	晴	4.1	8.6	10.4	7.64							
20	晴	6.7	8.5	10.7	7.90							
21	晴	9.1	8.4	9.2	7.85							
22	晴	11.2	8.5	11.4	7.87							
23	晴	7.4	8.2	10.7	7.85							
24	晴	9.7	7.7	11.3	7.89							
25	晴	11.2	7.9	10.2	7.70							
26	晴	2.8	7.7	8.2	7.64							
27	晴	1.2	7.3	8.0	7.81							
28	晴	4.4	7.2	7.8	7.83							
29	晴	5.0	6.9	7.5	7.81							
30	晴	8.1	7.2	6.8	7.78							
31	晴	3.2	6.8	6.3	7.70							
平均		8.7	9.0	11.7	7.78	39.9	46.8	92	4.9	0.12	<0.02	
最高		14.8	11.6	17.2	7.98	40.6	47.4	102	5.0	0.13	<0.02	
最低		1.2	6.8	6.3	7.40	39.2	46.1	83	4.8	0.11	<0.02	

令和 3年 12月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	14.8	12.9	0.8	7.48							
2	晴	7.9	12.7	0.8	7.39	38.4	48.0	89	7.3	0.04	<0.02	
3	晴	9.0	12.3	0.8	7.42							
4	晴	10.0	12.0	0.8	7.30							
5	曇	7.4	11.5	0.5	7.21							
6	雨	13.0	11.7	0.6	7.25							
7	雨	11.5	11.8	0.9	7.42							
8	曇	12.1	11.8	1.0	7.38							
9	晴	11.6	11.8	0.9	7.49							
10	曇	9.6	11.6	1.0	7.38							
11	晴	11.6	11.4	0.8	7.48							
12	晴	12.9	11.3	0.5	7.16							
13	晴	10.6	11.4	0.6	7.40							
14	曇	7.7	11.0	0.6	7.45							
15	晴	9.3	10.9	0.9	7.46							
16	晴	10.3	10.9	0.6	7.58	37.0	46.6	76	7.1	0.06	<0.02	
17	晴	12.5	10.8	0.8	7.52							
18	晴	3.1	10.8	0.6	7.14							
19	晴	4.1	10.2	0.5	7.58							
20	晴	6.7	9.9	0.5	7.61							
21	晴	9.1	9.8	0.6	7.53							
22	晴	11.2	9.7	0.8	7.50							
23	晴	7.4	9.8	0.7	7.58							
24	晴	9.7	9.5	0.8	7.56							
25	晴	11.2	9.5	0.8	7.32							
26	晴	2.8	9.5	0.8	7.54							
27	晴	1.2	9.0	0.5	7.51							
28	晴	4.4	8.8	0.7	7.50							
29	晴	5.0	8.4	0.5	7.29							
30	晴	8.1	8.4	0.3	7.40							
31	晴	3.2	8.4	0.5	7.30							
平均		8.7	10.6	0.7	7.42	37.7	47.3	82	7.2	0.05	<0.02	
最高		14.8	12.9	1.0	7.61	38.4	48.0	89	7.3	0.06	<0.02	
最低		1.2	8.4	0.3	7.14	37.0	46.6	76	7.1	0.04	<0.02	