

令和 4年 3月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	11.0	6.2	4.1	7.75	43.1	54.2	72.0	8.6	0.07	<0.02	
2	晴	9.9	5.5	4.7	7.73							
3	晴	9.7	5.7	4.3	7.72							
4	晴	8.0	5.5	4.4	7.70							
5	晴	9.9	5.8	4.9	7.60							
6	晴	7.0	5.9	4.2	7.55							
7	晴	5.9	5.6	5.2	7.76							
8	晴	9.5	5.8	4.0	7.74							
9	晴	9.6	5.9	5.0	7.76							
10	晴	11.2	6.0	4.5	7.77							
11	晴	11.9	6.3	5.5	7.81							
12	晴	14.8	6.5	5.8	7.58							
13	晴	15.9	7.0	6.3	7.58							
14	晴	16.7	7.4	7.4	7.74							
15	晴	18.8	7.8	6.5	7.78	42.9	52.9	100.0	9.1	<0.03	<0.02	
16	晴	15.6	7.9	5.2	7.78							
17	晴	15.0	7.8	4.3	7.76							
18	曇	13.5	8.2	6.1	7.78							
19	晴	12.5	8.2	6.5	7.68							
20	晴	9.2	8.5	5.9	7.72							
21	晴	9.7	8.2	6.1	7.71							
22	雨	6.9	8.5	6.0	7.80							
23	晴	7.1	8.1	5.6	7.79							
24	晴	10.5	8.2	5.7	7.77							
25	晴	7.9	8.2	6.0	7.76							
26	曇	14.4	9.2	6.8	7.67							
27	晴	16.1	9.7	7.6	7.68							
28	晴	15.4	9.6	6.9	7.78							
29	曇	13.7	9.5	6.0	7.71							
30	晴	15.7	9.3	7.2	7.71							
31	晴	17.7	9.6	8.5	7.71							
平均		12.0	7.5	5.7	7.72	43.0	53.6	86	8.9	0.04	<0.02	
最高		18.8	9.7	8.5	7.81	43.1	54.2	100	9.1	0.07	<0.02	
最低		5.9	5.5	4.0	7.55	42.9	52.9	72	8.6	<0.03	<0.02	

令和 4年 3月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	11.0	7.2	0.5	7.40	41.2	54.6	65.0	10.0	<0.03	<0.02	
2	晴	9.9	7.3	0.8	7.39							
3	晴	9.7	7.7	0.6	7.40							
4	晴	8.0	7.7	0.6	7.39							
5	晴	9.9	7.7	0.8	7.25							
6	晴	7.0	8.0	0.5	7.47							
7	晴	5.9	7.9	0.5	7.48							
8	晴	9.5	7.7	0.6	7.42							
9	晴	9.6	8.0	0.7	7.41							
10	晴	11.2	8.0	0.7	7.41							
11	晴	11.9	8.3	0.9	7.41							
12	晴	14.8	8.7	0.7	7.41							
13	晴	15.9	9.1	0.7	7.39							
14	晴	16.7	9.7	0.6	7.45							
15	晴	18.8	10.4	0.7	7.43	40.9	52.9	106.0	11.0	<0.03	<0.02	
16	晴	15.6	10.5	0.8	7.45							
17	晴	15.0	10.6	0.6	7.43							
18	曇	13.5	10.8	0.8	7.43							
19	晴	12.5	10.8	0.8	7.29							
20	晴	9.2	10.7	0.7	7.40							
21	晴	9.7	10.8	0.6	7.36							
22	雨	6.9	10.7	0.6	7.48							
23	晴	7.1	10.6	0.7	7.47							
24	晴	10.5	10.5	0.6	7.47							
25	晴	7.9	10.6	0.3	7.46							
26	曇	14.4	10.7	0.8	7.33							
27	晴	16.1	11.6	0.6	7.43							
28	晴	15.4	11.9	0.5	7.44							
29	曇	13.7	12.0	0.6	7.41							
30	晴	15.7	12.0	0.8	7.37							
31	晴	17.7	12.3	0.8	7.36							
平均		12.0	9.7	0.7	7.41	41.1	53.8	86	10.5	<0.03	<0.02	
最高		18.8	12.3	0.9	7.48	41.2	54.6	106	11.0	<0.03	<0.02	
最低		5.9	7.2	0.3	7.25	40.9	52.9	65	10.0	<0.03	<0.02	