

令和 4年 5月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	16.0	14.4	17.4	7.67							
2	晴	16.7	14.2	19.9	7.83							
3	晴	14.6	14.4	28.3	7.62							
4	晴	19.1	14.5	33.6	7.71							
5	晴	18.9	14.6	29.6	7.71							
6	晴	19.5	14.8	26.1	7.72							
7	晴	22.5	14.9	25.7	7.65							
8	晴	20.0	14.9	28.2	7.73							
9	曇	20.2	14.8	26.7	7.75							
10	曇	15.9	14.5	22.5	7.74							
11	晴	20.9	15.0	19.9	7.70							
12	曇	19.8	15.2	18.2	7.76	32.0	37.2	103	3.5	0.14	<0.02	
13	雨	19.0	14.9	20.1	7.85							
14	曇	21.0	15.2	18.5	7.71							
15	晴	20.3	15.2	21.3	7.71							
16	曇	16.3	15.1	14.9	7.85							
17	曇	17.0	14.9	12.2	7.81							
18	晴	19.5	15.0	12.7	7.80							
19	晴	20.5	15.2	10.8	7.87							
20	曇	19.8	15.5	12.4	7.95							
21	曇	19.1	15.7	13.0	7.79							
22	晴	20.2	15.7	12.0	7.79							
23	晴	22.5	15.6	12.7	7.86							
24	曇	22.0	15.9	15.0	7.79							
25	晴	22.5	16.1	16.5	7.87							
26	曇	18.1	16.1	14.8	8.03	34.8	40.5	69	3.4	0.15	<0.02	
27	曇	22.4	16.6	15.6	7.77							
28	晴	23.2	16.4	15.6	7.81							
29	晴	25.6	16.6		7.78							
30	晴	24.7	16.8	9.5	7.89							
31	曇	18.9	17.3	8.9	7.99							
平均		19.9	15.4	18.4	7.79	33.4	38.9	86	3.5	0.15	<0.02	
最高		25.6	17.3	33.6	8.03	34.8	40.5	103	3.5	0.15	<0.02	
最低		14.6	14.2	8.9	7.62	32.0	37.2	69	3.4	0.14	<0.02	

令和 4年 5月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	16.0	16.6	0.9	7.32							
2	晴	16.7	16.4	0.9	7.40							
3	晴	14.6	16.6	0.7	7.25							
4	晴	19.1	16.8	1.1	7.32							
5	晴	18.9	17.1	0.7	7.39							
6	晴	19.5	17.3	0.6	7.30							
7	晴	22.5	17.6	0.8	7.25							
8	晴	20.0	17.7	0.9	7.22							
9	曇	20.2	17.9	0.7	7.25							
10	曇	15.9	17.4	0.6	7.22							
11	晴	20.9	17.5	1.0	7.17							
12	曇	19.8	17.8	1.0	7.27	28.6	37.4	87	6.3	0.04	<0.02	
13	雨	19.0	17.7	1.1	7.25							
14	曇	21.0	17.9	0.8	7.22							
15	晴	20.3	17.9	0.8	7.15							
16	曇	16.3	17.8	0.6	7.29							
17	曇	17.0	17.5	0.6	7.22							
18	晴	19.5	17.4	0.7	7.29							
19	晴	20.5	17.6	0.7	7.36							
20	曇	19.8	18.1	0.7	7.35							
21	曇	19.1	18.3	0.8	7.24							
22	晴	20.2	18.3	0.5	7.28							
23	晴	22.5	18.5	0.5	7.35							
24	曇	22.0	18.9	0.8	7.29							
25	晴	22.5	19.0	0.8	7.31							
26	曇	18.1	19.2	0.6	7.32	31.7	41.3	60	5.8	0.05	<0.02	
27	曇	22.4	19.2	0.8	7.24							
28	晴	23.2	19.4		7.21							
29	晴	25.6	19.6		7.43							
30	晴	24.7	19.9	0.8	7.39							
31	曇	18.9	20.1	0.9	7.31							
平均		19.9	18.0	0.8	7.29	30.2	39.4	74	6.1	0.04	<0.02	
最高		25.6	20.1	1.1	7.43	31.7	41.3	87	6.3	0.05	<0.02	
最低		14.6	16.4	0.5	7.15	28.6	37.4	60	5.8	0.04	<0.02	