

令和 4年 6月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	25.0	17.1	12.8	7.84							
2	晴	24.4	17.1	8.5	7.86	37.0	43.4	111	4.0	0.05	<0.02	
3	晴	24.6	17.7	7.4	7.88							
4	晴	22.4	17.7	11.1	7.82							
5	晴	23.9	18.1	10.5	7.94							
6	雨	17.5	18.2	9.2	7.92							
7	晴	21.7	18.1	8.1	8.20							
8	晴	21.0	18.3	8.1	7.93							
9	晴	22.0	18.2	9.7	8.04							
10	曇	22.5	18.5	7.3	7.94							
11	曇	22.7	18.6	7.4	7.90							
12	晴	23.0	18.5	7.8	7.88							
13	曇	22.5	18.5	6.0	7.96							
14	雨	17.1	18.5	6.4	7.92							
15	雨	17.9	18.5	7.1	7.96							
16	曇	21.3	18.5	6.3	7.93	40.0	46.3	111	4.4	0.14	<0.02	
17	曇	23.2	18.7	5.9	8.01							
18	曇	22.6	19.0	4.7	7.75							
19	晴	23.5	19.0	4.8	8.11							
20	曇	24.3	19.1	7.1	8.13							
21	曇	24.8	19.2	7.4	8.11							
22	曇	23.7	19.5	6.8	7.91							
23	晴	23.8	19.6	8.4	7.94							
24	曇	25.3	19.5	8.2	8.10							
25	晴	26.6	21.6	6.3	7.80							
26	晴	27.9	21.6	5.6	7.90							
27	晴	30.9	20.4	5.9	7.77							
28	晴	30.0	20.7	3.9	7.81							
29	晴	29.1	21.0	5.0	7.77							
30	晴	31.3	21.0	5.4	7.77							
平均		23.9	19.0	7.3	7.93	38.5	44.9	111	4.2	0.09	<0.02	
最高		31.3	21.6	12.8	8.20	40.0	46.3	111	4.4	0.14	<0.02	
最低		17.1	17.1	3.9	7.75	37.0	43.4	111	4.0	0.05	<0.02	

令和 4年 6月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	25.0	20.1	0.8	7.28							
2	晴	24.4	20.1	0.8	7.44	33.9	43.2	94	6.2	0.04	<0.02	
3	晴	24.6	20.5	0.8	7.31							
4	晴	22.4	21.0	0.7	7.23							
5	晴	23.9	21.2	0.7	7.40							
6	雨	17.5	21.0	0.6	7.53							
7	晴	21.7	20.6	0.6	7.44							
8	晴	21.0	20.9	0.6	7.40							
9	晴	22.0	21.1	0.7	7.57							
10	曇	22.5	21.1	0.6	7.58							
11	曇	22.7	21.5	0.7	7.33							
12	晴	23.0	21.5	0.8	7.37							
13	曇	22.5	21.7	0.6	7.53							
14	雨	17.1	21.5	0.7	7.44							
15	雨	17.9	20.9	0.6	7.49							
16	曇	21.3	20.9	0.6	7.51	37.8	46.1	119	6.0	0.05	<0.02	
17	曇	23.2	21.1	0.6	7.56							
18	曇	22.6	21.5	0.2	7.44							
19	晴	23.5	21.6	0.0	7.61							
20	曇	24.3	21.7	0.5	7.65							
21	曇	24.8	22.0	0.5	7.62							
22	曇	23.7	22.0	0.6	7.42							
23	晴	23.8	22.0	0.6	7.43							
24	曇	25.3	22.2	1.1	7.44							
25	晴	26.6	22.4	0.8	7.45							
26	晴	27.9	22.9	0.5	7.39							
27	晴	30.9	23.2	0.5	7.36							
28	晴	30.0	23.3	0.5	7.39							
29	晴	29.1	23.8	0.5	7.37							
30	晴	31.3	24.3	0.5	7.32							
平均		23.9	21.7	0.6	7.44	35.9	44.7	107	6.1	0.05	<0.02	
最高		31.3	24.3	1.1	7.65	37.8	46.1	119	6.2	0.05	<0.02	
最低		17.1	20.1	0.0	7.23	33.9	43.2	94	6.0	0.04	<0.02	