

令和 4年 8月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原水水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	30.6	23.1	5.0	7.70							
2	晴	30.2	23.5	4.7	7.90							
3	晴	32.7	23.8	5.6	7.84							
4	晴	30.6	23.7	5.4	7.91	35.6	40.7	97	3.4	0.08	<0.02	
5	晴	28.4	23.3	5.9	7.83							
6	曇	26.3	23.3	5.0	7.88							
7	曇	26.5	23.4	4.2	7.88							
8	晴	29.8	23.5	4.1	7.89							
9	曇	29.4	24.1	3.6	7.88							
10	晴	31.1	24.1	4.5	7.83							
11	晴	31.6	24.4	5.6	7.87							
12	曇	28.1	24.1	5.5	7.86							
13	雨	24.8	24.0	5.2	7.84							
14	曇	27.1	22.5	10.2	7.81							
15	晴	31.0	23.0	10.8	7.83							
16	曇	29.4	23.3	5.8	7.85							
17	曇	27.0	23.5	7.3	7.79							
18	曇	27.2	23.4	5.5	7.86	35.5	40.3	73	3.7	0.06	<0.02	
19	晴	28.1	22.0	49.5	7.77							
20	晴	28.4	22.5	7.2	7.90							
21	曇	26.1	22.6	8.8	7.84							
22	晴	28.2	22.6	14.1	7.86							
23	曇	29.0	22.5	19.0	7.89							
24	晴	30.5	22.6	17.4	7.79							
25	曇	27.4	22.7	16.0	7.80							
26	晴	28.8	22.7	12.0	7.83							
27	晴	30.2	23.2	8.9	7.85							
28	晴	28.0	23.3	7.1	7.82							
29	晴	26.3	23.0	7.5	7.89							
30	晴	28.6	23.0	5.8	7.93							
31	曇	29.0	23.2	6.6	7.91							
平均		28.7	23.2	9.2	7.85	35.6	40.5	85	3.6	0.07	<0.02	
最高		32.7	24.4	49.5	7.93	35.6	40.7	97	3.7	0.08	<0.02	
最低		24.8	22.0	3.6	7.70	35.5	40.3	73	3.4	0.06	<0.02	

令和 4年 8月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考	
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L		
1	晴	30.6	27.2	0.5	7.65								
2	晴	30.2	27.3	0.5	7.52								
3	晴	32.7	27.3	0.6	7.40								
4	晴	30.6	27.5	0.6	7.44	33.6	41.2	84	4.7	0.04	<0.02		
5	晴	28.4	27.3	0.6	7.45								
6	曇	26.3	27.0	0.6	7.38								
7	曇	26.5	26.8	0.8	7.36								
8	晴	29.8	27.3	0.6	7.53								
9	曇	29.4	27.5	0.4	7.45								
10	晴	31.1	27.7	0.4	7.38								
11	晴	31.6	27.8	0.5	7.35								
12	曇	28.1	27.7	0.6	7.49								
13	雨	24.8	27.7	0.7	7.48								
14	曇	27.1	27.0	0.5	7.52								
15	晴	31.0	27.0	0.6	7.55								
16	曇	29.4	27.0	0.8	7.51								
17	曇	27.0	27.2	0.8	7.49								
18	曇	27.2	27.3	0.9	7.52	34.8	40.7	64	4.9	<0.03	<0.02		
19	晴	28.1	27.0	1.3	7.46								
20	晴	28.4	26.8	5.3	7.54								
21	曇	26.1	26.8	2.1	7.45								
22	晴	28.2	26.6	1.5	7.33								
23	曇	29.0	26.6	1.2	7.38								
24	晴	30.5	26.6	1.3	7.20								
25	曇	27.4	26.6	1.1	7.12								
26	晴	28.8	26.5	1.3	7.16								
27	晴	30.2	26.8	1.4	7.21								
28	晴	28.0	27.2	0.8	7.28								
29	晴	26.3	27.0	0.8	7.48								
30	晴	28.6	26.5	1.1	7.51								
31	曇	29.0	26.3	0.9	7.34								
平均		28.7	27.1	1.0	7.42	34.2	41.0	74	4.8	0.03	<0.02		
最高		32.7	27.8	5.3	7.65	34.8	41.2	84	4.9	0.04	<0.02		
最低		24.8	26.3	0.4	7.12	33.6	40.7	64	4.7	<0.03	<0.02		