

令和 4年 10月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

| 日 | 天候 | 気温 ℃ | 原 水 水質試験結果 (沈砂池) | | | | | | | | | 備考 |
|----|----|---------|------------------|---------|------|-------------------|------------|--------------------|--------------------|-----------|------------------|----|
| | | | 水温 ℃ | 濁度 度 | p H | アルカリ 度 mg/L | 硬度 mg/L | 蒸 発 残留物 mg/L | 塩化物 イオン mg/L | 鉄 mg/L | マン ガン mg/L | |
| 1 | 晴 | 24.5 | 20.1 | 35.2 | 7.48 | | | | | | | |
| 2 | 晴 | 25.3 | 20.2 | 30.4 | 7.56 | | | | | | | |
| 3 | 晴 | 25.2 | 20.2 | 27.4 | 7.67 | | | | | | | |
| 4 | 晴 | 25.3 | 20.2 | 22.9 | 7.78 | | | | | | | |
| 5 | 曇 | 25.0 | 20.1 | 19.1 | 7.75 | | | | | | | |
| 6 | 雨 | 17.2 | 19.8 | 16.5 | 7.83 | 35.9 | 39.5 | 70 | 2.9 | 0.08 | <0.02 | |
| 7 | 曇 | 16.1 | 19.2 | 18.9 | 7.77 | | | | | | | |
| 8 | 曇 | 18.6 | 18.9 | 14.6 | 7.57 | | | | | | | |
| 9 | 曇 | 18.6 | 18.9 | 10.9 | 7.77 | | | | | | | |
| 10 | 曇 | 20.8 | 18.7 | 12.4 | 7.66 | | | | | | | |
| 11 | 晴 | 19.3 | 18.7 | 11.1 | 7.74 | | | | | | | |
| 12 | 曇 | 18.4 | 18.2 | 16.9 | 7.73 | | | | | | | |
| 13 | 雨 | 17.9 | 17.7 | 13.1 | 7.84 | | | | | | | |
| 14 | 晴 | 20.5 | 17.5 | 16.0 | 7.73 | | | | | | | |
| 15 | 晴 | 23.3 | 17.7 | 12.2 | 7.65 | | | | | | | |
| 16 | 晴 | 23.6 | 18.0 | 12.6 | 7.75 | | | | | | | |
| 17 | 雨 | 22.9 | 18.0 | 7.9 | 7.85 | | | | | | | |
| 18 | 曇 | 19.0 | 17.7 | 7.6 | 7.86 | | | | | | | |
| 19 | 晴 | 17.6 | 18.5 | 19.5 | 7.72 | | | | | | | |
| 20 | 晴 | 16.9 | 17.3 | 12.5 | 7.80 | 36.4 | 39.8 | 103 | 3.0 | 0.08 | <0.02 | |
| 21 | 晴 | 17.5 | 17.1 | 10.1 | 7.81 | | | | | | | |
| 22 | 曇 | 18.9 | 17.2 | 7.6 | 7.84 | | | | | | | |
| 23 | 晴 | 19.6 | 17.2 | 7.9 | 7.87 | | | | | | | |
| 24 | 晴 | 18.3 | 17.3 | 8.2 | 7.85 | | | | | | | |
| 25 | 曇 | 13.3 | 17.0 | 6.5 | 7.82 | | | | | | | |
| 26 | 晴 | 14.7 | 16.7 | 14.9 | 7.84 | | | | | | | |
| 27 | 晴 | 13.5 | 16.1 | 9.4 | 7.90 | | | | | | | |
| 28 | 晴 | 16.9 | 16.1 | 9.8 | 7.92 | | | | | | | |
| 29 | 晴 | 16.6 | 16.0 | 8.4 | 7.43 | | | | | | | |
| 30 | 晴 | 15.9 | 16.2 | 7.5 | 7.76 | | | | | | | |
| 31 | 曇 | 15.9 | 15.9 | 7.3 | 7.82 | | | | | | | |
| 平均 | | 19.3 | 18.0 | 14.0 | 7.75 | 36.2 | 39.6 | 86 | 3.0 | 0.08 | <0.02 | |
| 最高 | | 25.3 | 20.2 | 35.2 | 7.92 | 36.4 | 39.8 | 103 | 3.0 | 0.08 | <0.02 | |
| 最低 | | 13.3 | 15.9 | 6.5 | 7.43 | 35.9 | 39.5 | 70 | 2.9 | 0.08 | <0.02 | |

令和 4年 10月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

| 日 | 天候 | 気温 ℃ | 浄水 水質試験結果 (配水池) | | | | | | | | | 備考 |
|----|----|---------|-----------------|---------|------|-------------------|------------|-------------------|--------------------|-----------|------------------|----|
| | | | 水温 ℃ | 濁度 度 | pH | アルカリ 度 mg/L | 硬度 mg/L | 蒸発 残留物 mg/L | 塩化物 イオン mg/L | 鉄 mg/L | マン ガン mg/L | |
| 1 | 晴 | 24.5 | 23.3 | 1.6 | 7.05 | | | | | | | |
| 2 | 晴 | 25.3 | 23.5 | 1.9 | 7.16 | | | | | | | |
| 3 | 晴 | 25.2 | 23.2 | 1.7 | 7.15 | | | | | | | |
| 4 | 晴 | 25.3 | 23.0 | 1.2 | 7.14 | | | | | | | |
| 5 | 曇 | 25.0 | 23.0 | 1.2 | 7.05 | | | | | | | |
| 6 | 雨 | 17.2 | 22.8 | 0.9 | 7.20 | 31.7 | 38.8 | 53 | 5.9 | 0.06 | <0.02 | |
| 7 | 曇 | 16.1 | 22.1 | 1.0 | 7.10 | | | | | | | |
| 8 | 曇 | 18.6 | 21.5 | 0.6 | 7.06 | | | | | | | |
| 9 | 曇 | 18.6 | 21.5 | 0.5 | 7.29 | | | | | | | |
| 10 | 曇 | 20.8 | 21.2 | 0.5 | 7.09 | | | | | | | |
| 11 | 晴 | 19.3 | 21.1 | 0.6 | 7.21 | | | | | | | |
| 12 | 曇 | 18.4 | 21.1 | 0.8 | 7.14 | | | | | | | |
| 13 | 雨 | 17.9 | 20.5 | 0.7 | 7.21 | | | | | | | |
| 14 | 晴 | 20.5 | 20.5 | 0.7 | 7.13 | | | | | | | |
| 15 | 晴 | 23.3 | 20.7 | 1.2 | 7.16 | | | | | | | |
| 16 | 晴 | 23.6 | 20.9 | 0.7 | 7.16 | | | | | | | |
| 17 | 雨 | 22.9 | 21.0 | 0.3 | 7.24 | | | | | | | |
| 18 | 曇 | 19.0 | 20.7 | 0.9 | 7.24 | | | | | | | |
| 19 | 晴 | 17.6 | 20.9 | 0.7 | 7.22 | | | | | | | |
| 20 | 晴 | 16.9 | 20.5 | 0.7 | 7.25 | 33.0 | 39.7 | 77 | 5.8 | <0.03 | <0.02 | |
| 21 | 晴 | 17.5 | 20.0 | 0.5 | 7.32 | | | | | | | |
| 22 | 曇 | 18.9 | 19.8 | 0.5 | 7.15 | | | | | | | |
| 23 | 晴 | 19.6 | 19.8 | 0.8 | 7.21 | | | | | | | |
| 24 | 晴 | 18.3 | 19.7 | 0.9 | 7.31 | | | | | | | |
| 25 | 曇 | 13.3 | 19.6 | 0.5 | 7.30 | | | | | | | |
| 26 | 晴 | 14.7 | 19.0 | 0.8 | 7.35 | | | | | | | |
| 27 | 晴 | 13.5 | 18.5 | 0.8 | 7.35 | | | | | | | |
| 28 | 晴 | 16.9 | 18.3 | 1.0 | 7.36 | | | | | | | |
| 29 | 晴 | 16.6 | 18.5 | 0.4 | 7.35 | | | | | | | |
| 30 | 晴 | 15.9 | 18.2 | 0.5 | 7.31 | | | | | | | |
| 31 | 曇 | 15.9 | 18.2 | 0.4 | 7.40 | | | | | | | |
| 平均 | | 19.3 | 20.7 | 0.8 | 7.21 | 32.4 | 39.2 | 65 | 5.8 | 0.03 | <0.02 | |
| 最高 | | 25.3 | 23.5 | 1.9 | 7.40 | 33.0 | 39.7 | 77 | 5.9 | 0.06 | <0.02 | |
| 最低 | | 13.3 | 18.2 | 0.3 | 7.05 | 31.7 | 38.8 | 53 | 5.8 | <0.03 | <0.02 | |