

令和 4年 11月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	17.2	15.8	5.8	7.82							
2	晴	18.7	15.8	11.0	7.85							
3	晴	17.6	15.8	8.0	7.82							
4	晴	18.8	15.5	8.3	7.85							
5	晴	15.0	15.2	7.0	7.66							
6	晴	15.4	15.1	5.9	7.80							
7	曇	17.2	14.8	6.0	7.78							
8	晴	17.0	14.7	5.1	7.85							
9	晴	13.4	14.7	6.0	7.86							
10	晴	11.5	14.6	5.4	7.84	39.2	44.6	110	4.1	0.04	<0.02	
11	晴	16.6	14.4	8.5	7.85							
12	晴	16.1	15.8	9.4	7.81							
13	晴	18.5	14.6	6.5	7.83							
14	曇	15.7	14.3	7.4	7.84							
15	晴	14.4	14.2	5.2	7.85							
16	晴	13.5	14.1	8.7	7.89							
17	晴	14.6	13.7	5.7	7.86							
18	晴	13.9	13.5	7.9	7.81							
19	晴	12.8	13.4	5.8	7.86							
20	曇	16.2	13.3	4.7	7.86							
21	雨	14.1	13.3	5.1	7.82							
22	晴	14.5	13.3	3.9	7.85							
23	雨	13.8	13.7	7.6	7.84							
24	晴	17.2	13.4	6.3	7.84	41.0	46.3	86	4.6	0.05	<0.02	
25	晴	13.5	13.1	6.8	7.83							
26	雨	14.5	13.1	5.0	7.83							
27	晴	15.4	12.9	6.4	7.81							
28	曇	15.7	12.8	4.2	7.77							
29	曇	20.1	13.0	6.5	7.84							
30	晴	18.9	13.9	9.0	7.80							
平均		15.7	14.2	6.6	7.83	40.1	45.4	98	4.4	0.04	<0.02	
最高		20.1	15.8	11.0	7.89	41.0	46.3	110	4.6	0.05	<0.02	
最低		11.5	12.8	3.9	7.66	39.2	44.6	86	4.1	0.04	<0.02	

令和 4年 11月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	17.2	18.2	0.5	7.32							
2	晴	18.7	18.1	0.4	7.36							
3	晴	17.6	18.1	0.6	7.25							
4	晴	18.8	17.9	0.4	7.32							
5	晴	15.0	17.7	0.5	7.30							
6	晴	15.4	17.5	0.3	7.28							
7	曇	17.2	17.2	0.3	7.34							
8	晴	17.0	17.0	0.3	7.37							
9	晴	13.4	17.1	0.4	7.37							
10	晴	11.5	16.9	0.5	7.33	36.4	44.7	106	6.2	<0.03	<0.02	
11	晴	16.6	16.8	0.6	7.34							
12	晴	16.1	16.6	0.6	7.28							
13	晴	18.5	16.7	0.5	7.33							
14	曇	15.7	16.7	0.4	7.37							
15	晴	14.4	16.6	0.5	7.39							
16	晴	13.5	16.5	0.7	7.42							
17	晴	14.6	16.0	0.5	7.45							
18	晴	13.9	15.8	0.5	7.36							
19	晴	12.8	15.6	0.4	7.36							
20	曇	16.2	15.6	0.5	7.43							
21	雨	14.1	15.4	0.4	7.45							
22	晴	14.5	15.4	0.6	7.46							
23	雨	13.8	15.7	0.5	7.39							
24	晴	17.2	15.6	0.7	7.41	38.5	45.8	79	6.4	<0.03	<0.02	
25	晴	13.5	15.5	0.5	7.43							
26	雨	14.5	15.3	0.3	7.39							
27	晴	15.4	15.3	0.4	7.33							
28	曇	15.7	15.2	0.4	7.44							
29	曇	20.1	15.2	0.4	7.48							
30	晴	18.9	15.7	0.7	7.48							
平均		15.7	16.4	0.5	7.37	37.4	45.2	92	6.3	<0.03	<0.02	
最高		20.1	18.2	0.7	7.48	38.5	45.8	106	6.4	<0.03	<0.02	
最低		11.5	15.2	0.3	7.25	36.4	44.7	79	6.2	<0.03	<0.02	