

令和 5年 1月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	6.2	7.5	4.7	7.80							
2	晴	6.5	7.4	4.6	7.58							
3	晴	4.2	7.1	5.4	7.74							
4	晴	5.5	7.2	4.3	7.75							
5	晴	5.2	6.8	5.2	7.73	38.4	46.1	125	5.9	<0.03	<0.02	
6	晴	4.5	6.6	6.6	7.70							
7	晴	4.8	6.6	4.9	7.72							
8	晴	6.9	6.5	5.7	7.75							
9	晴	7.2	6.5	5.7	7.74							
10	晴	5.6	6.6	4.9	7.78							
11	晴	5.3	6.3	5.7	7.78							
12	晴	8.6	6.1	4.3	7.77							
13	晴	7.4	6.0	5.1	7.75							
14	雨	12.2	6.4	5.3	7.79							
15	晴	11.4	6.6	7.2	7.89							
16	曇	11.7	6.7	4.1	7.88							
17	晴	9.9	6.3	3.8	7.85							
18	曇	9.0	6.7	4.6	7.67							
19	晴	7.1	6.5	4.3	7.86	40.2	49.1	73	5.6	0.03	<0.02	
20	晴	7.2	6.0	5.1	7.87							
21	晴	3.6	6.0	3.3	7.76							
22	晴	5.0	5.8	3.5	7.88							
23	曇	5.9	6.0	4.0	7.74							
24	曇	8.1	6.0	3.8	7.84							
25	晴	-1.9	5.6	4.8	7.76							
26	晴	0.5	5.4	6.1	7.78							
27	晴	3.9	5.4	5.4	7.79							
28	晴	1.2	5.2	5.3	7.85							
29	晴	2.3	5.4	5.3	7.71							
30	晴	3.8	5.4	5.4	7.70							
31	晴	2.6	5.2	5.8	7.72							
平均		5.9	6.3	5.0	7.77	39.3	47.6	99	5.8	<0.03	<0.02	
最高		12.2	7.5	7.2	7.89	40.2	49.1	125	5.9	0.03	<0.02	
最低		-1.9	5.2	3.3	7.58	38.4	46.1	73	5.6	<0.03	<0.02	

令和 5年 1月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	6.2	9.9	0.2	7.35							
2	晴	6.5	9.1	0.2	7.38							
3	晴	4.2	9.0	0.2	7.36							
4	晴	5.5	10.1	0.2	7.45							
5	晴	5.2	8.6	0.3	7.31	35.6	46.5	111	8.1	<0.03	<0.02	
6	晴	4.5	8.3	0.3	7.32							
7	晴	4.8	8.4	0.3	7.30							
8	晴	6.9	8.9	0.2	7.31							
9	晴	7.2	8.4	0.3	7.33							
10	晴	5.6	8.4	0.3	7.33							
11	晴	5.3	8.7	0.4	7.35							
12	晴	8.6	8.1	0.5	7.32							
13	晴	7.4	8.1	0.5	7.30							
14	雨	12.2	8.4	0.5	7.41							
15	晴	11.4	8.8	0.4	7.44							
16	曇	11.7	9.0	0.2	7.29							
17	晴	9.9	8.9	0.4	7.40							
18	曇	9.0	8.8	0.5	7.25							
19	晴	7.1	8.7	0.6	7.45	35.6	48.2	71	7.4	<0.03	<0.02	
20	晴	7.2	8.6	0.6	7.52							
21	晴	3.6	8.4	0.3	7.39							
22	晴	5.0	8.2	0.2	7.44							
23	曇	5.9	8.0	0.4	7.51							
24	曇	8.1	8.1	0.6	7.40							
25	晴	-1.9	7.9	0.5	7.52							
26	晴	0.5	7.2	0.7	7.44							
27	晴	3.9	7.1	0.7	7.45							
28	晴	1.2	6.8	0.6	7.66							
29	晴	2.3	6.9	0.5	7.34							
30	晴	3.8	6.9	0.4	7.49							
31	晴	2.6	6.8	0.8	7.48							
平均		5.9	8.3	0.4	7.40	35.6	47.4	91	7.8	<0.03	<0.02	
最高		12.2	10.1	0.8	7.66	35.6	48.2	111	8.1	<0.03	<0.02	
最低		-1.9	6.8	0.2	7.25	35.6	46.5	71	7.4	<0.03	<0.02	