

令和 5年 3月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	11.2	6.8	8.3	7.74							
2	晴	11.6	7.3	8.7	7.75	39.4	47.1	77.0	7.6	0.04	<0.02	
3	晴	8.6	6.7	12.0	7.69							
4	晴	8.3	7.1	9.4	7.68							
5	雨	8.5	6.6	8.4	7.67							
6	晴	9.4	6.5	8.4	7.69							
7	晴	11.1	6.9	6.8	7.67							
8	晴	12.1	7.7	7.2	7.70							
9	晴	14.1	7.4	6.3	7.68							
10	曇	16.0	7.9	10.5	7.68							
11	晴	14.7	7.4	6.4	7.58							
12	晴	15.6	7.6	6.5	7.67							
13	雨	10.4	7.8	6.8	7.69							
14	晴	10.1	7.7	4.2	7.70							
15	曇	11.1	8.6	5.0	7.75							
16	晴	15.9	8.9	5.5	7.73	37.6	45.4	78.0	6.4	0.05	<0.02	
17	晴	16.7	9.1	4.7	7.74							
18	雨	11.2	8.5	5.3	7.73							
19	曇	9.8	8.3	6.7	7.72							
20	晴	11.9	8.3	6.9	7.75							
21	曇	13.1	8.8	4.8	7.78							
22	晴	18.2	9.2	4.9	7.75							
23	曇	18.5	10.4	5.5	7.79							
24	晴	20.2	10.6	4.7	7.71							
25	雨	14.2	10.0	6.0	7.68							
26	雨	13.3	9.9	5.6	7.68							
27	晴	11.8	9.7	5.4	7.69							
28	晴	12.7	10.2	4.1	7.67							
29	晴	14.9	11.4	5.7	7.74							
30	晴	14.5	11.6	5.3	7.71							
31	曇	14.0	11.6	7.9	7.67							
平均		13.0	8.6	6.6	7.71	38.5	46.2	78	7.0	0.05	<0.02	
最高		20.2	11.6	12.0	7.79	39.4	47.1	78	7.6	0.05	<0.02	
最低		8.3	6.5	4.1	7.58	37.6	45.4	77	6.4	0.04	<0.02	

令和 5年 3月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	11.2	8.4	0.9	7.35							
2	晴	11.6	9.3	0.8	7.36	38.3	48.3	78.0	9.4	<0.03	<0.02	
3	晴	8.6	9.3	0.9	7.30							
4	晴	8.3	9.1	0.9	7.24							
5	雨	8.5	9.3	0.7	7.29							
6	晴	9.4	9.0	0.6	7.28							
7	晴	11.1	9.2	0.8	7.30							
8	晴	12.1	9.3	0.7	7.33							
9	晴	14.1	9.9	0.7	7.32							
10	曇	16.0	9.9	1.5	7.28							
11	晴	14.7	10.5	1.4	7.31							
12	晴	15.6	10.6	0.7	7.28							
13	雨	10.4	10.9	0.6	7.29							
14	晴	10.1	10.5	0.6	7.27							
15	曇	11.1	10.3	0.7	7.32							
16	晴	15.9	10.9	0.8	7.33	34.8	45.7	78.0	8.2	<0.03	<0.02	
17	晴	16.7	11.1	0.8	7.32							
18	雨	11.2	11.4	0.9	7.36							
19	曇	9.8	11.3	0.7	7.36							
20	晴	11.9	11.3	0.6	7.43							
21	曇	13.1	11.4	0.6	7.35							
22	晴	18.2	11.8	0.6	7.35							
23	曇	18.5	12.0	0.7	7.41							
24	晴	20.2	12.6	0.8	7.37							
25	雨	14.2	13.1	0.8	7.32							
26	雨	13.3	13.1	0.6	7.30							
27	晴	11.8	12.7	0.5	7.29							
28	晴	12.7	12.7	0.6	7.33							
29	晴	14.9	12.9	0.6	7.35							
30	晴	14.5	13.3	0.6	7.37							
31	曇	14.0	13.1	0.7	7.35							
平均		13.0	11.0	0.7	7.33	36.6	47.0	78	8.8	<0.03	<0.02	
最高		20.2	13.3	1.5	7.43	38.3	48.3	78	9.4	<0.03	<0.02	
最低		8.3	8.4	0.5	7.24	34.8	45.7	78	8.2	<0.03	<0.02	