

令和 5年 4月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	15.6	10.9	11.1	7.67							
2	晴	17.9	11.3	8.6	7.65							
3	晴	15.6	11.5	6.8	7.70							
4	晴	15.1	11.5	6.2	7.65							
5	曇	17.5	12.2	7.6	7.67							
6	曇	15.5	11.8	6.1	7.68							
7	曇	18.9	12.5	8.1	7.68							
8	晴	14.5	12.2	7.7	7.66							
9	晴	12.2	11.8	16.4	7.65							
10	晴	15.9	11.6	7.1	7.69							
11	晴	17.9	12.1	5.2	7.69							
12	曇	18.8	13.1	4.7	7.75							
13	晴	14.7	13.1	4.5	7.76	35.3	42.4	90	4.3	0.03	<0.02	
14	晴	16.8	12.8	6.7	7.73							
15	雨	12.5	12.5	6.3	7.70							
16	晴	17.7	12.3	6.6	7.70							
17	晴	14.4	12.3	6.0	7.75							
18	晴	16.2	12.6	4.6	7.62							
19	晴	20.9	13.6	6.3	7.66							
20	晴	19.7	13.0	5.5	7.61	31.8	37.1	58	3.8	<0.03	<0.02	
21	晴	20.6	13.2	7.0	7.68							
22	曇	16.2	13.3	5.6	7.61							
23	曇	14.0	13.0	6.1	7.63							
24	曇	15.2	13.2	5.4	7.65							
25	曇	14.0	13.6	4.7	7.66							
26	雨	15.0	13.8	7.7	8.04							
27	晴	16.2	13.4	8.9	7.62							
28	晴	18.5	13.5	7.6	7.64							
29	曇	18.8	13.7	7.2	7.62							
30	雨	19.6	14.0	7.1	7.66							
平均		16.5	12.6	7.0	7.68	33.6	39.8	74	4.0	<0.03	<0.02	
最高		20.9	14.0	16.4	8.04	35.3	42.4	90	4.3	0.03	<0.02	
最低		12.2	10.9	4.5	7.61	31.8	37.1	58	3.8	<0.03	<0.02	

令和 5年 4月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	15.6	13.3	1.1	7.31							
2	晴	17.9	13.9	1.3	7.25							
3	晴	15.6	14.2	0.8	7.28							
4	晴	15.1	14.4	1.0	7.29							
5	曇	17.5	14.3	0.9	7.32							
6	曇	15.5	14.7	0.8	7.30							
7	曇	18.9	14.4	1.0	7.36							
8	晴	14.5	14.7	0.7	7.23							
9	晴	12.2	14.4	0.9	7.26							
10	晴	15.9	14.5	0.8	7.37							
11	晴	17.9	14.6	0.8	7.25							
12	曇	18.8	14.9	0.7	7.37							
13	晴	14.7	15.1	0.9	7.35	33.3	41.9	73	6.2	<0.03	<0.02	
14	晴	16.8	14.7	0.8	7.35							
15	雨	12.5	15.2	0.8	7.30							
16	晴	17.7	15.2	1.0	7.36							
17	晴	14.4	15.4	0.9	7.38							
18	晴	16.2	15.2	0.8	7.26							
19	晴	20.9	15.3	0.6	7.27							
20	晴	19.7	15.7	0.9	7.25	30.2	37.0	72	5.7	<0.03	<0.02	
21	晴	20.6	16.3	0.7	7.26							
22	曇	16.2	16.4	0.5	7.26							
23	曇	14.0	16.3	0.5	7.26							
24	曇	15.2	16.3	0.7	7.29							
25	曇	14.0	15.5	0.5	7.22							
26	雨	15.0	16.0	0.3	7.40							
27	晴	16.2	15.2	0.7	7.12							
28	晴	18.5	15.8	0.6	7.16							
29	曇	18.8	16.4	0.7	7.09							
30	雨	19.6	16.6	0.5	7.18							
平均		16.5	15.2	0.8	7.28	31.8	39.4	72	6.0	<0.03	<0.02	
最高		20.9	16.6	1.3	7.40	33.3	41.9	73	6.2	<0.03	<0.02	
最低		12.2	13.3	0.3	7.09	30.2	37.0	72	5.7	<0.03	<0.02	