

令和 5年 6月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	22.6	16.6	18.1	7.65	36.2	41.8	133	3.5	0.09	<0.02	
2	雨	20.8	17.5	22.2	7.61							
3	曇	21.0	17.2	246.2	7.48							
4	晴	24.0	16.9	410.6	7.71							
5	晴	23.6	16.5	408.6	7.72							
6	曇	21.1	16.1	750.6	7.79							
7	晴	23.3	17.0	570.0	7.74							
8	晴	24.8	16.5	363.2	7.71							
9	雨	22.0	16.4	329.5	7.68							
10	曇	24.2	16.2	273.9	7.63							
11	雨	20.5	16.6	198.2	7.54							
12	雨	22.6	16.5	264.3	7.56							
13	晴	28.2	17.9	214.2	7.55							
14	曇	24.8	18.5	195.3	7.60							
15	曇	23.9	18.0	165.2	7.74	36.9	41.0	259	2.0	0.50	0.03	
16	晴	24.2	17.9	139.3	7.67							
17	晴	25.7	17.3	134.6	7.64							
18	晴	24.6	17.7	123.9	7.59							
19	晴	26.2	17.5	109.7	7.69							
20	晴	23.5	17.7	63.6	7.68							
21	曇	25.1	18.7	85.9	7.73							
22	曇	21.4	17.9	73.2	7.77							
23	曇	23.1	17.9	61.9	7.71							
24	晴	25.2	18.6	53.3	7.65							
25	曇	24.7	18.9	55.5	7.63							
26	曇	24.3	19.6	49.6	7.68							
27	曇	26.2	18.7	41.6	7.65							
28	晴	29.0	19.8	40.5	7.68							
29	曇	25.1	20.4	39.1	7.66							
30	雨	26.1	20.6	30.4	7.67							
平均		24.1	17.8	184.4	7.66	36.6	41.4	196	2.8	0.30	<0.02	
最高		29.0	20.6	750.6	7.79	36.9	41.8	259	3.5	0.50	0.03	
最低		20.5	16.1	18.1	7.48	36.2	41.0	133	2.0	0.09	<0.02	

令和 5年 6月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	22.6	19.7	0.8	7.08	31.9	40.2	84	6.3	<0.03	<0.02	
2	雨	20.8	20.0	1.1	7.15							
3	曇	21.0	20.2	1.0	7.12							
4	晴	24.0	20.0	2.4	7.02							
5	晴	23.6	20.1	2.9	7.05							
6	曇	21.1	19.8	1.7	6.95							
7	晴	23.3	19.8	1.5	6.75							
8	晴	24.8	19.7	1.6	6.63							
9	雨	22.0	19.9	1.7	6.67							
10	曇	24.2	19.5	2.5	6.74							
11	雨	20.5	19.8	1.2	6.66							
12	雨	22.6	19.7	1.4	6.67							
13	晴	28.2	19.4	1.5	6.69							
14	曇	24.8	20.2	1.8	6.74							
15	曇	23.9	20.2	1.5	6.84	28.4	40.8	65	9.0	<0.03	<0.02	
16	晴	24.2	20.1	1.6	6.79							
17	晴	25.7	20.4	2.0	6.82							
18	晴	24.6	20.8	2.0	6.94							
19	晴	26.2	21.0	1.0	6.85							
20	晴	23.5	20.9	1.4	6.93							
21	曇	25.1	20.8	1.6	6.93							
22	曇	21.4	21.0	1.2	6.94							
23	曇	23.1	20.6	1.0	6.91							
24	晴	25.2	20.8	1.1	6.99							
25	曇	24.7	21.3	1.0	6.96							
26	曇	24.3	21.6	0.7	7.03							
27	曇	26.2	21.7	0.8	7.02							
28	晴	29.0	21.8	0.5	7.06							
29	曇	25.1	21.7	0.9	7.07							
30	雨	26.1	22.2	0.7	7.08							
平均		24.1	20.5	1.4	6.90	30.2	40.5	74	7.6	<0.03	<0.02	
最高		29.0	22.2	2.9	7.15	31.9	40.8	84	9.0	<0.03	<0.02	
最低		20.5	19.4	0.5	6.63	28.4	40.2	65	6.3	<0.03	<0.02	