

令和 5年 7月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考	
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L		
1	雨	24.7	20.2	37.9	7.62								
2	晴	26.3	20.2	34.2	7.65								
3	晴	30.1	20.2	71.1	7.66								
4	晴	26.7	20.7	115.1	7.68								
5	曇	25.0	21.1	139.1	7.67								
6	晴	26.6	21.2	143.0	7.63	35.3	38.6	407	2.2	0.84	<0.02		
7	晴	28.1	22.0	114.0	7.62								
8	曇	26.8	21.3	147.2	7.59								
9	曇	27.3	20.5	152.4	7.55								
10	晴	29.0	21.1	77.4	7.74								
11	晴	29.3	21.4	54.1	7.70								
12	晴	30.4	22.2	45.9	7.68								
13	曇	26.0	21.7	34.3	7.75								
14	晴	27.5	21.6	40.0	7.71								
15	曇	27.3	21.4	46.0	7.67								
16	晴	27.9	21.9	47.6	7.65								
17	晴	27.8	21.1	86.7	7.67								
18	晴	30.8	22.4	77.2	7.66								
19	晴	28.8	22.5	67.4	7.66								
20	晴	28.7	22.2	52.3	7.71	35.0	38.5	441	2.6	3.10	<0.02		
21	晴	28.4	22.5	41.3	7.72								
22	晴	28.4	22.8	42.9	7.73								
23	晴	28.3	22.6	36.5	7.70								
24	晴	29.2	22.9	29.0	7.75								
25	晴	30.4	23.9	27.5	7.76								
26	晴	30.9	24.0	23.6	7.68								
27	晴	30.0	23.9	20.4	7.67								
28	晴	31.1	24.2	16.3	7.73								
29	晴	30.0	24.1	20.9	7.72								
30	晴	31.3	24.1	17.0	7.71								
31	晴	31.0	24.3	10.8	7.83								
平均		28.5	22.1	60.3	7.69	35.2	38.6	424	2.4	1.97	<0.02		
最高		31.3	24.3	152.4	7.83	35.3	38.6	441	2.6	3.10	<0.02		
最低		24.7	20.2	10.8	7.55	35.0	38.5	407	2.2	0.84	<0.02		

令和 5年 7月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考	
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L		
1	雨	24.7	22.2	1.2	7.04								
2	晴	26.3	22.6	0.7	7.04								
3	晴	30.1	23.1	0.6	7.00								
4	晴	26.7	23.5	0.9	7.10								
5	曇	25.0	23.5	0.9	6.91								
6	晴	26.6	23.2	0.8	6.83	27.6	38.3	80	8.1	0.04	<0.02		
7	晴	28.1	23.5	0.9	6.80								
8	曇	26.8	23.6	1.0	6.81								
9	曇	27.3	23.9	0.9	6.92								
10	晴	29.0	23.5	0.4	6.93								
11	晴	29.3	23.9	0.6	6.94								
12	晴	30.4	24.5	0.9	7.08								
13	曇	26.0	24.1	0.8	7.10								
14	晴	27.5	23.9	0.9	7.12								
15	曇	27.3	24.6	0.6	7.03								
16	晴	27.9	24.3	0.7	7.07								
17	晴	27.8	24.7	0.6	7.09								
18	晴	30.8	25.0	0.7	7.03								
19	晴	28.8	25.1	1.1	7.04								
20	晴	28.7	24.7	1.0	7.03	29.9	38.0	65	6.6	<0.03	<0.02		
21	晴	28.4	24.9	0.8	7.09								
22	晴	28.4	25.1	1.1	7.07								
23	晴	28.3	25.4	1.1	7.16								
24	晴	29.2	25.6	0.5	7.15								
25	晴	30.4	26.3	0.8	7.16								
26	晴	30.9	26.5	0.7	7.09								
27	晴	30.0	26.3	0.8	7.17								
28	晴	31.1	26.4	0.7	7.15								
29	晴	30.0	26.4	0.6	7.17								
30	晴	31.3	26.7	0.5	7.16								
31	晴	31.0	27.1	0.4	7.26								
平均		28.5	24.6	0.8	7.05	28.8	38.2	72	7.4	<0.03	<0.02		
最高		31.3	27.1	1.2	7.26	29.9	38.3	80	8.1	0.04	<0.02		
最低		24.7	22.2	0.4	6.80	27.6	38.0	65	6.6	<0.03	<0.02		