

令和 5年 8月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原水水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	30.5	24.7	14.1	7.76							
2	晴	29.7	24.8	9.6	7.80							
3	晴	31.2	24.7	9.5	7.81	38.4	42.3	129	3.3	0.05	<0.02	
4	晴	30.6	25.0	7.4	7.80							
5	晴	29.4	24.8	8.8	7.82							
6	晴	30.2	25.0	13.7	7.70							
7	雨	26.8	25.7	7.9	7.65							
8	晴	30.6	25.7	6.9	7.78							
9	雨	27.1	26.0	7.7	7.76							
10	晴	29.5	25.1	5.8	7.74							
11	晴	29.8	25.2	5.1	7.77							
12	晴	29.8	25.4	4.2	7.73							
13	晴	30.7	25.6	4.8	7.77							
14	晴	29.9	25.8	4.1	7.83							
15	雨	26.4	25.9	3.2	7.84							
16	晴	28.3	25.2	4.8	7.85							
17	曇	28.6	25.4	13.7	7.74	33.7	37.8	96	3.0	0.06	<0.02	
18	晴	29.9	24.8	6.3	7.75							
19	晴	29.4	24.1	9.2	7.59							
20	晴	30.8	25.1	5.6	7.76							
21	晴	30.7	25.2	5.6	7.76							
22	晴	31.8	25.5	6.6	7.77							
23	雨	26.4	26.1	8.3	7.77							
24	雨	26.1	25.4	5.7	7.81							
25	晴	28.6	25.3	7.3	7.82							
26	晴	29.9	24.4	12.6	7.70							
27	晴	28.3	24.9	7.2	7.77							
28	晴	29.1	25.0	6.5	7.78							
29	晴	29.8	25.0	6.8	7.83							
30	曇	28.6	25.9	6.9	7.76							
31	晴	30.0	25.3	5.5	7.82							
平均		29.3	25.2	7.5	7.77	36.0	40.0	112	3.2	0.06	<0.02	
最高		31.8	26.1	14.1	7.85	38.4	42.3	129	3.3	0.06	<0.02	
最低		26.1	24.1	3.2	7.59	33.7	37.8	96	3.0	0.05	<0.02	

令和 5年 8月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	30.5	27.0	0.9	7.21							
2	晴	29.7	27.3	0.8	7.22							
3	晴	31.2	27.2	0.9	7.22	35.7	41.8	71	5.8	<0.03	<0.02	
4	晴	30.6	27.3	0.4	7.28							
5	晴	29.4	27.3	0.5	7.25							
6	晴	30.2	27.2	0.5	7.29							
7	雨	26.8	28.0	0.4	7.34							
8	晴	30.6	27.7	0.5	7.22							
9	雨	27.1	27.7	0.4	7.32							
10	晴	29.5	27.0	0.4	7.37							
11	晴	29.8	27.0	0.5	7.24							
12	晴	29.8	27.4	0.4	7.24							
13	晴	30.7	27.8	0.2	7.37							
14	晴	29.9	27.9	0.2	7.39							
15	雨	26.4	27.6	0.4	7.47							
16	晴	28.3	27.2	0.4	7.45							
17	曇	28.6	27.6	0.3	7.35	37.6	43.4	81	5.5	<0.03	<0.02	
18	晴	29.9	27.1	0.4	7.34							
19	晴	29.4	27.7	0.4	7.37							
20	晴	30.8	27.3	0.3	7.33							
21	晴	30.7	27.6	0.3	7.35							
22	晴	31.8	27.7	0.4	7.35							
23	雨	26.4	28.1	0.5	7.28							
24	雨	26.1	27.4	0.4	7.38							
25	晴	28.6	27.4	0.4	7.21							
26	晴	29.9	26.7	0.7	7.21							
27	晴	28.3	26.9	0.6	7.23							
28	晴	29.1	27.2	0.5	7.37							
29	晴	29.8	27.3	0.6	7.38							
30	曇	28.6	27.8	0.4	7.27							
31	晴	30.0	27.3	0.5	7.29							
平均		29.3	27.4	0.5	7.31	36.6	42.6	76	5.6	<0.03	<0.02	
最高		31.8	28.1	0.9	7.47	37.6	43.4	81	5.8	<0.03	<0.02	
最低		26.1	26.7	0.2	7.21	35.7	41.8	71	5.5	<0.03	<0.02	