

令和 5年 9月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	29.3	25.4	4.7	7.80							
2	晴	29.0	25.4	4.8	7.79							
3	晴	30.1	24.7	5.7	7.81							
4	曇	29.7	25.6	3.7	7.84							
5	晴	28.7	25.7	3.3	7.78							
6	雨	24.7	26.1	3.5	7.81							
7	曇	25.6	25.4	3.5	7.80	41.4	46.9	163	3.4	<0.03	<0.02	
8	曇	22.7	25.8	3.5	7.78							
9	晴	26.2	24.0	4.8	7.80							
10	晴	27.8	25.0	5.1	7.85							
11	曇	28.3	24.9	3.2	7.89							
12	晴	28.2	25.0	4.0	7.85							
13	晴	28.3	25.4	3.8	7.88							
14	曇	28.3	25.3	4.1	7.86							
15	晴	30.0	25.0	3.9	7.87							
16	晴	29.9	25.1	3.9	7.83							
17	晴	29.0	25.2	6.7	7.89							
18	晴	28.8	24.6	4.5	7.95							
19	晴	27.7	25.3	2.8	7.83							
20	晴	29.7	25.9	3.4	7.84							
21	雨	24.6	25.2	3.1	7.83	44.9	50.0	82	4.2	<0.03	<0.02	
22	曇	24.8	25.7	4.4	7.84							
23	晴	25.5	24.9	6.9	7.63							
24	曇	23.3	23.9	9.8	7.80							
25	晴	24.6	25.0	5.8	7.84							
26	晴	23.5	24.3	4.6	7.81							
27	晴	26.6	24.8	5.3	7.83							
28	晴	29.3	24.7	4.0	7.82							
29	晴	26.0	24.7	4.4	7.85							
30	晴	26.5	24.5	3.9	7.83							
平均		27.2	25.1	4.5	7.83	43.2	48.4	122	3.8	<0.03	<0.02	
最高		30.1	26.1	9.8	7.95	44.9	50.0	163	4.2	<0.03	<0.02	
最低		22.7	23.9	2.8	7.63	41.4	46.9	82	3.4	<0.03	<0.02	

令和 5年 9月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	29.3	27.4	0.5	7.32							
2	晴	29.0	27.4	0.6	7.38							
3	晴	30.1	27.9	0.6	7.38							
4	曇	29.7	27.7	0.4	7.41							
5	晴	28.7	27.6	0.7	7.33							
6	雨	24.7	27.9	0.7	7.30							
7	曇	25.6	27.0	0.6	7.36	39.6	46.0	62	5.2	<0.03	<0.02	
8	曇	22.7	26.9	0.8	7.23							
9	晴	26.2	26.5	0.5	7.23							
10	晴	27.8	26.3	0.9	7.29							
11	曇	28.3	26.4	0.9	7.49							
12	晴	28.2	26.4	1.3	7.39							
13	晴	28.3	26.8	1.6	7.34							
14	曇	28.3	26.8	1.8	7.32							
15	晴	30.0	26.4	1.7	7.34							
16	晴	29.9	26.5	1.9	7.42							
17	晴	29.0	26.7	2.4	7.46							
18	晴	28.8	26.7	1.3	7.50							
19	晴	27.7	26.7	0.9	7.43							
20	晴	29.7	27.2	0.4	7.33							
21	雨	24.6	26.4	0.5	7.46	43.5	50.2	76	6.0	<0.03	<0.02	
22	曇	24.8	26.7	0.5	7.35							
23	晴	25.5	26.0	0.5	7.49							
24	曇	23.3	25.9	0.5	7.33							
25	晴	24.6	26.1	0.6	7.36							
26	晴	23.5	25.3	0.5	7.34							
27	晴	26.6	25.8	0.4	7.32							
28	晴	29.3	25.6	0.4	7.42							
29	晴	26.0	25.6	0.4	7.45							
30	晴	26.5	25.6	0.3	7.33							
平均		27.2	26.6	0.8	7.37	41.6	48.1	69	5.6	<0.03	<0.02	
最高		30.1	27.9	2.4	7.50	43.5	50.2	76	6.0	<0.03	<0.02	
最低		22.7	25.3	0.3	7.23	39.6	46.0	62	5.2	<0.03	<0.02	