

令和 5年 10月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原水水質試験結果 (沈砂池)									備考	
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L		
1	晴	27.1	24.6	6.2	7.91								
2	晴	23.4	24.4	2.9	7.89								
3	晴	22.5	23.9	5.9	7.92								
4	雨	18.9	24.1	4.0	7.86								
5	晴	23.4	23.5	3.8	7.88	45.1	51.1	268	4.7	0.11	<0.02		
6	晴	19.7	22.5	4.4	7.83								
7	曇	19.1	22.3	6.2	7.78								
8	曇	18.9	22.3	5.5	7.73								
9	雨	18.2	21.0	5.0	7.78								
10	晴	21.2	21.7	4.5	7.73								
11	曇	21.3	21.8	7.7	7.80								
12	晴	21.2	21.2	7.6	7.82								
13	晴	19.6	20.6	5.0	7.84								
14	曇	18.6	19.6	7.3	7.78								
15	雨	16.9	20.1	6.3	7.84								
16	晴	20.2	20.0	4.5	7.79								
17	晴	23.0	20.3	2.6	7.90								
18	晴	20.3	20.8	8.0	7.93								
19	晴	23.0	19.7	5.5	7.86	41.7	47.8	169	5.0	0.05	<0.02		
20	晴	22.8	19.7	5.3	7.83								
21	晴	17.8	19.3	4.8	7.83								
22	晴	15.4	18.8	4.5	7.90								
23	晴	17.0	18.7	4.2	7.83								
24	晴	18.1	18.6	2.0	7.90								
25	曇	15.4	18.9	3.4	7.96								
26	晴	17.9	18.7	2.7	7.88								
27	晴	17.6	18.4	4.5	7.90								
28	晴	16.6	18.2	3.7	7.85								
29	晴	16.1	17.2	4.5	7.86								
30	晴	17.2	17.9	3.1	7.78								
31	晴	18.0	17.8	3.1	7.80								
平均		19.6	20.5	4.8	7.84	43.4	49.4	218	4.8	0.08	<0.02		
最高		27.1	24.6	8.0	7.96	45.1	51.1	268	5.0	0.11	<0.02		
最低		15.4	17.2	2.0	7.73	41.7	47.8	169	4.7	0.05	<0.02		

令和 5年 10月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	27.1	25.6	0.4	7.48							
2	晴	23.4	25.4	0.3	7.47							
3	晴	22.5	25.0	0.4	7.50							
4	雨	18.9	25.0	0.5	7.41							
5	晴	23.4	24.2	0.4	7.42	43.1	50.9	106	6.5	<0.03	<0.02	
6	晴	19.7	23.4	0.3	7.46							
7	曇	19.1	22.7	0.5	7.30							
8	曇	18.9	22.8	0.4	7.45							
9	雨	18.2	22.5	0.3	7.29							
10	晴	21.2	22.2	0.4	7.40							
11	曇	21.3	22.6	0.8	7.28							
12	晴	21.2	22.5	1.1	7.36							
13	晴	19.6	21.7	0.7	7.31							
14	曇	18.6	21.7	0.6	7.08							
15	雨	16.9	21.0	0.7	7.38							
16	晴	20.2	21.0	0.4	7.42							
17	晴	23.0	21.0	0.5	7.32							
18	晴	20.3	21.2	0.4	7.35							
19	晴	23.0	20.9	0.9	7.36	38.9	46.7	85	7.4	<0.03	<0.02	
20	晴	22.8	20.7	0.5	7.30							
21	晴	17.8	20.3	0.3	7.29							
22	晴	15.4	19.8	0.3	7.40							
23	晴	17.0	19.5	0.2	7.37							
24	晴	18.1	19.4	0.3	7.36							
25	曇	15.4	19.6	0.3	7.39							
26	晴	17.9	19.6	0.5	7.36							
27	晴	17.6	19.2	0.3	7.43							
28	晴	16.6	19.0	0.3	7.32							
29	晴	16.1	19.1	0.2	7.30							
30	晴	17.2	18.6	0.1	7.31							
31	晴	18.0	18.6	0.2	7.39							
平均		19.6	21.5	0.4	7.36	41.0	48.8	96	7.0	<0.03	<0.02	
最高		27.1	25.6	1.1	7.50	43.1	50.9	106	7.4	<0.03	<0.02	
最低		15.4	18.6	0.1	7.08	38.9	46.7	85	6.5	<0.03	<0.02	