

令和 5年 11月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	17.6	18.3	3.7	7.88							
2	晴	19.8	17.9	3.8	7.79	45.1	51.0	102	5.0	<0.03	<0.02	
3	晴	19.4	17.5	3.2	7.71							
4	晴	19.5	17.6	2.9	7.86							
5	晴	18.7	17.5	3.2	7.86							
6	曇	22.3	17.6	2.7	7.89							
7	雨	19.9	17.9	1.8	7.90							
8	晴	17.5	18.1	3.3	7.88							
9	曇	17.1	17.5	3.6	7.81							
10	雨	16.9	17.7	6.8	7.70							
11	曇	14.8	16.0	4.3	7.71							
12	曇	14.1	16.6	4.1	7.75							
13	曇	11.9	15.4	2.8	7.73							
14	晴	11.9	15.5	2.5	7.82							
15	晴	9.9	15.6	3.0	7.87							
16	晴	11.8	15.2	3.3	7.82	43.4	49.6	148	4.9	0.04	<0.02	
17	雨	13.4	15.3	5.2	7.85							
18	晴	10.3	15.0	7.8	7.78							
19	晴	12.0	14.4	10.0	7.80							
20	晴	13.6	14.5	7.9	7.79							
21	曇	11.1	14.2	5.5	7.70							
22	晴	14.1	13.8	5.4	7.69							
23	晴	13.9	13.9	5.6	7.64							
24	晴	15.7	13.8	7.9	7.81							
25	晴	10.0	12.4	7.2	7.75							
26	曇	10.8	13.1	7.3	7.72							
27	晴	10.2	12.9	3.5	7.67							
28	曇	15.1	12.3	4.8	7.79							
29	晴	10.4	12.8	4.8	7.77							
30	晴	11.9	12.5	4.1	7.70							
平均		14.5	15.4	4.7	7.78	44.2	50.3	125	5.0	<0.03	<0.02	
最高		22.3	18.3	10.0	7.90	45.1	51.0	148	5.0	0.04	<0.02	
最低		9.9	12.3	1.8	7.64	43.4	49.6	102	4.9	<0.03	<0.02	

令和 5年 11月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	17.6	18.9	0.3	7.35							
2	晴	19.8	18.6	0.6	7.26	41.9	50.7	92	7.7	<0.03	<0.02	
3	晴	19.4	18.2	0.5	7.39							
4	晴	19.5	18.2	0.1	7.33							
5	晴	18.7	18.2	0.2	7.31							
6	曇	22.3	18.3	0.2	7.36							
7	雨	19.9	18.7	0.3	7.39							
8	晴	17.5	18.9	0.4	7.34							
9	曇	17.1	18.4	0.4	7.30							
10	雨	16.9	18.4	0.8	7.24							
11	曇	14.8	18.0	0.5	7.23							
12	曇	14.1	17.4	0.3	7.22							
13	曇	11.9	17.0	0.3	7.27							
14	晴	11.9	16.3	0.3	7.28							
15	晴	9.9	16.1	0.3	7.31							
16	晴	11.8	15.8	0.3	7.31	40.9	50.7	74	7.6	<0.03	<0.02	
17	雨	13.4	15.7	0.6	7.26							
18	晴	10.3	15.5	0.5	7.22							
19	晴	12.0	14.9	0.3	7.24							
20	晴	13.6	14.9	0.4	7.25							
21	曇	11.1	14.6	0.5	7.24							
22	晴	14.1	14.3	0.6	7.22							
23	晴	13.9	14.4	0.6	7.31							
24	晴	15.7	14.6	0.5	7.18							
25	晴	10.0	14.3	0.3	7.13							
26	曇	10.8	13.8	0.2	7.17							
27	晴	10.2	13.6	0.3	7.19							
28	曇	15.1	13.7	0.5	7.24							
29	晴	10.4	13.5	0.6	7.22							
30	晴	11.9	13.1	0.5	7.21							
平均		14.5	16.2	0.4	7.27	41.4	50.7	83	7.6	<0.03	<0.02	
最高		22.3	18.9	0.8	7.39	41.9	50.7	92	7.7	<0.03	<0.02	
最低		9.9	13.1	0.1	7.13	40.9	50.7	74	7.6	<0.03	<0.02	