

令和 5年 12月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	7.7	12.2	5.3	7.72							
2	晴	8.0	12.0	7.7	7.68							
3	晴	8.3	11.9	4.3	7.69							
4	晴	9.2	11.7	3.9	7.67							
5	曇	8.2	10.7	4.5	7.70							
6	晴	11.8	11.5	3.9	7.79							
7	晴	13.3	11.6	2.8	7.87	42.0	49.4	129	5.4	<0.03	<0.02	
8	晴	11.0	11.2	5.1	7.69							
9	晴	9.4	11.2	4.2	7.66							
10	晴	10.3	11.2	5.6	7.70							
11	曇	11.7	11.1	3.6	7.68							
12	雨	14.8	10.5	2.9	7.68							
13	晴	12.1	11.9	3.5	7.80							
14	晴	9.7	11.2	2.6	7.81							
15	雨	12.7	10.9	5.3	7.81							
16	曇	18.1	10.0	5.2	7.74							
17	晴	6.1	10.5	4.7	7.67							
18	晴	4.1	10.0	4.1	7.73							
19	晴	7.0	10.1	2.9	7.71							
20	晴	9.1	10.0	2.9	7.89							
21	晴	6.2	9.7	3.2	7.82	43.6	50.0	145	5.7	<0.03	<0.02	
22	晴	2.1	9.4	3.3	7.77							
23	晴	2.8	9.1	6.0	7.68							
24	晴	5.5	9.1	20.3	7.77							
25	晴	6.2	9.0	17.5	7.52							
26	晴	6.4	8.7	19.5	7.69							
27	晴	9.1	8.5	18.7	7.67							
28	晴	5.8	8.3	15.4	7.79							
29	晴	8.3	8.2	13.2	7.60							
30	晴	6.3	7.9	12.9	7.56							
31	雨	11.1	7.2	12.4	7.67							
平均		8.8	10.2	7.3	7.72	42.8	49.7	137	5.6	<0.03	<0.02	
最高		18.1	12.2	20.3	7.89	43.6	50.0	145	5.7	<0.03	<0.02	
最低		2.1	7.2	2.6	7.52	42.0	49.4	129	5.4	<0.03	<0.02	

令和 5年 12月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	7.7	12.9	0.5	7.16							
2	晴	8.0	12.6	0.6	7.18							
3	晴	8.3	12.3	0.4	7.16							
4	晴	9.2	12.1	0.2	7.18							
5	曇	8.2	11.9	0.4	7.24							
6	晴	11.8	12.0	0.6	7.21							
7	晴	13.3	12.0	0.6	7.24	39.5	49.2	125	8.2	<0.03	<0.02	
8	晴	11.0	11.8	0.5	7.25							
9	晴	9.4	11.7	0.4	7.11							
10	晴	10.3	11.7	0.6	7.12							
11	曇	11.7	11.7	0.4	7.18							
12	雨	14.8	12.0	0.5	7.24							
13	晴	12.1	12.4	0.5	7.26							
14	晴	9.7	12.1	0.5	7.23							
15	雨	12.7	11.9	0.7	7.30							
16	曇	18.1	12.0	0.5	7.29							
17	晴	6.1	11.8	0.6	7.23							
18	晴	4.1	11.1	0.3	7.26							
19	晴	7.0	10.6	0.3	7.25							
20	晴	9.1	10.7	0.5	7.33							
21	晴	6.2	10.4	0.5	7.28	40.4	50.2	70	8.1	<0.03	<0.02	
22	晴	2.1	10.0	0.5	7.31							
23	晴	2.8	9.6	0.4	7.23							
24	晴	5.5	9.4	0.7	7.30							
25	晴	6.2	9.4	0.5	7.18							
26	晴	6.4	9.3	0.9	7.09							
27	晴	9.1	9.1	0.9	7.04							
28	晴	5.8	9.0	0.9	7.12							
29	晴	8.3	8.9	0.9	7.04							
30	晴	6.3	8.8	0.7	7.15							
31	雨	11.1	9.0	0.6	7.10							
平均		8.8	11.0	0.5	7.20	40.0	49.7	98	8.2	<0.03	<0.02	
最高		18.1	12.9	0.9	7.33	40.4	50.2	125	8.2	<0.03	<0.02	
最低		2.1	8.8	0.2	7.04	39.5	49.2	70	8.1	<0.03	<0.02	