

令和 6年 3月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原水水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	9.8	8.2	82.3	7.55							
2	晴	4.3	8.0	81.1	7.51							
3	晴	4.8	6.7	61.7	7.57							
4	晴	7.3	7.5	48.8	7.56							
5	雨	8.3	7.4	37.6	7.53							
6	雨	8.5	7.6	40.0	7.55							
7	曇	6.5	7.6	31.1	7.55	33.8	40.6	122.0	4.6	0.12	<0.02	
8	晴	9.7	7.5	24.8	7.54							
9	晴	5.5	7.1	25.0	7.54							
10	晴	6.8	7.0	26.6	7.50							
11	晴	7.6	7.3	25.0	7.60							
12	雨	10.4	7.5	19.2	7.53							
13	晴	9.2	8.0	18.0	7.70							
14	晴	7.5	7.8	20.7	7.73	35.9	44.1	78.0	4.5	0.10	<0.02	
15	晴	11.9	7.5	15.1	7.69							
16	晴	14.8	8.0	13.8	7.60							
17	曇	13.6	7.9	12.2	7.51							
18	晴	9.7	8.0	9.1	7.60							
19	曇	7.4	7.8	7.7	7.66							
20	晴	11.6	8.4	8.5	7.67							
21	晴	5.5	7.6	5.9	7.66							
22	晴	6.2	7.5	7.1	7.64							
23	雨	6.0	7.5	5.9	7.50							
24	雨	9.2	7.5	5.9	7.34							
25	雨	11.7	7.5	9.5	7.54							
26	雨	11.3	8.0	7.5	7.53							
27	晴	11.5	8.1	4.8	7.68							
28	曇	13.3	9.0	9.8	7.69							
29	雨	17.2	9.0	7.1	7.63							
30	晴	18.2	8.0	32.8	7.37							
31	曇	17.0	9.2	32.7	7.54							
平均		9.8	7.8	23.8	7.57	34.8	42.4	100	4.6	0.11	<0.02	
最高		18.2	9.2	82.3	7.73	35.9	44.1	122	4.6	0.12	<0.02	
最低		4.3	6.7	4.8	7.34	33.8	40.6	78	4.5	0.10	<0.02	

様式-工水1 (A4用紙)

令和 6年 3月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	9.8	8.8	1.9	6.93							
2	晴	4.3	8.6	1.8	6.94							
3	晴	4.8	8.7	1.3	6.96							
4	晴	7.3	8.0	1.1	6.97							
5	雨	8.3	8.0	1.5	7.01							
6	雨	8.5	7.9	1.5	6.91							
7	曇	6.5	8.0	1.6	6.95	29.2	40.0	95.0	8.9	<0.03	<0.02	
8	晴	9.7	8.0	1.7	6.96							
9	晴	5.5	7.6	1.5	6.89							
10	晴	6.8	7.5	1.1	6.93							
11	晴	7.6	7.6	1.0	6.94							
12	雨	10.4	8.0	1.3	7.06							
13	晴	9.2	8.7	1.2	7.15							
14	晴	7.5	8.2	1.5	7.08	31.3	43.9	72.0	8.7	<0.03	<0.02	
15	晴	11.9	8.7	1.2	7.10							
16	晴	14.8	8.5	0.9	6.93							
17	曇	13.6	8.5	0.9	6.93							
18	晴	9.7	8.7	0.7	7.14							
19	曇	7.4	8.5	0.8	7.11							
20	晴	11.6	9.0	1.0	7.36							
21	晴	5.5	8.3	0.7	7.13							
22	晴	6.2	8.2	0.6	7.08							
23	雨	6.0	8.5	0.6	7.01							
24	雨	9.2	8.1	0.7	7.17							
25	雨	11.7	8.0	0.6	7.03							
26	雨	11.3	8.9	0.6	7.07							
27	晴	11.5	8.6	0.7	7.08							
28	曇	13.3	9.1	0.7	7.10							
29	雨	17.2	9.8	0.8	7.04							
30	晴	18.2	10.2	0.6	7.13							
31	曇	17.0	10.3	1.1	6.88							
平均		9.8	8.5	1.1	7.03	30.2	42.0	84	8.8	<0.03	<0.02	
最高		18.2	10.3	1.9	7.36	31.3	43.9	95	8.9	<0.03	<0.02	
最低		4.3	7.5	0.6	6.88	29.2	40.0	72	8.7	<0.03	<0.02	