

令和 6年 4月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	20.4	9.8	39.0	7.61							
2	晴	14.9	10.0	59.4	7.49							
3	雨	12.9	10.2	65.1	7.43							
4	晴	17.3	10.5	51.4	7.50							
5	曇	14.9	10.6	46.8	7.49							
6	晴	12.9	10.5	39.0	7.48							
7	晴	17.8	11.0	40.1	7.40							
8	曇	18.9	11.0	26.7	7.55							
9	雨	17.0	12.2	26.7	7.36							
10	晴	14.0	11.8	69.3	7.51							
11	晴	15.6	12.0	34.7	7.56	32.8	38.2	154	3.1	0.14	<0.02	
12	曇	15.9	12.2	107.0	7.51							
13	晴	17.8	13.2	143.9	7.44							
14	晴	18.4	12.0	124.2	7.44							
15	晴	20.0	12.3	95.5	7.57							
16	曇	18.8	13.7	68.9	7.61							
17	晴	18.4	13.2	51.7	7.56							
18	曇	20.4	13.2	27.8	7.63	18.6	19.8	51	3.7	<0.03	<0.02	
19	晴	16.6	13.1	36.8	7.56							
20	晴	22.0	14.0	33.4	7.62							
21	晴	20.1	14.0	26.3	7.35							
22	曇	19.7	13.9	21.4	7.59							
23	曇	19.3	14.0	18.7	7.63							
24	雨	15.2	14.6	18.1	7.53							
25	晴	20.4	14.0	15.7	7.48							
26	晴	22.5	14.7	14.9	7.60							
27	曇	19.5	14.7	12.8	7.49							
28	晴	20.7	15.0	15.2	7.12							
29	晴	20.4	15.0	12.1	7.52							
30	曇	21.3	15.2	9.9	7.68							
平均		18.1	12.7	45.1	7.51	25.7	29.0	102	3.4	0.07	<0.02	
最高		22.5	15.2	143.9	7.68	32.8	38.2	154	3.7	0.14	<0.02	
最低		12.9	9.8	9.9	7.12	18.6	19.8	51	3.1	<0.03	<0.02	

令和 6年 4月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	20.4	10.5	0.8	6.93							
2	晴	14.9	10.6	1.7	6.81							
3	雨	12.9	11.0	1.9	6.71							
4	晴	17.3	11.0	2.0	6.75							
5	曇	14.9	11.3	1.7	6.74							
6	晴	12.9	11.5	1.7	6.70							
7	晴	17.8	11.5	1.3	6.75							
8	曇	18.9	12.0	0.9	6.86							
9	雨	17.0	12.5	1.7	6.82							
10	晴	14.0	13.4	1.4	6.83							
11	晴	15.6	12.5	1.9	6.73	24.8	36.7	114	8.1	<0.03	<0.02	
12	曇	15.9	12.7	1.3	6.83							
13	晴	17.8	12.0	2.2	6.52							
14	晴	18.4	13.0	2.0	6.50							
15	晴	20.0	13.2	1.5	6.61							
16	曇	18.8	13.5	1.9	6.73							
17	晴	18.4	14.1	2.4	6.76							
18	曇	20.4	14.0	1.9	6.83	18.5	19.9	52	3.8	<0.03	<0.02	
19	晴	16.6	14.0	1.4	6.76							
20	晴	22.0	14.8	1.1	6.83							
21	晴	20.1	14.2	1.0	7.02							
22	曇	19.7	14.4	1.1	6.83							
23	曇	19.3	14.7	1.2	6.94							
24	雨	15.2	15.0	1.2	6.84							
25	晴	20.4	14.6	1.0	6.82							
26	晴	22.5	15.2	0.6	7.03							
27	曇	19.5	15.4	0.7	6.90							
28	晴	20.7	15.9	0.8	6.99							
29	晴	20.4	15.8	0.7	6.90							
30	曇	21.3	16.0	0.4	7.07							
平均		18.1	13.3	1.4	6.81	21.6	28.3	83	6.0	<0.03	<0.02	
最高		22.5	16.0	2.4	7.07	24.8	36.7	114	8.1	<0.03	<0.02	
最低		12.9	10.5	0.4	6.50	18.5	19.9	52	3.8	<0.03	<0.02	