

令和 6年 5月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	20.2	15.7	7.8	7.56							
2	曇	14.5	15.2	7.3	7.64							
3	晴	19.2	15.5	7.6	7.46							
4	晴	20.4	16.4	7.0	7.60							
5	晴	20.4	16.2	6.2	7.57							
6	曇	20.2	17.0	5.8	7.63							
7	雨	19.4	16.2	3.0	7.53							
8	晴	20.5	16.0	6.7	7.64							
9	晴	16.2	16.1	5.4	7.51	33.6	37.2	74	3.4	<0.03	<0.02	
10	晴	18.8	16.2	4.8	7.68							
11	晴	19.6	16.5	11.9	7.97							
12	曇	20.5	16.5	4.8	7.65							
13	雨	19.9	16.9	3.9	7.41							
14	晴	20.4	16.2	8.9	7.59							
15	晴	21.6	16.2	8.7	7.49							
16	曇	19.3	16.3	7.2	7.68							
17	晴	19.7	16.2	13.2	7.72							
18	晴	23.3	16.7	29.4	7.74							
19	雨	17.7	16.5	18.7	7.70							
20	曇	19.6	16.6	13.5	7.67							
21	晴	24.3	16.5	11.7	7.70							
22	晴	24.0	16.8	11.6	7.68							
23	曇	21.0	16.8	11.9	7.72	34.0	38.8	105	3.1	0.04	<0.02	
24	晴	23.0	17.4	10.6	7.69							
25	曇	23.1	17.5	12.9	7.72							
26	曇	22.2	18.2	10.2	7.75							
27	雨	20.2	17.3	11.6	7.73							
28	雨	22.0	17.5	9.9	7.64							
29	晴	20.6	17.4	43.3	7.71							
30	晴	23.3	17.5	58.9	7.74							
31	曇	19.1	17.2	221.6	7.71							
平均		20.5	16.6	19.2	7.65	33.8	38.0	90	3.2	<0.03	<0.02	
最高		24.3	18.2	221.6	7.97	34.0	38.8	105	3.4	0.04	<0.02	
最低		14.5	15.2	3.0	7.41	33.6	37.2	74	3.1	<0.03	<0.02	

令和 6年 5月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	20.2	16.2	0.9	7.07							
2	曇	14.5	16.1	0.5	7.01							
3	晴	19.2	16.0	0.4	6.80							
4	晴	20.4	17.1	0.2	6.91							
5	晴	20.4	17.0	0.3	6.94							
6	曇	20.2	17.9	0.1	7.01							
7	雨	19.4	16.8	0.3	7.14							
8	晴	20.5	16.7	0.4	7.07							
9	晴	16.2	16.7	0.5	6.86	30.0	37.6	73	6.5	<0.03	<0.02	
10	晴	18.8	16.7	0.4	7.04							
11	晴	19.6	17.0	0.7	7.00							
12	曇	20.5	17.0	0.2	6.98							
13	雨	19.9	17.3	0.4	7.16							
14	晴	20.4	17.0	0.5	7.05							
15	晴	21.6	17.0	1.0	6.83							
16	曇	19.3	17.2	0.5	7.06							
17	晴	19.7	17.1	0.5	7.23							
18	晴	23.3	17.0	1.1	7.16							
19	雨	17.7	17.5	0.8	7.17							
20	曇	19.6	17.2	0.7	7.23							
21	晴	24.3	17.4	0.7	7.12							
22	晴	24.0	17.6	0.9	7.12							
23	曇	21.0	17.8	0.4	7.19	29.3	37.4	87	6.4	<0.03	<0.02	
24	晴	23.0	17.8	0.8	7.19							
25	曇	23.1	18.5	0.6	7.19							
26	曇	22.2	19.2	0.4	7.21							
27	雨	20.2	18.4	0.6	7.23							
28	雨	22.0	18.0	0.8	7.18							
29	晴	20.6	18.2	0.4	7.18							
30	晴	23.3	18.3	1.3	7.09							
31	曇	19.1	18.3	2.2	6.91							
平均		20.5	17.4	0.6	7.08	29.6	37.5	80	6.4	<0.03	<0.02	
最高		24.3	19.2	2.2	7.23	30.0	37.6	87	6.5	<0.03	<0.02	
最低		14.5	16.0	0.1	6.80	29.3	37.4	73	6.4	<0.03	<0.02	