

令和 6年 6月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	20.5	18.2	184.4	7.71							
2	曇	22.4	17.5	141.3	7.78							
3	晴	20.5	17.0	125.7	7.75							
4	晴	21.6	16.9	113.6	7.74							
5	晴	22.7	17.0	95.7	7.72							
6	晴	24.7	17.3	90.4	7.79	37.2	41.5	171	2.2	0.46	<0.02	
7	晴	24.2	17.5	85.6	7.73							
8	晴	23.3	16.0	72.2	7.72							
9	雨	19.9	17.5	64.4	7.73							
10	晴	22.8	17.4	52.1	7.75							
11	晴	24.9	17.6	45.0	7.76							
12	晴	25.1	18.1	37.5	7.76							
13	曇	23.5	18.0	32.9	7.75							
14	晴	26.0	18.3	26.4	7.74							
15	晴	25.5	19.0	23.1	7.74							
16	曇	22.6	19.0	20.6	7.78							
17	曇	26.3	18.8	16.9	7.64							
18	雨	19.0	18.9	15.3	7.69							
19	晴	23.8	18.7	17.3	7.72							
20	曇	24.2	19.5	15.8	7.72	36.3	41.4	130	3.1	0.06	<0.02	
21	雨	19.0	19.2	19.0	7.74							
22	曇	23.8	19.0	35.9	7.65							
23	雨	21.5	21.1	36.6	7.69							
24	晴	29.1	19.2	41.5	7.71							
25	曇	27.9	19.3	72.1	7.68							
26	晴	28.3	19.0	166.9	7.65							
27	晴	27.4	19.2	171.2	7.79							
28	雨	24.0	20.2	107.4	7.75							
29	曇	26.1	21.5	169.2	7.70							
30	雨	24.2	19.5	202.9	7.73							
平均		23.8	18.5	76.6	7.73	36.8	41.4	150	2.6	0.26	<0.02	
最高		29.1	21.5	202.9	7.79	37.2	41.5	171	3.1	0.46	<0.02	
最低		19.0	16.0	15.3	7.64	36.3	41.4	130	2.2	0.06	<0.02	

令和 6年 6月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	20.5	19.5	1.5	6.92							
2	曇	22.4	19.0	1.6	6.97							
3	晴	20.5	18.5	0.8	6.97							
4	晴	21.6	18.5	1.4	6.98							
5	晴	22.7	18.4	1.4	6.98							
6	晴	24.7	18.5	1.3	7.03	29.0	42.4	95	8.0	<0.03	<0.02	
7	晴	24.2	18.6	1.3	6.98							
8	晴	23.3	19.0	1.2	7.02							
9	雨	19.9	18.5	0.7	7.04							
10	晴	22.8	18.5	0.4	7.06							
11	晴	24.9	18.5	1.4	7.08							
12	晴	25.1	19.2	1.0	7.09							
13	曇	23.5	19.4	1.2	7.10							
14	晴	26.0	19.5	0.9	7.10							
15	晴	25.5	20.0	0.8	7.13							
16	曇	22.6	20.5	0.6	7.17							
17	曇	26.3	20.0	0.6	7.08							
18	雨	19.0	20.0	0.7	7.12							
19	晴	23.8	19.6	0.6	7.15							
20	曇	24.2	20.2	0.8	7.12	30.6	40.7	111	6.6	0.03	<0.02	
21	雨	19.0	20.2	0.6	7.15							
22	曇	23.8	20.5	0.8	7.06							
23	雨	21.5	20.1	0.7	7.07							
24	晴	29.1	20.2	0.6	7.07							
25	曇	27.9	20.5	0.8	7.06							
26	晴	28.3	20.5	1.4	6.91							
27	晴	27.4	20.6	1.5	6.87							
28	雨	24.0	20.8	1.7	6.89							
29	曇	26.1	19.5	1.7	6.90							
30	雨	24.2	21.4	1.8	7.35							
平均		23.8	19.6	1.1	7.05	29.8	41.6	103	7.3	<0.03	<0.02	
最高		29.1	21.4	1.8	7.35	30.6	42.4	111	8.0	0.03	<0.02	
最低		19.0	18.4	0.4	6.87	29.0	40.7	95	6.6	<0.03	<0.02	