

令和 6年 7月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	雨	24.8	18.5	270.3	7.74							
2	晴	28.0	19.2	233.1	7.78							
3	曇	29.0	19.0	185.1	7.76							
4	晴	31.8	19.4	255.2	7.73	33.9	37.4	333	1.8	1.10	0.02	
5	晴	31.6	19.6	202.0	7.77							
6	晴	31.7	20.2	186.6	7.72							
7	晴	32.2	20.5	136.6	7.71							
8	晴	32.5	20.3	114.6	7.75							
9	曇	30.9	20.4	95.0	7.73							
10	晴	31.0	21.0	70.4	7.83							
11	曇	27.0	20.6	60.1	7.78							
12	雨	23.9	20.8	41.3	7.79							
13	晴	26.5	21.0	62.5	7.82							
14	曇	25.6	21.0	34.4	7.81							
15	晴	28.6	23.4	44.2	7.80							
16	雨	24.9	20.6	37.9	7.79							
17	晴	28.8	20.6	31.2	7.78							
18	晴	31.3	21.0	33.5	7.80	34.6	37.9	139	2.6	0.09	<0.02	
19	曇	28.6	21.2	25.9	7.78							
20	晴	30.7	21.0	45.1	7.76							
21	晴	32.5	22.3	41.2	7.74							
22	晴	33.9	21.5	37.4	7.72							
23	晴	32.1	21.9	33.4	7.77							
24	晴	31.6	22.2	32.7	7.68							
25	晴	32.2	22.0	24.7	7.72							
26	晴	30.9	22.4	25.3	7.78							
27	晴	31.7	23.0	23.9	7.73							
28	晴	34.3	23.0	20.9	7.82							
29	晴	35.3	23.0	17.6	7.68							
30	晴	35.1	23.1	14.9	7.76							
31	晴	33.1	23.2	11.9	7.72							
平均		30.4	21.2	79.0	7.76	34.2	37.6	236	2.2	0.59	<0.02	
最高		35.3	23.4	270.3	7.83	34.6	37.9	333	2.6	1.10	0.02	
最低		23.9	18.5	11.9	7.68	33.9	37.4	139	1.8	0.09	<0.02	

令和 6年 7月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	雨	24.8	20.2	1.2	6.83							
2	晴	28.0	20.4	2.0	6.84							
3	曇	29.0	20.4	1.3	6.89							
4	晴	31.8	20.7	1.3	6.84	25.8	37.7	107	9.1	<0.03	<0.02	
5	晴	31.6	21.1	2.1	6.82							
6	晴	31.7	22.1	1.6	6.87							
7	晴	32.2	23.5	1.0	6.86							
8	晴	32.5	22.0	0.8	6.89							
9	曇	30.9	22.0	1.3	6.90							
10	晴	31.0	22.4	1.2	6.98							
11	曇	27.0	22.2	1.0	7.01							
12	雨	23.9	22.2	1.1	7.04							
13	晴	26.5	22.0	1.3	7.07							
14	曇	25.6	22.0	1.0	7.15							
15	晴	28.6	22.0	0.8	7.10							
16	雨	24.9	22.3	0.7	7.10							
17	晴	28.8	22.2	1.2	7.09							
18	晴	31.3	22.3	1.0	7.06	28.6	37.9	108	7.0	<0.03	<0.02	
19	曇	28.6	22.8	1.1	7.07							
20	晴	30.7	23.0	1.2	7.04							
21	晴	32.5	24.2	0.9	7.03							
22	晴	33.9	23.0	0.9	7.03							
23	晴	32.1	23.8	1.2	7.07							
24	晴	31.6	23.8	1.2	7.03							
25	晴	32.2	23.8	1.1	7.07							
26	晴	30.9	24.0	1.1	7.09							
27	晴	31.7	24.5	1.2	7.08							
28	晴	34.3	24.5	0.5	7.17							
29	晴	35.3	24.5	0.5	7.08							
30	晴	35.1	24.8	0.7	7.14							
31	晴	33.1	24.8	0.6	7.14							
平均		30.4	22.7	1.1	7.01	27.2	37.8	108	8.0	<0.03	<0.02	
最高		35.3	24.8	2.1	7.17	28.6	37.9	108	9.1	<0.03	<0.02	
最低		23.9	20.2	0.5	6.82	25.8	37.7	107	7.0	<0.03	<0.02	