

令和 6年 9月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	雨	31.4	23.4	52.7	7.75							
2	曇	29.1	22.0	22.4	7.74							
3	晴	30.3	22.1	19.4	7.75							
4	晴	29.2	22.2	25.4	7.72							
5	晴	30.8	22.3	22.3	7.76	33.8	37.0	77	2.5	0.10	<0.02	
6	晴	30.4	22.8	16.3	7.80							
7	晴	32.3	23.0	13.2	7.80							
8	晴	28.0	23.0	17.5	7.83							
9	晴	32.5	23.0	11.8	7.83							
10	晴	32.5	23.2	9.9	7.88							
11	晴	31.6	23.4	9.2	7.78							
12	晴	31.9	23.7	8.7	7.75							
13	曇	28.6	24.0	8.5	7.82							
14	晴	30.9	23.5	7.6	7.75							
15	晴	28.3	24.5	7.6	7.83							
16	晴	32.8	25.1	6.4	7.88							
17	晴	32.1	24.0	7.3	7.71							
18	晴	32.5	24.0	6.1	7.74							
19	晴	32.9	24.4	6.1	7.78	38.0	42.3	98	3.6	<0.03	<0.02	
20	晴	32.8	24.3	5.9	7.81							
21	曇	31.2	25.5	6.9	7.85							
22	雨	28.6	25.0	6.1	7.91							
23	晴	26.1	24.8	5.4	7.85							
24	晴	24.6	24.1	9.0	7.89							
25	晴	23.7	23.9	5.1	7.84							
26	曇	27.5	23.7	4.9	7.82							
27	曇	25.0	23.9	5.1	7.85							
28	曇	25.5	24.5	3.5	7.82							
29	曇	25.8	23.9	4.9	7.86							
30	晴	27.9	23.2	4.9	7.90							
平均		29.6	23.7	11.3	7.81	35.9	39.6	88	3.0	0.05	<0.02	
最高		32.9	25.5	52.7	7.91	38.0	42.3	98	3.6	0.10	<0.02	
最低		23.7	22.0	3.5	7.71	33.8	37.0	77	2.5	<0.03	<0.02	

令和 6年 9月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	雨	31.4	25.2	0.4	7.19							
2	曇	29.1	23.4	0.5	7.07							
3	晴	30.3	23.4	0.8	7.16							
4	晴	29.2	23.7	0.8	7.12							
5	晴	30.8	23.6	1.0	7.13	28.2	36.9	61	6.2	<0.03	<0.02	
6	晴	30.4	24.1	1.0	7.17							
7	晴	32.3	24.5	0.8	7.21							
8	晴	28.0	24.5	0.8	7.23							
9	晴	32.5	24.5	0.5	7.27							
10	晴	32.5	24.8	0.7	7.30							
11	晴	31.6	24.9	0.6	7.18							
12	晴	31.9	24.9	0.6	7.25							
13	曇	28.6	25.2	0.5	7.27							
14	晴	30.9	25.6	0.4	7.24							
15	晴	28.3	25.9	0.5	7.25							
16	晴	32.8	25.5	0.2	7.32							
17	晴	32.1	25.3	0.4	7.18							
18	晴	32.5	25.2	0.4	7.23							
19	晴	32.9	25.3	0.3	7.29	34.8	42.5	93	6.2	<0.03	<0.02	
20	晴	32.8	25.4	0.3	7.31							
21	曇	31.2	26.4	0.3	7.29							
22	雨	28.6	26.0	0.2	7.33							
23	晴	26.1	26.1	0.1	7.37							
24	晴	24.6	25.2	0.3	7.36							
25	晴	23.7	24.8	0.4	7.26							
26	曇	27.5	24.6	0.3	7.32							
27	曇	25.0	24.8	0.3	7.34							
28	曇	25.5	25.5	0.4	7.92							
29	曇	25.8	25.0	0.4	7.91							
30	晴	27.9	24.3	0.4	7.48							
平均		29.6	24.9	0.5	7.30	31.5	39.7	77	6.2	<0.03	<0.02	
最高		32.9	26.4	1.0	7.92	34.8	42.5	93	6.2	<0.03	<0.02	
最低		23.7	23.4	0.1	7.07	28.2	36.9	61	6.2	<0.03	<0.02	