

令和 6年 11月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	22.2	17.8	9.2	7.86							
2	雨	19.9	17.5	12.4	7.74							
3	晴	18.2	18.0	23.0	7.67							
4	晴	22.9	17.5	19.8	7.71							
5	曇	18.9	16.7	14.4	7.74							
6	晴	20.4	16.7	82.0	7.72							
7	晴	16.0	16.4	100.0	7.73	34.3	37.7	177	2.4	0.26	<0.02	
8	曇	14.1	15.9	97.9	7.72							
9	晴	14.7	15.9	95.0	7.78							
10	曇	20.0	16.0	60.0	7.70							
11	曇	19.0	15.4	45.6	7.74							
12	曇	20.6	15.7	34.3	7.80							
13	晴	20.5	15.3	35.5	7.79							
14	曇	17.2	15.2	33.0	7.82							
15	曇	17.5	14.9	34.6	7.79							
16	曇	18.0	15.0	37.3	7.83							
17	晴	18.7	15.0	28.7	7.78							
18	晴	17.5	15.0	26.7	7.81							
19	曇	11.5	14.5	22.2	7.83							
20	曇	10.0	14.4	20.9	7.66							
21	晴	14.6	14.3	21.0	7.76	37.0	42.3	100	3.0	0.21	<0.02	
22	晴	14.3	14.3	22.0	7.80							
23	晴	12.0	14.2	22.3	7.80							
24	曇	11.5	14.5	18.7	7.69							
25	曇	9.3	14.0	15.3	7.77							
26	曇	15.4	13.6	15.1	7.82							
27	晴	16.0	13.6	14.9	7.82							
28	晴	12.6	13.4	15.1	7.80							
29	曇	9.1	13.1	16.0	7.75							
30	晴	10.0	12.5	15.5	7.75							
平均		16.1	15.2	33.6	7.77	35.6	40.0	138	2.7	0.24	<0.02	
最高		22.9	18.0	100.0	7.86	37.0	42.3	177	3.0	0.26	<0.02	
最低		9.1	12.5	9.2	7.66	34.3	37.7	100	2.4	0.21	<0.02	

令和 6年 11月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	22.2	19.3	0.4	7.29							
2	雨	19.9	19.0	0.4	7.37							
3	晴	18.2	19.7	0.4	7.20							
4	晴	22.9	19.5	0.4	7.13							
5	曇	18.9	18.4	0.6	7.22							
6	晴	20.4	18.5	1.1	7.23							
7	晴	16.0	18.0	1.6	7.05	27.7	37.6	88	7.5	0.03	<0.02	
8	曇	14.1	17.5	1.4	7.06							
9	晴	14.7	17.7	1.7	7.06							
10	曇	20.0	17.5	1.1	7.08							
11	曇	19.0	17.0	1.0	7.11							
12	曇	20.6	17.2	1.2	7.14							
13	晴	20.5	17.4	1.3	7.22							
14	曇	17.2	17.0	1.6	7.17							
15	曇	17.5	16.8	1.2	7.13							
16	曇	18.0	16.5	1.3	7.11							
17	晴	18.7	16.5	0.9	7.16							
18	晴	17.5	16.6	0.8	7.20							
19	曇	11.5	16.1	1.1	7.25							
20	曇	10.0	16.0	0.9	7.14							
21	晴	14.6	15.6	1.1	7.15	32.9	42.7	98	6.8	<0.03	<0.02	
22	晴	14.3	15.5	1.0	7.19							
23	晴	12.0	15.5	1.7	7.18							
24	曇	11.5	15.6	0.8	7.11							
25	曇	9.3	15.0	0.7	7.20							
26	曇	15.4	14.6	0.9	7.19							
27	晴	16.0	14.7	0.9	7.24							
28	晴	12.6	14.5	1.2	7.21							
29	曇	9.1	14.2	1.1	7.27							
30	晴	10.0	13.5	0.8	7.18							
平均		16.1	16.7	1.0	7.17	30.3	40.2	93	7.2	<0.03	<0.02	
最高		22.9	19.7	1.7	7.37	32.9	42.7	98	7.5	0.03	<0.02	
最低		9.1	13.5	0.4	7.05	27.7	37.6	88	6.8	<0.03	<0.02	