

令和 6年 12月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考	
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L		
1	晴	13.0	12.7	15.5	7.82								
2	晴	14.5	12.2	11.9	7.65								
3	晴	15.7	12.1	9.2	7.80								
4	晴	14.1	12.2	11.1	7.84								
5	晴	11.9	12.0	9.0	7.75	38.3	45.8	94	3.8	0.08	<0.02		
6	晴	9.1	11.7	10.9	7.81								
7	晴	10.5	11.8	11.5	7.82								
8	曇	7.8	11.0	10.3	7.77								
9	晴	8.8	10.9	9.3	7.75								
10	晴	9.2	10.7	5.7	7.83								
11	晴	9.3	10.6	10.8	10.80								
12	晴	7.5	10.5	9.0	7.82								
13	曇	6.2	10.3	10.0	7.79								
14	晴	7.9	10.6	9.7	7.64								
15	晴	5.0	10.0	13.8	7.75								
16	晴	7.9	10.0	9.4	7.80								
17	晴	8.8	9.8	7.1	7.78								
18	晴	7.6	9.7	7.3	7.80								
19	晴	6.5	9.4	7.6	7.83	39.4	45.2	85	4.4	0.09	<0.02		
20	晴	3.5	9.2	8.6	7.73								
21	晴	7.6	9.0	7.2	7.73								
22	晴	9.3	8.9	7.3	7.77								
23	晴	5.7	8.5	6.9	7.74								
24	晴	6.7	8.6	5.5	7.84								
25	晴	6.1	8.6	5.7	7.94								
26	曇	10.8	8.5	5.1	7.81								
27	晴	8.0	8.3	6.0	7.76								
28	晴	5.9	8.2	4.7	7.75								
29	晴	7.0	8.5	5.2	7.75								
30	晴	6.7	7.6	4.8	7.75								
31	曇	7.4	8.0	4.9	7.74								
平均		8.6	10.0	8.4	7.88	38.8	45.5	90	4.1	0.09	<0.02		
最高		15.7	12.7	15.5	10.80	39.4	45.8	94	4.4	0.09	<0.02		
最低		3.5	7.6	4.7	7.64	38.3	45.2	85	3.8	0.08	<0.02		

令和 6年 12月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考	
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L		
1	晴	13.0	13.8	0.4	7.21								
2	晴	14.5	13.1	0.7	7.15								
3	晴	15.7	13.0	0.8	7.27								
4	晴	14.1	13.2	1.6	7.30								
5	晴	11.9	13.0	0.8	7.35	35.4	45.3	91	6.7	<0.03	<0.02		
6	晴	9.1	12.8	0.7	7.28								
7	晴	10.5	12.9	0.7	7.27								
8	曇	7.8	12.0	0.7	7.23								
9	晴	8.8	11.7	0.6	7.28								
10	晴	9.2	11.5	0.7	7.38								
11	晴	9.3	11.6	1.8	7.36								
12	晴	7.5	11.4	0.9	7.33								
13	曇	6.2	11.0	1.0	7.27								
14	晴	7.9	11.4	0.9	7.22								
15	晴	5.0	11.0	0.9	7.28								
16	晴	7.9	10.7	0.6	7.31								
17	晴	8.8	10.4	0.8	7.33								
18	晴	7.6	10.4	1.0	7.40								
19	晴	6.5	10.2	1.1	7.40	36.3	45.2	75	6.8	0.05	<0.02		
20	晴	3.5	9.8	0.8	7.25								
21	晴	7.6	9.7	0.7	7.24								
22	晴	9.3	9.8	0.4	7.28								
23	晴	5.7	9.3	0.4	7.35								
24	晴	6.7	9.2	0.8	7.37								
25	晴	6.1	9.2	1.1	7.36								
26	曇	10.8	9.2	0.9	7.41								
27	晴	8.0	9.1	0.6	7.30								
28	晴	5.9	9.0	0.5	7.33								
29	晴	7.0	9.5	0.4	7.34								
30	晴	6.7	8.5	0.5	7.54								
31	曇	7.4	8.9	0.3	7.37								
平均		8.6	10.8	0.8	7.31	35.8	45.2	83	6.8	<0.03	<0.02		
最高		15.7	13.8	1.8	7.54	36.3	45.3	91	6.8	0.05	<0.02		
最低		3.5	8.5	0.3	7.15	35.4	45.2	75	6.7	<0.03	<0.02		