

令和 7年 1月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果（沈砂池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	6.5	7.9	4.0	7.75							
2	晴	10.3	7.9	3.8	7.76							
3	晴	8.0	7.8	3.1	7.78							
4	晴	5.0	7.6	3.4	7.76							
5	晴	4.0	7.5	4.4	7.50							
6	雨	7.3	7.2	3.1	7.77							
7	晴	9.4	7.4	2.8	7.89							
8	晴	4.1	7.2	2.6	7.80							
9	晴	5.7	7.0	2.7	7.70	39.7	46.2	86	5.3	<0.03	<0.02	
10	晴	0.5	6.7	3.3	7.84							
11	晴	6.5	6.5	2.9	7.69							
12	曇	4.6	6.6	3.2	7.73							
13	晴	6.5	6.8	3.1	7.68							
14	晴	7.7	6.7	2.6	7.79							
15	曇	7.5	6.7	3.0	7.81							
16	晴	3.3	6.5	3.4	7.80							
17	晴	7.4	6.2	4.1	7.78							
18	曇	4.1	6.5	4.3	7.69							
19	曇	7.9	6.4	3.8	7.77							
20	晴	10.8	6.2	4.6	7.74							
21	晴	8.3	6.5	3.7	7.78							
22	晴	8.1	6.5	4.2	7.83							
23	晴	7.8	6.4	5.1	7.71	40.3	46.1	83	6.0	<0.03	<0.02	
24	晴	7.9	6.3	5.9	7.78							
25	晴	10.0	6.3	5.7	7.78							
26	晴	11.5	6.4	5.6	7.74							
27	曇	5.0	5.9	5.3	7.77							
28	晴	8.6	6.0	4.8	7.63							
29	晴	6.2	6.1	5.4	7.74							
30	晴	5.8	5.8	5.5	7.76							
31	晴	5.2	5.6	6.8	7.76							
平均		6.8	6.7	4.1	7.75	40.0	46.2	84	5.6	<0.03	<0.02	
最高		11.5	7.9	6.8	7.89	40.3	46.2	86	6.0	<0.03	<0.02	
最低		0.5	5.6	2.6	7.50	39.7	46.1	83	5.3	<0.03	<0.02	

令和 7年 1月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	6.5	9.0	0.4	7.40							
2	晴	10.3	8.8	0.2	7.39							
3	晴	8.0	8.5	0.3	7.42							
4	晴	5.0	8.9	0.1	7.40							
5	晴	4.0	8.0	0.5	7.40							
6	雨	7.3	8.0	0.2	7.42							
7	晴	9.4	8.2	0.4	7.48							
8	晴	4.1	8.1	0.4	7.34							
9	晴	5.7	7.8	0.5	7.36	37.3	46.0	85	7.4	<0.03	<0.02	
10	晴	0.5	7.6	0.4	7.36							
11	晴	6.5	7.3	0.3	7.53							
12	曇	4.6	7.3	0.3	7.36							
13	晴	6.5	7.6	0.3	7.41							
14	晴	7.7	7.3	0.3	7.43							
15	曇	7.5	7.4	0.7	7.49							
16	晴	3.3	7.2	0.4	7.36							
17	晴	7.4	7.0	0.5	7.36							
18	曇	4.1	7.3	0.9	7.33							
19	曇	7.9	7.4	0.4	7.33							
20	晴	10.8	7.1	0.5	7.35							
21	晴	8.3	7.2	0.7	7.36							
22	晴	8.1	7.5	1.1	7.48							
23	晴	7.8	7.5	0.9	7.31	37.6	46.1	84	8.1	<0.03	<0.02	
24	晴	7.9	7.5	0.8	7.38							
25	晴	10.0	7.6	1.1	7.34							
26	晴	11.5	7.6	0.7	7.33							
27	曇	5.0	7.2	0.9	7.36							
28	晴	8.6	7.0	1.1	7.25							
29	晴	6.2	7.2	1.4	7.35							
30	晴	5.8	6.9	1.2	7.39							
31	晴	5.2	6.7	1.1	7.33							
平均		6.8	7.6	0.6	7.38	37.4	46.0	84	7.8	<0.03	<0.02	
最高		11.5	9.0	1.4	7.53	37.6	46.1	85	8.1	<0.03	<0.02	
最低		0.5	6.7	0.1	7.25	37.3	46.0	84	7.4	<0.03	<0.02	