

令和 7年 2月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	5.6	6.0	7.3	7.63							
2	雨	5.8	6.1	8.3	7.63							
3	曇	7.9	5.9	9.0	7.69							
4	晴	5.3	6.1	8.0	7.75							
5	晴	1.5	6.0	10.3	7.90							
6	晴	1.1	5.4	10.0	7.81	43.2	52.2	130	7.0			
7	晴	2.1	5.5	16.6	7.71							
8	晴	1.8	5.5	16.9	7.71							
9	晴	3.1	5.5	16.5	7.67							
10	晴	5.3	5.4	16.8	7.72							
11	晴	6.8	5.7	21.0	7.80							
12	晴	6.8	5.8	16.4	7.67							
13	晴	9.6	6.0	15.6	7.82							
14	晴	7.3	5.8	17.4	7.77							
15	晴	7.8	6.1	18.4	7.67							
16	曇	8.0	6.2	19.1	7.65							
17	晴	10.9	6.0	19.3	7.73							
18	晴	4.5	5.7	19.7	7.71							
19	晴	3.2	5.8	20.5	7.82							
20	晴	3.4	5.5	20.4	7.69	47.0	55.7	118	8.0	0.13	0.03	
21	曇	0.7	5.3	19.5	7.73							
22	晴	4.2	5.7	18.6	7.63							
23	晴	2.0	5.5	19.2	7.77							
24	晴	3.5	5.9	18.2	7.73							
25	晴	5.9	5.5	15.7	7.79							
26	晴	10.0	5.8	16.2	7.81							
27	晴	10.1	5.9	18.2	7.70							
28	晴	11.4	6.1	17.1	7.77							
平均		5.6	5.8	16.1	7.73	45.1	54.0	124	7.5	0.13	0.03	
最高		11.4	6.2	21.0	7.90	47.0	55.7	130	8.0	0.13	0.03	
最低		0.7	5.3	7.3	7.63	43.2	52.2	118	7.0	0.13	0.03	

令和 7年 2月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	5.6	7.0	1.1	7.21							
2	雨	5.8	7.1	1.1	7.27							
3	曇	7.9	6.8	1.1	7.31							
4	晴	5.3	7.0	1.2	7.34							
5	晴	1.5	7.0	1.2	7.47							
6	晴	1.1	6.6	1.5	7.33	39.5	52.3	118	9.8			
7	晴	2.1	6.5	1.2	7.22							
8	晴	1.8	6.5	1.5	7.22							
9	晴	3.1	6.0	1.1	7.22							
10	晴	5.3	6.2	1.0	7.34							
11	晴	6.8	6.1	1.2	7.30							
12	晴	6.8	6.4	1.6	7.28							
13	晴	9.6	6.6	1.3	7.21							
14	晴	7.3	6.7	1.5	7.23							
15	晴	7.8	7.0	1.3	7.24							
16	曇	8.0	7.2	1.0	7.23							
17	晴	10.9	7.1	1.3	7.33							
18	晴	4.5	6.8	1.6	7.22							
19	晴	3.2	6.8	1.8	7.30							
20	晴	3.4	6.4	2.3	7.23	43.1	54.7	111	11.0	<0.03	<0.02	
21	曇	0.7	6.3	1.9	7.24							
22	晴	4.2	6.5	2.0	7.15							
23	晴	2.0	6.0	1.7	7.27							
24	晴	3.5	6.5	1.4	7.27							
25	晴	5.9	6.3	1.6	7.28							
26	晴	10.0	6.5	1.9	7.38							
27	晴	10.1	6.8	1.6	7.23							
28	晴	11.4	7.1	1.3	7.26							
平均		5.6	6.6	1.4	7.27	41.3	53.5	114	10.4	<0.03	<0.02	
最高		11.4	7.2	2.3	7.47	43.1	54.7	118	11.0	<0.03	<0.02	
最低		0.7	6.0	1.0	7.15	39.5	52.3	111	9.8	<0.03	<0.02	