

令和 7年 3月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果（沈砂池）									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	15.1	6.4	16.3	7.77							
2	曇	15.3	6.7	15.5	7.70							
3	雨	14.8	6.6	22.4	7.71							
4	雨	5.4	6.8	12.0	7.78							
5	曇	12.6	6.7	11.5	7.79							
6	曇	8.9	6.8	11.5	7.80	43.9	51.9	112	8.7	0.60	0.12	
7	晴	7.5	6.6	10.6	7.80							
8	曇	7.3	7.1	10.3	7.73							
9	晴	8.8	7.3	10.7	7.78							
10	晴	11.2	6.9	12.4	7.69							
11	雨	9.5	7.3	11.3	7.81							
12	曇	13.9	7.6	25.1	7.78							
13	晴	14.9	7.7	10.6	7.75	40.5	49.1	83	7.9	0.61	0.12	
14	晴	12.3	7.6	12.6	7.76							
15	曇	11.2	8.0	11.0	7.69							
16	雨	10.1	7.5	9.5	7.78							
17	晴	9.4	7.5	9.9	7.83							
18	晴	6.9	7.5	7.0	7.84							
19	晴	6.7	7.8	7.5	7.71							
20	晴	7.3	8.0	6.9	7.85							
21	晴	12.1	7.7	7.5	7.81							
22	晴	15.6	8.5	6.8	7.83							
23	晴	17.3	8.5	6.1	7.79							
24	曇	16.1	8.5	5.7	7.77							
25	晴	15.9	9.1	4.6	7.82							
26	晴	21.6	9.5	7.4	7.82							
27	曇	16.9	9.5	4.8	7.82							
28	曇	20.9	10.0	5.5	7.82							
29	曇	12.2	10.3	4.8	7.57							
30	晴	12.9	9.1	4.8	7.76							
31	曇	9.0	9.5	4.6	7.70							
平均		12.2	7.9	9.9	7.77	42.2	50.5	98	8.3	0.60	0.12	
最高		21.6	10.3	25.1	7.85	43.9	51.9	112	8.7	0.61	0.12	
最低		5.4	6.4	4.6	7.57	40.5	49.1	83	7.9	0.60	0.12	

令和 7年 3月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄 水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	15.1	7.5	1.3	7.22							
2	曇	15.3	7.9	0.8	7.24							
3	雨	14.8	7.9	1.5	7.27							
4	雨	5.4	8.0	1.0	7.33							
5	曇	12.6	8.0	1.2	7.37							
6	曇	8.9	8.0	1.5	7.29	40.0	51.8	96	12	0.07	0.03	
7	晴	7.5	7.9	1.0	7.31							
8	曇	7.3	8.3	0.7	7.27							
9	晴	8.8	8.5	0.7	7.29							
10	晴	11.2	8.0	0.5	7.29							
11	雨	9.5	8.3	0.7	7.30							
12	曇	13.9	8.6	0.7	7.34							
13	晴	14.9	9.0	0.8	7.27	38.1	49.3	83	11	0.08	0.04	
14	晴	12.3	9.2	0.5	7.26							
15	曇	11.2	9.6	0.4	7.20							
16	雨	10.1	9.0	0.4	7.26							
17	晴	9.4	9.0	0.4	7.39							
18	晴	6.9	8.8	0.5	7.33							
19	晴	6.7	9.0	0.6	7.31							
20	晴	7.3	9.5	0.6	7.38							
21	晴	12.1	9.0	0.5	7.45							
22	晴	15.6	9.8	0.5	7.38							
23	晴	17.3	9.5	0.4	7.37							
24	曇	16.1	9.7	0.2	7.38							
25	晴	15.9	10.4	0.4	7.38							
26	晴	21.6	11.0	0.7	7.45							
27	曇	16.9	11.2	0.4	7.33							
28	曇	20.9	11.8	0.6	7.38							
29	曇	12.2	12.2	0.5	7.53							
30	晴	12.9	11.2	0.5	7.64							
31	曇	9.0	11.1	0.3	7.32							
平均		12.2	9.3	0.7	7.34	39.0	50.6	90	12	0.08	0.04	
最高		21.6	12.2	1.5	7.64	40.0	51.8	96	12	0.08	0.04	
最低		5.4	7.5	0.2	7.20	38.1	49.3	83	11	0.07	0.03	