

令和 8年 1月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	7.6	8.2	8.2	7.81							
2	晴	3.0	8.0	9.5	7.83							
3	晴	4.8	9.0	9.6	7.81							
4	晴	5.6	7.2	8.3	7.80							
5	晴	7.3	7.3	8.1	7.68							
6	晴	7.3	7.4	6.7	7.78							
7	曇	4.5	7.3	6.3	7.78							
8	晴	8.1	7.2	6.2	7.80	42.7	50.5	86	6.3	0.14	0.03	
9	晴	2.5	6.8	9.2	7.78							
10	晴	2.5	7.3	9.2	7.75							
11	曇	10.7	7.5	9.3	7.82							
12	晴	3.5	6.2	7.3	7.82							
13	晴	6.9	6.6	5.5	7.75							
14	晴	6.6	6.7	5.5	7.83							
15	晴	5.5	6.4	6.6	7.83							
16	晴	12.1	6.5	8.2	7.78							
17	晴	12.5	6.9	8.3	7.78							
18	晴	8.3	6.9	6.8	7.75							
19	晴	9.9	6.5	6.2	7.72							
20	晴	11.5	6.7	5.6	7.72							
21	晴	3.1	6.5	5.8	7.82							
22	晴	3.1	6.2	6.2	7.75	40.6	51.9	80	6.5	0.16	0.02	
23	晴	1.2	6.0	8.0	7.79							
24	晴	2.9	6.0	8.8	7.83							
25	晴	4.1	6.0	9.4	7.78							
26	晴	1.0	5.6	8.6	7.80							
27	晴	5.7	5.6	9.0	7.74							
28	晴	7.4	6.0	9.9	7.85							
29	晴	5.2	6.0	9.1	7.84							
30	晴	1.2	5.7	10.1	7.79							
31	晴	3.4	6.0	10.2	7.73							
平均		5.8	6.7	7.9	7.79	41.6	51.2	83	6.4	0.15	0.02	
最高		12.5	9.0	10.2	7.85	42.7	51.9	86	6.5	0.16	0.03	
最低		1.0	5.6	5.5	7.68	40.6	50.5	80	6.3	0.14	0.02	

令和 8年 1月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	7.6	9.0	0.1	7.47							
2	晴	3.0	9.0	0.3	7.49							
3	晴	4.8	8.0	0.2	7.46							
4	晴	5.6	7.9	0.4	7.47							
5	晴	7.3	8.0	0.3	7.31							
6	晴	7.3	8.1	0.2	7.44							
7	曇	4.5	8.0	0.3	7.43							
8	晴	8.1	8.0	0.4	7.43	39.7	50.3	86	9.1	<0.03	0.03	
9	晴	2.5	7.6	0.4	7.38							
10	晴	2.5	8.1	0.5	7.38							
11	曇	10.7	8.0	0.3	7.44							
12	晴	3.5	7.1	0.4	7.46							
13	晴	6.9	7.0	0.4	7.33							
14	晴	6.6	7.2	0.4	7.50							
15	晴	5.5	7.2	0.3	7.45							
16	晴	12.1	7.4	0.4	7.42							
17	晴	12.5	8.1	0.4	7.33							
18	晴	8.3	8.1	0.5	7.37							
19	晴	9.9	7.6	0.3	7.33							
20	晴	11.5	7.7	0.5	7.36							
21	晴	3.1	7.6	0.4	7.50							
22	晴	3.1	7.3	0.4	7.40	40.6	51.7	78	9.0	<0.03	<0.02	
23	晴	1.2	7.0	0.4	7.40							
24	晴	2.9	7.0	0.5	7.41							
25	晴	4.1	7.1	0.2	7.41							
26	晴	1.0	6.4	0.3	7.47							
27	晴	5.7	6.2	0.4	7.35							
28	晴	7.4	6.5	0.4	7.57							
29	晴	5.2	6.6	0.6	7.44							
30	晴	1.2	6.5	0.6	7.41							
31	晴	3.4	7.0	0.6	7.36							
平均		5.8	7.5	0.4	7.42	40.2	51.0	82	9.0	<0.03	<0.02	
最高		12.5	9.0	0.6	7.57	40.6	51.7	86	9.1	<0.03	0.03	
最低		1.0	6.2	0.1	7.31	39.7	50.3	78	9.0	<0.03	<0.02	