

令和 8年 8月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果（沈砂池）									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	31.7	25.0	5.7	7.84							
2	晴	36.3	27.7	5.6	7.89							
3	曇	30.1	24.5	5.8	7.88							
4	曇	27.8	24.6	5.9	7.83							
5	晴	30.7	24.6	5.4	7.88							
6	晴	33.7	24.8	5.6	7.89	43.3	47.7	72	4.0	0.14	<0.02	
7	晴	33.0	25.1	6.3	7.88							
8	晴	29.4	26.3	5.3	7.87							
9	晴	33.1	26.1	5.5	7.91							
10	曇	30.5	24.7	5.7	7.89							
11	曇	26.1	25.0	5.0	7.88							
12	曇	29.1	24.7	5.5	7.87							
13	晴	28.3	24.6	4.6	7.88							
14	晴	29.4	24.6	5.1	7.85							
15	晴	29.3	25.8	5.5	7.90							
16	晴	27.5	25.0	5.6	7.92							
17	晴	29.8	24.7	5.3	7.88							
18	晴	29.6	24.7	5.2	7.84							
19	晴	31.3	24.7	5.2	7.88							
20	曇	27.8	24.5	4.7	7.85	42.5	47.1	93	4.6	0.15	<0.02	
21	晴	29.7	24.7	4.4	7.86							
22	晴	28.4	25.0	4.5	7.89							
23	晴	30.3	25.0	4.2	7.89							
24	晴	31.9	25.0	3.8	7.89							
25	曇	28.8	25.1	5.3	7.85							
26	晴	33.3	25.2	3.9	7.89							
27	曇	31.8	25.2	4.8	7.87							
28	曇	25.1	25.2	4.2	7.87							
29	曇	28.3	25.0	3.6	7.89							
30	晴	29.6	25.4	4.1	7.83							
31	曇	28.3	25.1	4.3	7.90							
平均		30.0	25.1	5.0	7.88	42.9	47.4	82	4.3	0.14	<0.02	
最高		36.3	27.7	6.3	7.92	43.3	47.7	93	4.6	0.15	<0.02	
最低		25.1	24.5	3.6	7.83	42.5	47.1	72	4.0	0.14	<0.02	

令和 8年 8月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄 水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	31.7	26.6	0.2	7.53							
2	晴	36.3	25.8	0.5	7.60							
3	曇	30.1	26.6	0.2	7.64							
4	曇	27.8	26.2	0.2	7.51							
5	晴	30.7	26.3	0.3	7.52							
6	晴	33.7	26.5	0.4	7.57	40.0	48.0	85	6.3	<0.03	<0.02	
7	晴	33.0	26.8	0.3	7.56							
8	晴	29.4	28.3	0.4	7.58							
9	晴	33.1	28.7	0.2	7.71							
10	曇	30.5	27.0	0.4	7.68							
11	曇	26.1	27.0	0.4	7.61							
12	曇	29.1	26.5	0.1	7.64							
13	晴	28.3	26.3	0.3	7.65							
14	晴	29.4	26.5	0.3	7.66							
15	晴	29.3	27.8	0.3	7.71							
16	晴	27.5	27.0	0.3	7.72							
17	晴	29.8	26.5	0.2	7.69							
18	晴	29.6	26.5	0.3	7.52							
19	晴	31.3	26.4	0.4	7.57							
20	曇	27.8	26.4	0.4	7.56	39.4	46.8	94	6.6	<0.03	<0.02	
21	晴	29.7	26.5	0.4	7.54							
22	晴	28.4	26.0	0.6	7.58							
23	晴	30.3	28.1	0.3	7.59							
24	晴	31.9	26.9	0.3	7.65							
25	曇	28.8	26.9	0.5	7.52							
26	晴	33.3	27.0	0.3	7.54							
27	曇	31.8	27.1	0.3	7.54							
28	曇	25.1	26.9	0.4	7.54							
29	曇	28.3	26.5	0.4	7.53							
30	晴	29.6	27.1	0.3	7.58							
31	曇	28.3	26.7	0.3	7.60							
平均		30.0	26.8	0.3	7.59	39.7	47.4	90	6.4	<0.03	<0.02	
最高		36.3	28.7	0.6	7.72	40.0	48.0	94	6.6	<0.03	<0.02	
最低		25.1	25.8	0.1	7.51	39.4	46.8	85	6.3	<0.03	<0.02	