

令和2年8月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	30.0	20.5	212.1	7.86	—	—	—	—	—	—	
2	曇	28.0	20.6	167.8	7.82	—	—	—	—	—	—	
3	晴	27.6	21.8	134.6	7.73	—	—	—	—	—	—	
4	晴	29.1	22.2	86.7	7.73	33.2	38.7	190	3.4	3.80	0.12	
5	晴	28.3	22.3	96.3	7.72	—	—	—	—	—	—	
6	曇	28.6	22.6	75.8	7.70	—	—	—	—	—	—	
7	晴	29.5	22.6	75.7	7.80	—	—	—	—	—	—	
8	晴	30.5	20.6	78.2	7.67	—	—	—	—	—	—	
9	晴	33.0	22.1	59.4	7.68	—	—	—	—	—	—	
10	晴	30.1	23.3	44.3	7.73	—	—	—	—	—	—	
11	曇	30.3	23.5	42.6	7.72	—	—	—	—	—	—	
12	晴	30.8	23.7	30.3	7.59	—	—	—	—	—	—	
13	晴	31.5	23.8	33.4	7.69	—	—	—	—	—	—	
14	晴	31.3	24.1	24.4	7.64	—	—	—	—	—	—	
15	晴	35.5	23.0	22.4	7.69	—	—	—	—	—	—	
16	晴	36.5	23.6	20.8	7.72	—	—	—	—	—	—	
17	晴	31.5	24.8	13.8	7.72	—	—	—	—	—	—	
18	晴	31.0	24.9	15.5	7.72	38.2	39.9	100	3.0	0.68	<0.02	
19	晴	31.0	24.9	13.0	7.66	—	—	—	—	—	—	
20	晴	30.7	25.1	11.4	7.67	—	—	—	—	—	—	
21	晴	30.9	25.3	9.3	7.66	—	—	—	—	—	—	
22	晴	34.5	24.6	6.0	7.78	—	—	—	—	—	—	
23	曇	28.0	24.2	6.2	7.74	—	—	—	—	—	—	
24	晴	28.6	25.4	27.9	7.71	—	—	—	—	—	—	
25	晴	29.0	25.3	7.3	7.70	—	—	—	—	—	—	
26	晴	29.1	25.3	4.9	7.67	—	—	—	—	—	—	
27	晴	31.1	25.5	6.6	7.73	—	—	—	—	—	—	
28	晴	29.3	25.6	6.0	7.68	—	—	—	—	—	—	
29	晴	33.5	24.9	5.4	7.70	—	—	—	—	—	—	
30	晴	34.0	25.1	5.4	7.76	—	—	—	—	—	—	
31	曇	30.2	25.9	5.3	7.73	—	—	—	—	—	—	
平均		30.7	23.8	43.5	7.71	35.7	39.3	145	3.2	2.24	0.06	
最高		36.5	25.9	212.1	7.86	38.2	39.9	190	3.4	3.80	0.12	
最低		27.6	20.5	4.9	7.59	33.2	38.7	100	3.0	0.68	<0.02	

令和2年8月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	30.0	22.5	1.9	7.05	—	—	—	—	—	—	
2	曇	28.0	22.0	1.7	7.05	—	—	—	—	—	—	
3	晴	27.6	23.0	1.4	7.05	—	—	—	—	—	—	
4	晴	29.1	23.3	1.7	7.11	25.5	37.3	83	10.5	0.08	<0.02	
5	晴	28.3	23.5	1.7	7.10	—	—	—	—	—	—	
6	曇	28.6	23.6	1.7	7.09	—	—	—	—	—	—	
7	晴	29.5	23.8	1.3	7.15	—	—	—	—	—	—	
8	晴	30.5	24.0	1.4	7.14	—	—	—	—	—	—	
9	晴	33.0	24.3	1.2	7.19	—	—	—	—	—	—	
10	晴	30.1	24.5	1.0	7.25	—	—	—	—	—	—	
11	曇	30.3	24.7	1.2	7.24	—	—	—	—	—	—	
12	晴	30.8	24.9	1.0	7.25	—	—	—	—	—	—	
13	晴	31.5	25.0	0.9	7.35	—	—	—	—	—	—	
14	晴	31.3	25.1	1.3	7.31	—	—	—	—	—	—	
15	晴	35.5	25.2	1.2	7.31	—	—	—	—	—	—	
16	晴	36.5	25.6	1.1	7.36	—	—	—	—	—	—	
17	晴	31.5	25.7	1.2	7.35	—	—	—	—	—	—	
18	晴	31.0	25.7	1.5	7.31	31.8	39.6	88	8.0	0.07	<0.02	
19	晴	31.0	25.8	1.3	7.28	—	—	—	—	—	—	
20	晴	30.7	25.9	1.4	7.32	—	—	—	—	—	—	
21	晴	30.9	26.0	1.3	7.35	—	—	—	—	—	—	
22	晴	34.5	25.8	1.1	7.35	—	—	—	—	—	—	
23	曇	28.0	25.9	1.5	7.38	—	—	—	—	—	—	
24	晴	28.6	26.2	1.2	7.45	—	—	—	—	—	—	
25	晴	29.0	26.3	1.3	7.40	—	—	—	—	—	—	
26	晴	29.1	26.2	1.5	7.32	—	—	—	—	—	—	
27	晴	31.1	26.3	1.6	7.43	—	—	—	—	—	—	
28	晴	29.3	26.4	1.4	7.39	—	—	—	—	—	—	
29	晴	33.5	26.6	1.5	7.39	—	—	—	—	—	—	
30	晴	34.0	26.6	1.4	7.43	—	—	—	—	—	—	
31	曇	30.2	26.8	1.4	7.45	—	—	—	—	—	—	
平均		30.7	25.1	1.4	7.28	28.6	38.4	86	9.2	0.08	<0.02	
最高		36.5	26.8	1.9	7.45	31.8	39.6	88	10.5	0.08	<0.02	
最低		27.6	22.0	0.9	7.05	25.5	37.3	83	8.0	0.07	<0.02	