

令和2年11月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	21.5	15.8	6.6	7.59	—	—	—	—	—	—	
2	曇	18.5	17.1	8.3	7.74	—	—	—	—	—	—	
3	晴	20.0	17.0	5.5	7.76	—	—	—	—	—	—	
4	晴	11.5	16.8	6.7	7.78	39.8	44.1	93	3.5	0.29	<0.02	
5	晴	11.7	16.6	5.3	7.70	—	—	—	—	—	—	
6	曇	13.7	16.6	6.0	7.72	—	—	—	—	—	—	
7	曇	19.0	15.6	3.8	7.72	—	—	—	—	—	—	
8	曇	18.0	15.3	4.7	7.66	—	—	—	—	—	—	
9	晴	14.3	16.3	5.5	7.79	—	—	—	—	—	—	
10	晴	10.7	16.0	5.0	7.79	—	—	—	—	—	—	
11	晴	10.7	15.8	4.4	7.79	—	—	—	—	—	—	
12	曇	12.3	15.7	5.3	7.77	—	—	—	—	—	—	
13	晴	13.7	15.6	4.2	7.72	—	—	—	—	—	—	
14	晴	19.5	14.2	4.5	7.68	—	—	—	—	—	—	
15	晴	19.0	14.0	3.3	7.53	—	—	—	—	—	—	
16	晴	16.5	15.5	4.0	7.77	—	—	—	—	—	—	
17	晴	15.8	15.5	4.1	7.73	43.6	44.9	110	4.1	0.24	<0.02	
18	晴	18.6	15.6	3.4	7.71	—	—	—	—	—	—	
19	晴	18.6	15.8	4.7	7.71	—	—	—	—	—	—	
20	雨	20.0	15.0	3.2	7.69	—	—	—	—	—	—	
21	晴	17.3	14.5	3.0	7.70	—	—	—	—	—	—	
22	曇	17.8	14.1	2.5	7.56	—	—	—	—	—	—	
23	晴	19.0	14.4	3.3	7.71	—	—	—	—	—	—	
24	晴	13.2	15.2	3.1	7.77	—	—	—	—	—	—	
25	晴	14.0	15.3	2.8	7.71	—	—	—	—	—	—	
26	晴	11.3	15.0	2.7	7.70	—	—	—	—	—	—	
27	晴	13.6	15.0	2.6	7.75	—	—	—	—	—	—	
28	晴	14.0	13.5	2.1	7.69	—	—	—	—	—	—	
29	晴	13.5	13.0	2.0	7.67	—	—	—	—	—	—	
30	晴	10.3	14.4	2.2	7.76	—	—	—	—	—	—	
平均		15.6	15.3	4.2	7.71	41.7	44.5	102	3.8	0.26	<0.02	
最高		21.5	17.1	8.3	7.79	43.6	44.9	110	4.1	0.29	<0.02	
最低		10.3	13.0	2.0	7.53	39.8	44.1	93	3.5	0.24	<0.02	

令和2年11月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	21.5	18.7	0.4	7.41	—	—	—	—	—	—	
2	曇	18.5	18.7	0.1	7.51	—	—	—	—	—	—	
3	晴	20.0	18.2	0.3	7.39	—	—	—	—	—	—	
4	晴	11.5	18.4	0.1	7.41	34.8	41.4	85	8.1	<0.03	<0.02	
5	晴	11.7	18.0	0.2	7.42	—	—	—	—	—	—	
6	曇	13.7	18.0	0.1	7.43	—	—	—	—	—	—	
7	曇	19.0	18.1	0.2	7.48	—	—	—	—	—	—	
8	曇	18.0	18.2	0.2	7.49	—	—	—	—	—	—	
9	晴	14.3	18.0	0.2	7.49	—	—	—	—	—	—	
10	晴	10.7	17.6	0.2	7.48	—	—	—	—	—	—	
11	晴	10.7	17.3	0.3	7.45	—	—	—	—	—	—	
12	曇	12.3	17.2	0.4	7.47	—	—	—	—	—	—	
13	晴	13.7	17.2	0.2	7.44	—	—	—	—	—	—	
14	晴	19.5	17.2	0.3	7.51	—	—	—	—	—	—	
15	晴	19.0	16.7	0.3	7.52	—	—	—	—	—	—	
16	晴	16.5	17.1	0.2	7.50	—	—	—	—	—	—	
17	晴	15.8	17.1	0.1	7.48	38.0	48.3	100	8.2	<0.03	<0.02	
18	晴	18.6	17.2	0.2	7.43	—	—	—	—	—	—	
19	晴	18.6	17.4	0.2	7.40	—	—	—	—	—	—	
20	雨	20.0	17.6	0.2	7.42	—	—	—	—	—	—	
21	晴	17.3	17.5	0.3	7.42	—	—	—	—	—	—	
22	曇	17.8	17.2	0.3	7.43	—	—	—	—	—	—	
23	晴	19.0	17.1	0.2	7.46	—	—	—	—	—	—	
24	晴	13.2	16.8	0.1	7.49	—	—	—	—	—	—	
25	晴	14.0	16.8	0.1	7.42	—	—	—	—	—	—	
26	晴	11.3	16.5	0.2	7.40	—	—	—	—	—	—	
27	晴	13.6	16.3	0.2	7.47	—	—	—	—	—	—	
28	晴	14.0	16.5	0.1	7.52	—	—	—	—	—	—	
29	晴	13.5	15.9	0.2	7.52	—	—	—	—	—	—	
30	晴	10.3	15.8	0.1	7.55	—	—	—	—	—	—	
平均		15.6	17.3	0.2	7.46	36.4	44.8	92	8.2	<0.03	<0.02	
最高		21.5	18.7	0.4	7.55	38.0	48.3	100	8.2	<0.03	<0.02	
最低		10.3	15.8	0.1	7.39	34.8	41.4	85	8.1	<0.03	<0.02	