

令和3年2月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	8.1	8.5	2.2	7.66	—	—	—	—	—	—	
2	曇	7.8	9.0	2.0	7.73	42.3	47.2	91	7.0	0.12	<0.02	
3	晴	4.3	8.6	2.1	7.70	—	—	—	—	—	—	
4	晴	4.0	8.5	2.8	7.71	—	—	—	—	—	—	
5	晴	4.5	8.3	2.2	7.73	—	—	—	—	—	—	
6	晴	13.0	7.3	2.2	7.42	—	—	—	—	—	—	
7	晴	13.0	7.5	2.2	7.54	—	—	—	—	—	—	
8	晴	7.6	8.7	2.1	7.89	—	—	—	—	—	—	
9	晴	2.4	8.5	2.0	7.72	—	—	—	—	—	—	
10	晴	5.4	8.4	1.9	7.65	—	—	—	—	—	—	
11	晴	10.5	7.3	3.2	7.31	—	—	—	—	—	—	
12	曇	9.0	8.8	2.0	7.68	—	—	—	—	—	—	
13	晴	13.5	7.8	2.6	7.59	—	—	—	—	—	—	
14	曇	10.0	8.1	2.7	7.56	—	—	—	—	—	—	
15	雨	12.8	9.6	1.9	7.63	—	—	—	—	—	—	
16	曇	7.6	9.4	2.5	7.67	40.8	42.4	92	7.4	0.10	<0.02	
17	曇	5.6	9.1	2.1	7.65	—	—	—	—	—	—	
18	晴	1.5	8.6	1.8	7.60	—	—	—	—	—	—	
19	晴	3.6	8.5	2.1	7.56	—	—	—	—	—	—	
20	晴	10.0	7.5	2.8	7.36	—	—	—	—	—	—	
21	晴	16.0	9.0	2.0	7.59	—	—	—	—	—	—	
22	晴	12.0	9.2	2.2	7.59	—	—	—	—	—	—	
23	晴	11.0	8.4	3.0	7.62	—	—	—	—	—	—	
24	晴	4.8	9.2	2.1	7.70	—	—	—	—	—	—	
25	晴	7.0	9.0	2.3	7.61	—	—	—	—	—	—	
26	雨	8.6	9.2	1.9	7.66	—	—	—	—	—	—	
27	晴	7.0	7.6	2.0	7.36	—	—	—	—	—	—	
28	晴	9.5	7.8	2.7	7.50	—	—	—	—	—	—	
平均		8.2	8.5	2.3	7.61	41.6	44.8	92	7.2	0.11	<0.02	
最高		16.0	9.6	3.2	7.89	42.3	47.2	92	7.4	0.12	<0.02	
最低		1.5	7.3	1.8	7.31	40.8	42.4	91	7.0	0.10	<0.02	

令和3年2月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	8.1	9.6	0.2	7.44	—	—	—	—	—	—	
2	曇	7.8	10.0	0.1	7.50	39.3	48.1	92	10.0	<0.03	<0.02	
3	晴	4.3	9.9	0.3	7.46	—	—	—	—	—	—	
4	晴	4.0	9.8	0.2	7.48	—	—	—	—	—	—	
5	晴	4.5	9.6	0.2	7.46	—	—	—	—	—	—	
6	晴	13.0	9.6	0.3	7.41	—	—	—	—	—	—	
7	晴	13.0	10.9	0.4	7.52	—	—	—	—	—	—	
8	晴	7.6	10.0	0.2	7.60	—	—	—	—	—	—	
9	晴	2.4	9.8	0.3	7.51	—	—	—	—	—	—	
10	晴	5.4	9.5	0.3	7.48	—	—	—	—	—	—	
11	晴	10.5	9.7	0.3	7.47	—	—	—	—	—	—	
12	曇	9.0	9.8	0.3	7.46	—	—	—	—	—	—	
13	晴	13.5	10.0	0.2	7.49	—	—	—	—	—	—	
14	曇	10.0	10.3	0.2	7.34	—	—	—	—	—	—	
15	雨	12.8	10.8	0.2	7.40	—	—	—	—	—	—	
16	曇	7.6	10.7	0.2	7.42	37.2	45.5	88	10.7	<0.03	<0.02	
17	曇	5.6	10.4	0.3	7.40	—	—	—	—	—	—	
18	晴	1.5	9.8	0.3	7.37	—	—	—	—	—	—	
19	晴	3.6	9.6	0.6	7.41	—	—	—	—	—	—	
20	晴	10.0	9.8	0.2	7.30	—	—	—	—	—	—	
21	晴	16.0	11.2	0.3	7.35	—	—	—	—	—	—	
22	晴	12.0	10.5	0.4	7.45	—	—	—	—	—	—	
23	晴	11.0	10.8	0.2	7.41	—	—	—	—	—	—	
24	晴	4.8	10.5	0.6	7.42	—	—	—	—	—	—	
25	晴	7.0	10.1	0.4	7.47	—	—	—	—	—	—	
26	雨	8.6	10.3	0.4	7.33	—	—	—	—	—	—	
27	晴	7.0	10.1	0.3	7.32	—	—	—	—	—	—	
28	晴	9.5	10.1	0.5	7.35	—	—	—	—	—	—	
平均		8.2	10.1	0.3	7.43	38.2	46.8	90	10.4	<0.03	<0.02	
最高		16.0	11.2	0.6	7.60	39.3	48.1	92	10.7	<0.03	<0.02	
最低		1.5	9.5	0.1	7.30	37.2	45.5	88	10.0	<0.03	<0.02	