

令和3年3月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	13.2	9.3	1.8	7.64	—	—	—	—	—	—	
2	雨	14.8	9.8	1.9	7.63	38.2	42.4	82	6.8	0.09	<0.02	
3	晴	7.6	9.3	2.0	7.67	—	—	—	—	—	—	
4	晴	11.1	9.7	2.9	7.57	—	—	—	—	—	—	
5	曇	13.0	9.9	3.2	7.62	—	—	—	—	—	—	
6	曇	11.0	9.0	2.0	7.38	—	—	—	—	—	—	
7	曇	10.0	9.1	2.1	7.49	—	—	—	—	—	—	
8	雨	9.5	10.2	2.4	7.62	—	—	—	—	—	—	
9	晴	10.5	10.0	1.8	7.65	—	—	—	—	—	—	
10	晴	13.0	10.3	1.8	7.60	—	—	—	—	—	—	
11	晴	12.2	10.3	1.6	7.60	—	—	—	—	—	—	
12	曇	13.3	10.5	1.4	7.60	—	—	—	—	—	—	
13	曇	11.0	9.4	2.1	7.48	—	—	—	—	—	—	
14	晴	12.0	9.2	2.2	7.44	—	—	—	—	—	—	
15	晴	10.2	10.3	2.1	7.64	—	—	—	—	—	—	
16	晴	11.8	10.6	2.1	7.63	37.7	40.8	89	6.3	0.09	<0.02	
17	晴	13.9	10.8	1.9	7.62	—	—	—	—	—	—	
18	晴	14.6	10.9	2.1	7.65	—	—	—	—	—	—	
19	晴	13.0	11.2	2.3	7.68	—	—	—	—	—	—	
20	晴	17.5	10.2	2.1	7.48	—	—	—	—	—	—	
21	雨	12.0	11.5	2.4	7.43	—	—	—	—	—	—	
22	晴	9.8	12.3	133.0	7.51	—	—	—	—	—	—	
23	晴	8.6	12.5	33.6	7.50	—	—	—	—	—	—	
24	晴	13.5	12.0	10.1	7.61	—	—	—	—	—	—	
25	曇	14.4	12.2	7.4	7.58	—	—	—	—	—	—	
26	晴	13.3	12.1	6.9	7.60	—	—	—	—	—	—	
27	晴	17.0	11.2	8.2	7.43	—	—	—	—	—	—	
28	曇	17.0	11.8	12.3	7.57	—	—	—	—	—	—	
29	晴	17.0	13.2	18.2	7.58	—	—	—	—	—	—	
30	晴	16.6	13.3	23.3	7.51	—	—	—	—	—	—	
31	晴	16.5	13.4	16.1	7.42	—	—	—	—	—	—	
平均		12.9	10.8	10.1	7.56	38.0	41.6	86	6.6	0.09	<0.02	
最高		17.5	13.4	133.0	7.68	38.2	42.4	89	6.8	0.09	<0.02	
最低		7.6	9.0	1.4	7.38	37.7	40.8	82	6.3	0.09	<0.02	

令和3年3月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	13.2	10.3	0.2	7.36	—	—	—	—	—	—	
2	雨	14.8	10.9	0.4	7.38	34.5	40.8	82	10.4	<0.03	<0.02	
3	晴	7.6	10.5	0.4	7.38	—	—	—	—	—	—	
4	晴	11.1	10.6	0.4	7.34	—	—	—	—	—	—	
5	曇	13.0	11.1	0.4	7.31	—	—	—	—	—	—	
6	曇	11.0	11.3	0.2	7.32	—	—	—	—	—	—	
7	曇	10.0	11.5	0.2	7.39	—	—	—	—	—	—	
8	雨	9.5	11.3	0.3	7.37	—	—	—	—	—	—	
9	晴	10.5	11.1	0.3	7.42	—	—	—	—	—	—	
10	晴	13.0	11.4	0.5	7.30	—	—	—	—	—	—	
11	晴	12.2	11.6	0.3	7.37	—	—	—	—	—	—	
12	曇	13.3	11.8	0.5	7.32	—	—	—	—	—	—	
13	曇	11.0	11.7	0.3	7.36	—	—	—	—	—	—	
14	晴	12.0	11.6	0.5	7.42	—	—	—	—	—	—	
15	晴	10.2	11.5	0.4	7.41	—	—	—	—	—	—	
16	晴	11.8	11.8	0.4	7.45	34.7	43.1	90	9.9	<0.03	<0.02	
17	晴	13.9	12.1	0.4	7.45	—	—	—	—	—	—	
18	晴	14.6	12.1	0.4	7.40	—	—	—	—	—	—	
19	晴	13.0	12.5	0.5	7.45	—	—	—	—	—	—	
20	晴	17.5	12.7	0.4	7.43	—	—	—	—	—	—	
21	雨	12.0	12.8	0.2	7.34	—	—	—	—	—	—	
22	晴	9.8	13.1	0.3	7.37	—	—	—	—	—	—	
23	晴	8.6	13.3	0.7	7.19	—	—	—	—	—	—	
24	晴	13.5	13.0	1.0	7.22	—	—	—	—	—	—	
25	曇	14.4	13.1	0.9	7.23	—	—	—	—	—	—	
26	晴	13.3	13.1	0.5	7.26	—	—	—	—	—	—	
27	晴	17.0	13.3	0.4	7.21	—	—	—	—	—	—	
28	曇	17.0	12.6	0.4	7.32	—	—	—	—	—	—	
29	晴	17.0	13.9	0.5	7.24	—	—	—	—	—	—	
30	晴	16.6	14.1	0.5	7.14	—	—	—	—	—	—	
31	晴	16.5	14.3	0.7	7.03	—	—	—	—	—	—	
平均		12.9	12.1	0.4	7.33	34.6	42.0	86	10.2	<0.03	<0.02	
最高		17.5	14.3	1.0	7.45	34.7	43.1	90	10.4	<0.03	<0.02	
最低		7.6	10.3	0.2	7.03	34.5	40.8	82	9.9	<0.03	<0.02	