

令和3年11月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	17.0	17.4	2.3	7.62	—	—	—	—	—	—	
2	曇	17.6	17.4	2.5	7.55	46.4	50.3	91	5.2	0.14	0.06	
3	晴	20.0	16.8	2.4	7.44	—	—	—	—	—	—	
4	晴	15.6	17.1	2.2	7.61	—	—	—	—	—	—	
5	晴	13.9	17.0	2.1	7.60	—	—	—	—	—	—	
6	曇	15.0	16.4	2.0	7.42	—	—	—	—	—	—	
7	曇	16.5	16.3	1.9	7.59	—	—	—	—	—	—	
8	晴	18.8	16.5	2.2	7.64	—	—	—	—	—	—	
9	雨	17.0	16.7	1.9	7.59	—	—	—	—	—	—	
10	晴	11.9	16.3	2.3	7.66	—	—	—	—	—	—	
11	晴	13.2	16.0	2.4	7.63	—	—	—	—	—	—	
12	晴	13.1	15.8	7.7	7.62	—	—	—	—	—	—	
13	晴	15.0	15.1	4.2	7.62	—	—	—	—	—	—	
14	晴	17.0	15.0	3.5	7.58	—	—	—	—	—	—	
15	晴	13.7	15.1	2.8	7.63	—	—	—	—	—	—	
16	曇	12.6	15.1	5.4	7.70	46.6	50.2	83	4.9	0.22	0.04	
17	晴	12.1	15.1	3.0	7.66	—	—	—	—	—	—	
18	晴	14.0	15.0	4.6	7.71	—	—	—	—	—	—	
19	晴	12.0	14.6	3.9	7.70	—	—	—	—	—	—	
20	晴	15.0	14.3	3.7	7.67	—	—	—	—	—	—	
21	曇	12.0	14.4	3.2	7.52	—	—	—	—	—	—	
22	曇	16.4	14.6	3.6	7.74	—	—	—	—	—	—	
23	晴	13.0	13.9	3.2	7.65	—	—	—	—	—	—	
24	晴	9.4	13.8	3.2	7.78	—	—	—	—	—	—	
25	晴	10.5	13.6	3.3	7.76	—	—	—	—	—	—	
26	晴	10.9	13.5	3.4	7.76	—	—	—	—	—	—	
27	晴	11.0	13.0	3.1	7.68	—	—	—	—	—	—	
28	晴	12.0	12.6	2.6	7.63	—	—	—	—	—	—	
29	晴	8.6	12.8	3.1	7.76	—	—	—	—	—	—	
30	晴	9.7	12.7	3.5	7.77	—	—	—	—	—	—	
平均		13.8	15.1	3.2	7.64	46.5	50.2	87	5.0	0.18	0.05	
最高		20.0	17.4	7.7	7.78	46.6	50.3	91	5.2	0.22	0.06	
最低		8.6	12.6	1.9	7.42	46.4	50.2	83	4.9	0.14	0.04	

令和3年11月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	17.0	19.4	0.2	7.48	—	—	—	—	—	—	
2	曇	17.6	19.3	0.3	7.47	43.4	51.8	83	8.1	<0.03	0.02	
3	晴	20.0	19.2	0.2	7.40	—	—	—	—	—	—	
4	晴	15.6	19.1	0.2	7.45	—	—	—	—	—	—	
5	晴	13.9	19.0	0.2	7.45	—	—	—	—	—	—	
6	曇	15.0	18.8	0.2	7.41	—	—	—	—	—	—	
7	曇	16.5	18.6	0.2	7.44	—	—	—	—	—	—	
8	晴	18.8	18.6	0.2	7.50	—	—	—	—	—	—	
9	雨	17.0	18.5	0.2	7.45	—	—	—	—	—	—	
10	晴	11.9	18.3	0.2	7.47	—	—	—	—	—	—	
11	晴	13.2	18.1	0.1	7.48	—	—	—	—	—	—	
12	晴	13.1	17.8	0.1	7.46	—	—	—	—	—	—	
13	晴	15.0	17.5	0.2	7.41	—	—	—	—	—	—	
14	晴	17.0	17.4	0.1	7.43	—	—	—	—	—	—	
15	晴	13.7	17.3	0.1	7.42	—	—	—	—	—	—	
16	曇	12.6	17.1	0.2	7.46	41.2	49.6	79	9.7	<0.03	<0.02	
17	晴	12.1	17.1	0.2	7.43	—	—	—	—	—	—	
18	晴	14.0	17.1	0.2	7.40	—	—	—	—	—	—	
19	晴	12.0	16.8	0.2	7.46	—	—	—	—	—	—	
20	晴	15.0	16.7	0.3	7.45	—	—	—	—	—	—	
21	曇	12.0	16.4	0.2	7.44	—	—	—	—	—	—	
22	曇	16.4	16.6	0.2	7.51	—	—	—	—	—	—	
23	晴	13.0	16.4	0.2	7.46	—	—	—	—	—	—	
24	晴	9.4	15.9	0.3	7.47	—	—	—	—	—	—	
25	晴	10.5	15.4	0.2	7.47	—	—	—	—	—	—	
26	晴	10.9	15.4	0.3	7.43	—	—	—	—	—	—	
27	晴	11.0	15.3	0.2	7.45	—	—	—	—	—	—	
28	晴	12.0	14.9	0.4	7.48	—	—	—	—	—	—	
29	晴	8.6	14.7	0.2	7.43	—	—	—	—	—	—	
30	晴	9.7	14.8	0.1	7.49	—	—	—	—	—	—	
平均		13.8	17.2	0.2	7.45	42.3	50.7	81	8.9	<0.03	<0.02	
最高		20.0	19.4	0.4	7.51	43.4	51.8	83	9.7	<0.03	0.02	
最低		8.6	14.7	0.1	7.40	41.2	49.6	79	8.1	<0.03	<0.02	