

令和4年1月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	5.5	7.5	3.8	7.54	—	—	—	—	—	—	
2	晴	9.5	7.3	4.3	7.77	—	—	—	—	—	—	
3	晴	4.6	8.1	3.2	7.72	—	—	—	—	—	—	
4	晴	6.0	8.2	3.1	7.72	—	—	—	—	—	—	
5	晴	3.2	7.8	3.8	7.74	40.6	46.1	80	6.4	0.32	0.02	
6	雨	3.5	7.9	3.0	7.73	—	—	—	—	—	—	
7	晴	3.9	7.8	2.8	7.75	—	—	—	—	—	—	
8	曇	4.0	7.5	2.5	7.78	—	—	—	—	—	—	
9	晴	7.8	6.7	2.3	7.62	—	—	—	—	—	—	
10	晴	12.5	6.8	2.3	7.55	—	—	—	—	—	—	
11	曇	8.4	7.8	2.3	7.68	—	—	—	—	—	—	
12	晴	2.4	7.5	2.5	7.68	—	—	—	—	—	—	
13	晴	2.8	7.3	2.0	7.71	—	—	—	—	—	—	
14	晴	1.1	7.1	2.3	7.72	—	—	—	—	—	—	
15	曇	5.0	6.1	2.4	7.68	—	—	—	—	—	—	
16	晴	8.2	6.1	2.4	7.55	—	—	—	—	—	—	
17	晴	6.8	7.1	3.6	7.75	—	—	—	—	—	—	
18	晴	2.4	7.0	2.3	7.73	42.1	44.8	70	5.7	0.14	<0.02	
19	晴	2.6	6.7	3.0	7.74	—	—	—	—	—	—	
20	晴	1.8	7.0	2.8	7.74	—	—	—	—	—	—	
21	晴	1.9	6.6	3.6	7.74	—	—	—	—	—	—	
22	晴	6.0	5.8	3.1	7.62	—	—	—	—	—	—	
23	曇	6.0	5.7	3.5	7.45	—	—	—	—	—	—	
24	曇	5.8	6.6	3.2	7.70	—	—	—	—	—	—	
25	曇	6.6	6.7	3.9	7.73	—	—	—	—	—	—	
26	晴	5.5	6.8	4.2	7.71	—	—	—	—	—	—	
27	晴	5.8	6.7	3.7	7.74	—	—	—	—	—	—	
28	晴	4.1	6.8	2.9	7.75	—	—	—	—	—	—	
29	晴	10.0	6.1	3.1	7.58	—	—	—	—	—	—	
30	曇	7.0	6.0	3.0	7.53	—	—	—	—	—	—	
31	晴	4.1	7.0	2.8	7.69	—	—	—	—	—	—	
平均		5.3	7.0	3.0	7.68	41.4	45.4	75	6.0	0.23	<0.02	
最高		12.5	8.2	4.3	7.78	42.1	46.1	80	6.4	0.32	0.02	
最低		1.1	5.7	2.0	7.45	40.6	44.8	70	5.7	0.14	<0.02	

令和4年1月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	5.5	10.1	0.6	7.40	—	—	—	—	—	—	
2	晴	9.5	8.4	0.5	7.43	—	—	—	—	—	—	
3	晴	4.6	9.9	0.2	7.51	—	—	—	—	—	—	
4	晴	6.0	10.0	0.4	7.46	—	—	—	—	—	—	
5	晴	3.2	9.8	0.3	7.50	37.8	45.6	93	10.2	<0.03	<0.02	
6	雨	3.5	9.6	0.4	7.43	—	—	—	—	—	—	
7	晴	3.9	9.6	0.3	7.43	—	—	—	—	—	—	
8	曇	4.0	9.4	0.4	7.47	—	—	—	—	—	—	
9	晴	7.8	9.4	0.4	7.45	—	—	—	—	—	—	
10	晴	12.5	9.6	0.4	7.45	—	—	—	—	—	—	
11	曇	8.4	9.8	0.3	7.43	—	—	—	—	—	—	
12	晴	2.4	9.6	0.3	7.38	—	—	—	—	—	—	
13	晴	2.8	9.2	0.3	7.41	—	—	—	—	—	—	
14	晴	1.1	9.1	0.5	7.41	—	—	—	—	—	—	
15	曇	5.0	8.9	0.4	7.45	—	—	—	—	—	—	
16	晴	8.2	8.9	0.4	7.38	—	—	—	—	—	—	
17	晴	6.8	9.0	0.2	7.51	—	—	—	—	—	—	
18	晴	2.4	9.0	0.4	7.51	36.0	43.9	83	10.3	<0.03	<0.02	
19	晴	2.6	8.6	0.6	7.44	—	—	—	—	—	—	
20	晴	1.8	8.6	0.3	7.39	—	—	—	—	—	—	
21	晴	1.9	8.6	0.4	7.51	—	—	—	—	—	—	
22	晴	6.0	8.4	0.2	7.42	—	—	—	—	—	—	
23	曇	6.0	8.4	0.3	7.34	—	—	—	—	—	—	
24	曇	5.8	8.5	0.2	7.41	—	—	—	—	—	—	
25	曇	6.6	8.6	0.2	7.45	—	—	—	—	—	—	
26	晴	5.5	8.8	0.3	7.40	—	—	—	—	—	—	
27	晴	5.8	8.8	0.4	7.45	—	—	—	—	—	—	
28	晴	4.1	8.8	0.4	7.42	—	—	—	—	—	—	
29	晴	10.0	8.9	0.6	7.43	—	—	—	—	—	—	
30	曇	7.0	8.8	0.3	7.45	—	—	—	—	—	—	
31	晴	4.1	8.7	0.2	7.41	—	—	—	—	—	—	
平均		5.3	9.1	0.4	7.44	36.9	44.8	88	10.2	<0.03	<0.02	
最高		12.5	10.1	0.6	7.51	37.8	45.6	93	10.3	<0.03	<0.02	
最低		1.1	8.4	0.2	7.34	36.0	43.9	83	10.2	<0.03	<0.02	